

Overview of the Foundation Fieldbus device drivers

Sensor		FF	Emerson AMS	DeltaV	HIST tests																	ABB	Honeywell	Rockwell	Yokogawa	Invensys	
Name	Firmware version				DD-Revision (*1)	ITK test version	Emerson										Delta V										HHx75
							AMS	AMS	AMS	AMS	AMS	AMS	AMS	AMS	AMS	AMS	AMS	AMS	AMS	AMS	AMS						
VEGASON 6x	3.83	0401	5.0	>= 9.0	>= 8.4	X	X						X	X	X	X	X			X	X	X	X		X	X	
VEGACAL 6x	1.30	0401	5.0	>= 9.0	>= 8.4	X	X						X	X	X	X	X			X	X	X	X		X	X	
VEGADIF 65	1.04	0401	5.0	>= 9.0	>= 8.4	X	X						X	X	X	X	X			X	X	X	X				
FIBERTRAC 3x	1.7.0	0201	6.0	>= 9.0	>= 8.4	X	X		X	X			X	X	X	X	X	X		X	X	X	X		X		
	2.0.1	0301	6.2.0	>= 12	>= 12				X	X	X	X	X					X	X	X		X					
SOLITRAC 3x	1.7.0	0201	6.0	>= 9.0	>= 9.3	X	X		X	X			X	X		X	X	X	X		X	X	X		X		
	2.0.1	0301	6.2.0	>= 12	>= 12				X	X	X	X	X					X	X	X		X			X		
MINITRAC 3x	1.7.0	0201	6.0	>= 9.0	>= 8.4	X	X		X	X			X	X	X	X	X	X	X		X	X	X		X	X	
	2.0.1	0301	6.2.0	>= 12	>= 12				X	X	X	X	X					X	X	X		X			X		
POINTRAC 3x	1.7.0	0201	6.0	>= 9.0	>= 9.3	X	X		X	X			X	X		X	X	X	X		X	X			X		
	2.0.1	0301	6.2.0	>= 12	>= 12				X	X	X	X	X					X	X	X		X					
VEGAPULS 60 series, nicht 64,69	4.4.4	0501	5.2	>= 9.0	>= 8.4	X	X	X	X				X	X	X	X	X	X		X	X	X	X			X	
	4.5.0	0601	5.2	>= 9.0	>= 8.4	X	X	X	X				X	X	X	X	X	X		X	X	X	X			X	
VEGAPULS WL61, SR68	4.4.4	0501	5.2	>= 9.0	>= 8.4	X	X	X	X				X	X	X	X	X			X	X	X	X			X	
	4.5.0	0601	5.2	>= 9.0	>= 8.4	X	X	X	X				X	X	X	X	X	X		X	X	X	X			X	
VEGAPULS 69	1.0.0	0101	6.1	>= 10.5	>= 10.3			X	X	X	X					X	X	X	X		X	X			X		
		0102	6.1.2										X							X	X	X			X		
	1.1.0	0201	6.1.2	>= 10.5	>= 10.3			X	X	X	X					X	X	X	X		X	X			X		
VEGAFLEX 80 series	1.1.0	0101	6.1	>= 9.0	>= 9.3	X	X		X	X			X	X		X	X	X		X	X	X			X		
	1.2.0	0201	6.1.2	>= 10.5	>= 10.3			X	X	X			X	X		X	X	X	X		X	X			X		
	1.3.0	0301	6.2.0																	X	X	X			X		
		0302	6.3.0	>= 10.5	>= 10.3			X	X	X	X			X	X		X	X	X	X		X	X			X	
VEGABAR 80 series	1.0.0	0101	6.1											X						X	X	X			X		
	1.1.0	0201	6.1.2																		X	X				X	
	1.1.0	0202	6.1.2	>= 10.5	>= 10.3			X	X	X			X	X		X	X	X	X		X	X			X		
	1.2.0	0301	6.2.0																		X	X				X	
VEGADIF 85	1.2.0	0301	6.2.0																								
		0302	6.3.0	>= 10.5	>= 10.3			X	X	X	X			X	X		X	X	X	X					X		

(*1) EDD file format: 0102 --> 01: Device-Revision 1, 02: DD-Revision 2

Wie läuft eine Gerätebestellung ?

Ablauf HIST bei Emerson