



# IECEx Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: **IECEx TUN 16.0021X** Page 1 of 4 [Certificate history:](#)  
Status: **Current** Issue No: 1 Issue 0 (2016-06-23)  
Date of Issue: 2022-08-19  
Applicant: **VEGA Grieshaber KG**  
Am Hohenstein 113  
77761 Schiltach  
Germany  
Equipment: **Signal conditioning instruments VEGATOR 131 type TOR131.\*\*S/X\*\*\*\* and VEGATOR 132 type TOR132.\*\*\*\*\***  
Optional accessory:  
Type of Protection: **Intrinsic safety "i", increased safety "e", type of protection "n"**  
Marking: **Ex ec nC [ia Ga] IIC T4 Gc**  
**Ex ec nC [ia IIIC Da] IIC T4 Gc**  
**Ex ec nC [ia I Ma] IIC T4 Gc**  
**[Ex ia Ma] I**  
**[Ex ia Ga] IIC**  
**[Ex ia Da] IIIC**

Approved for issue on behalf of the IECEx  
Certification Body:

**Andreas Meyer**

Position:

**Deputy Head of the IECEx Certification Body**

Signature:  
(for printed version)

Date:  
(for printed version)



Digital unterschrieben  
von Meyer Andreas  
Datum: 2022.08.19  
16:54:29 +02'00'

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting [www.iecex.com](http://www.iecex.com) or use of this QR Code.



Certificate issued by:

**TÜV NORD CERT GmbH**  
Hanover Office  
TÜV NORD CERT, 1, 30519 Hannover  
Germany





# IECEx Certificate of Conformity

Certificate No.: **IECEX TUN 16.0021X**

Page 2 of 4

Date of issue: 2022-08-19

Issue No: 1

Manufacturer: **VEGA Grieshaber KG**  
Am Hohenstein 113  
77761 Schiltach  
Germany

Manufacturing locations: **VEGA Grieshaber KG**  
Am Hohenstein 113  
77761 Schiltach  
Germany

**VEGA Americas**  
4241 Allendorf Drive  
Cincinnati, Ohio 45209  
United States of America

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

## STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

[IEC 60079-0:2017](#) Explosive atmospheres - Part 0: Equipment - General requirements  
Edition:7.0

[IEC 60079-11:2011](#) Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"  
Edition:6.0

[IEC 60079-15:2017](#) Explosive atmospheres - Part 15: Equipment protection by type of protection "n"  
Edition:5.0

[IEC 60079-7:2017](#) Explosive atmospheres - Part 7: Equipment protection by increased safety "e"  
Edition:5.1

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

## TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

[DE/TUN/ExTR16.0028/01](#)

Quality Assessment Report:

[DE/TUN/QAR06.0002/11](#)



# IECEx Certificate of Conformity

Certificate No.: **IECEx TUN 16.0021X**

Page 3 of 4

Date of issue: 2022-08-19

Issue No: 1

## **EQUIPMENT:**

Equipment and systems covered by this Certificate are as follows:

The signal conditioning instruments VEGATOR 131 type TOR131.\*\*S/X\*\*\*\* and VEGATOR 132 type TOR132.\*\*\*\*\* are used for the supply of passive, intrinsically safe conductive sensors of type EL e.g for level point detection and pump control and for the safe galvanic separation of the intrinsically safe circuits from all non-intrinsically safe circuits.

Refers to Attachment to IECEx TUN 16.0021X issue No.1 for electrical and thermal data.

## **SPECIFIC CONDITIONS OF USE: YES as shown below:**

1. For EPL Gc applications the signal conditioning instruments VEGATOR 131 type TOR131.\*\*S/X\*\*\*\* and VEGATOR 132 type TOR132.\*\*\*\*\* have to be installed in a suitable enclosure according to IEC 60079-7 resp. IEC 60079-15 in such a way that a degree of protection of at least IP54 is achieved.
2. For EPL Gc applications the signal conditioning instruments VEGATOR 131 type TOR131.\*\*S/X\*\*\*\* and VEGATOR 132 type TOR132.\*\*\*\*\* have to be erected in such a way that a pollution degree 2 or less, according to IEC 60664-1, is achieved.
3. For EPL Gc applications measures have to be taken, external to the signal conditioning instruments VEGATOR 131 type TOR131 .\*\*S/X\*\*\*\* and VEGATOR 132 type TOR132.\*\*\*\*\* , to provide a transient protection that ensures that the rated voltage, connected to the power supply terminals, is not exceeded by more than 40 %.
4. The connecting and disconnecting of non-intrinsically safe circuits is only permitted in the absence of a potentially explosive atmosphere.



# IECEx Certificate of Conformity

Certificate No.: **IECEx TUN 16.0021X**

Page 4 of 4

Date of issue: 2022-08-19

Issue No: 1

## **DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)**

Proof of conformity of the signal conditioning instruments VEGATOR 131 type TOR131.\*\*S/X\*\*\*\* VEGATOR 132 type TOR132.\*\*\*\*\* to the current versions of the standards IEC 60079-0:2017/COR1:2020, IEC 60079-7:2017, IEC 60079-11:2011/COR1:2012 and IEC 60079-15:2017

The marking of the devices is extended to cover:

Ex ec nC [ja Ga] IIC T4 Gc

Ex ec nC [ja IIIC Da] IIC T4 Gc

Ex ec nC [ja I Ma] IIC T4 Gc

Actuating the buttons behind the cover plate cannot increase the maximum intrinsically safe output current and the internal effective reactances, therefore the ignition protection type intrinsic safety is not affected. The "ic" circuit can therefore be omitted from the marking.

## **Annex:**

[Attachment to IECEx TUN 16.0021X issue No.1.pdf](#)

**Page 1 of 2**  
**Attachment to IECEx TUN 16.0021X issue No.: 1**

**General product information:**

**Description:**

The signal conditioning instruments VEGATOR 131 type TOR131.\*\*S/X\*\*\*\* and VEGATOR 132 type TOR132.\*\*\*\*\* are used for the supply of passive, intrinsically safe conductive sensors of type EL e.g for level point detection and pump control and for the safe galvanic separation of the intrinsically safe circuits from all non-intrinsically safe circuits.

**Type code and Marking:**

VEGATOR 131 type TOR131.**S/X****	Ex ec nC [ia Ga] IIC T4 Gc
VEGATOR 132 type TOR132.*****	Ex ec nC [ia IIIC Da] IIC T4 Gc
	Ex ec nC [ia I Ma] IIC T4 Gc
	[Ex ia Ma] I
	[Ex ia Ga] IIC
	[Ex ia Da] IIIC

**Electrical data:**

Supply (Terminals 16/17) For connection to non-intrinsically safe circuits with the following maximum values:

U = 24...230 V a.c (-15 ... +10%)  
 U = 24... 65 V d.c (-15 ... +10%)  
 U<sub>m</sub> = 253 V a.c

Relay outputs (Terminals) For connection to non-intrinsically safe circuits with the following maximum values:

Relay 1: 10/11/12 U<sub>n</sub> = 253 V a.c ; I<sub>n</sub> = 3 A  
 Relay 2: 13/14/15 U<sub>n</sub> = 50 V d.c; I<sub>n</sub> = 1 A

Signal circuits (Terminals 1/2/3, 4/5) In type of protection intrinsic safety Ex ia I/IIC/IIIB(IIIC) with following maximum values per circuit:

U<sub>o</sub> = 12.6 V  
 I<sub>o</sub> = 7.7 mA  
 P<sub>o</sub> = 24.3 mW  
 Characteristic line: linear  
 Negligibly small  
 Negligibly small

Effective internal capacitance C<sub>i</sub>  
 Effective internal inductance L<sub>i</sub>

The maximum permissible values for the external inductance L<sub>o</sub> and the external capacitance C<sub>o</sub> can be taken from the following tables:

<b>Ex ia I</b>	L <sub>o</sub> [mH]	100	20	10	0.5	0.2
	C <sub>o</sub> [µF]	9.1	12	13	27	29

<b>Ex ia IIC</b>	L <sub>o</sub> [mH]	100	50	10	0.5	0.05
	C <sub>o</sub> [µF]	0.38	0.42	0.52	0.91	1.15

**Page 2 of 2**  
**Attachment to IECEx TUN 16.0021X issue No.: 1**

<b>Ex ia IIB (IIIC)</b>	L <sub>o</sub> [mH]	100	50	10	2	0.2
	C <sub>o</sub> [μF]	2.5	2.7	3.5	4.7	7.4

The intrinsically safe signal circuit is safe galvanically separated from the non-intrinsically safe circuits up to a peak value of the voltage of 375 V.

**Thermal data:**

Permissible ambient temperature range:  $-20\text{ °C} \leq T_a \leq +60\text{ °C}$ .

**Details of change (applicable only when revising an existing ExTR package):**

Proof of conformity of the signal conditioning instruments VEGATOR 131 type TOR131.\*\*S/X\*\*\*\* VEGATOR 132 type TOR132.\*\*\*\*\* to the current versions of the standards IEC 60079-0:2017/COR1:2020, IEC 60079-7:2017, IEC 60079-11:2011/COR1:2012 and IEC 60079-15:2017

The marking of the devices is extended to cover:

Ex ec nC [ia Ga] IIC T4 Gc  
 Ex ec nC [ia IIIC Da] IIC T4 Gc  
 Ex ec nC [ia I Ma] IIC T4 Gc

Actuating the buttons behind the cover plate cannot increase the maximum intrinsically safe output current and the internal effective reactances, therefore the ignition protection type intrinsic safety is not affected. The "ic" circuit can therefore be omitted from the marking.

**Specific Conditions of Use:**

1. For EPL Gc applications the signal conditioning instruments VEGATOR 131 type TOR131.\*\*S/X\*\*\*\* and VEGATOR 132 type TOR132.\*\*\*\*\* have to be installed in a suitable enclosure according to IEC 60079-7 resp. IEC 60079-15 in such a way that a degree of protection of at least IP54 is achieved.
2. For EPL Gc applications the signal conditioning instruments VEGATOR 131 type TOR131.\*\*S/X\*\*\*\* and VEGATOR 132 type TOR132.\*\*\*\*\* have to be erected in such a way that a pollution degree 2 or less, according to IEC 60664-1, is achieved.
3. For EPL Gc applications measures have to be taken, external to the signal conditioning instruments VEGATOR 131 type TOR131.\*\*S/X\*\*\*\* and VEGATOR 132 type TOR132.\*\*\*\*\* , to provide a transient protection that ensures that the rated voltage, connected to the power supply terminals, is not exceeded by more than 40 %.
4. The connecting and disconnecting of non-intrinsically safe circuits is only permitted in the absence of a potentially explosive atmosphere.



# IECEx Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.:

IECEx TUN 16.0021X

Issue No.: 0

Certificate history:

Status:

Current

Date of Issue:

2016-06-23

Page 1 of 3

Applicant:

**VEGA Grieshaber KG**  
Am Hohenstein 113  
77761 Schiltach  
Germany

Equipment:

**Signal conditioning instrument typ VEGATOR 131/132. IC/O/U\*\*\*\*\* and VEGATOR 131/132. AA\*\*\*\*\***

Optional accessory:

Type of Protection:

**Intrinsic safety "i", increased safety "e", type of protection "n"**

Marking:

Ex ec nC ic IIC T4 Gc  
[Ex ia Ga] IIC  
[Ex ia Da] IIIC  
[Ex ia Ma] I

Approved for issue on behalf of the IECEx  
Certification Body:

Karl-Heinz Schwedt

Position:

Head of IECEx Certification Body

Signature:  
(for printed version)

Date:

2016-06-23

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

**TÜV NORD CERT GmbH**  
Hanover Office  
Am TÜV 1  
30519 Hannover  
Germany





# IECEx Certificate of Conformity

Certificate No.: IECEx TUN 16.0021X

Date of Issue: 2016-06-23

Issue No.: 0

Page 2 of 3

Manufacturer: **VEGA Grieshaber KG**  
Am Hohenstein 113  
77761 Schiltach  
Germany

Additional Manufacturing location  
(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

<b>IEC 60079-0 : 2011</b> Edition: 6.0	Explosive atmospheres - Part 0: General requirements
<b>IEC 60079-11 : 2011</b> Edition: 6.0	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
<b>IEC 60079-15 : 2010</b> Edition: 4	Explosive atmospheres - Part 15: Equipment protection by type of protection "n"
<b>IEC 60079-7 : 2015</b> Edition: 5.0	Explosive atmospheres – Part 7: Equipment protection by increased safety "e"

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

#### TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

Test Report:  
DE/TUN/ExTR16.0028/00

Quality Assessment Report:  
DE/TUN/QAR06.0002/06





# IECEx Certificate of Conformity

Certificate No.: IECEX TUN 16.0021X

Date of Issue: 2016-06-23

Issue No.: 0

Page 3 of 3

## Schedule

### EQUIPMENT:

*Equipment and systems covered by this certificate are as follows:*

#### Signal conditioning instrument

VEGATOR 131. IC/O/U\*\*\*\*\*

VEGATOR 132. IC/O/U\*\*\*\*\*

and

VEGATOR 131. AA\*\*\*\*\*

VEGATOR 132. AA\*\*\*\*\*

### CONDITIONS OF CERTIFICATION: YES as shown below:

See Annexe





