

Translation

(1) **EU-Type Examination Certificate**

- (2) Equipment and protective systems intended for use in potentially explosive atmospheres, **Directive 2014/34/EU**




- (3) **Certificate Number** TÜV 16 ATEX 190806 X **issue:** 02
- (4) for the product: Differential pressure measuring device  
VEGADIF DF85(\*). \*C/U/O/H\*\*\*\*\*Z/H/A/P/F\*\*\*\*\*
- (5) of the manufacturer: **VEGA Grieshaber KG**
- (6) Address: Am Hohenstein 113  
77761 Schiltach  
Germany
- Order number: 8003026472  
Date of issue: 2021-03-19

- (7) The design of this product and any acceptable variation thereto are specified in the schedule to this EU-Type Examination Certificate and the documents therein referred to.
- (8) The TÜV NORD CERT GmbH, Notified Body No. 0044, in accordance with Article 17 of the Directive 2014/34/EU of the European Parliament and the Council of 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.  
The examination and test results are recorded in the confidential ATEX Assessment Report No. 20 203 284714.
- (9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

**EN IEC 60079-0:2018                      EN 60079-11:2012                      EN 60079:26:2015**

except in respect of those requirements listed at item 18 of the schedule.

- (10) If the sign "X" is placed after the certificate number, it indicates that the product is subject to the Specific Conditions for Use specified in the schedule to this certificate.
- (11) This EU-Type Examination Certificate relates only to the design, and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this equipment. These are not covered by this certificate.
- (12) The marking of the product shall include the following:

 **II 1 G Ex ia IIC T6...T1 Ga or**  
**II 1/2 G Ex ia IIC T6...T1 Ga/Gb or**  
**II 2 G Ex ia IIC T6...T1 Gb**

TÜV NORD CERT GmbH, Langemarckstraße 20, 45141 Essen, notified by the central office of the countries for safety engineering (ZLS), Ident. Nr. 0044, legal successor of the TÜV NORD CERT GmbH & Co. KG Ident. Nr. 0032

The deputy of the head of the notified body



Heinen

Hanover office, Am TÜV 1, 30519 Hannover, Tel. +49 511 998-61455, Fax +49 511 998-61590



### (13) SCHEDULE

(14) EU-Type Examination Certificate No. TÜV 16 ATEX 190806 X

Issue 02

### (15) Description of product:

The differential pressure measuring devices type VEGADIF DF85(\*). \*C/U/O/H\*\*\*\*\*Z/H/A/P/F\*\*\*\*\* are used for differential pressure measurement of liquids and gases.

The Differential pressure measuring devices type VEGADIF DF85(\*). \*C/U/O/H\*\*\*\*\*Z/H/A/P/F\*\*\*\*\* consist of an electronics housing, a differential pressure measuring element and the process connections.

Optionally, also an indication and operation module may be installed.

The following electronic versions are available:

VEGADIF DF85(\*). \*C/U/O/H\*\*\*\*\*Z\*\*\*\*\*: 2 wire 4 ... 20 mA transmitters

VEGADIF DF85(\*). \*C/U/O/H\*\*\*\*\*H\*\*\*\*\*: 2 wire 4 ... 20 mA transmitters with superposed HART signal

VEGADIF DF85(\*). \*C/U/O/H\*\*\*\*\*A\*\*\*\*\*: 2 wire 4 ... 20 mA transmitters with superposed HART signal and additional SIL qualification

VEGADIF DF85(\*). \*C/U/O/H\*\*\*\*\*P\*\*\*\*\*: With electronics for Profibus PA

VEGADIF DF85(\*). \*C/U/O/H\*\*\*\*\*F\*\*\*\*\*: With electronics for Foundation Fieldbus

#### Type code:

VEGADIF DF85(\*). \*C/U/O/H\*\*\*\*\*Z/H/A/P/F\*\*\*\*\*

#### Electrical data:

VEGADIF DF85 with built-in electronics Z,H,A

Supply and signal circuit  
(Terminals 1[+], 2[-] in the Ex-i electronics compartment, in the execution with 2 chamber housing in the terminal housing)

in type of protection „Intrinsic Safety“ Ex ia IIC  
Only for connection to a certified intrinsically safe circuit

Maximum values:

$U_i = 30 \text{ V}$

$I_i = 131 \text{ mA}$

$P_i = 983 \text{ mW}$

The effective internal capacitance is negligibly small.

Effective internal inductance:  $5 \mu\text{H}$

In execution with the 2 chamber housing:  $10 \mu\text{H}$

In the execution with connection cable mounted fixed, the following values have to be observed additionally:

$L_i^* = 0.62 \mu\text{H/m}$

$C_i^* \text{ wire/wire} = 150 \text{ pF/m}$

$C_i^* \text{ wire/shield} = 270 \text{ pF/m}$

VEGADIF DF85 with built-in electronics P, F

Supply and signal circuit  
(Terminals 1[+], 2[-] in the Ex-i electronics compartment, in the execution with 2 chamber housing in the terminal housing)

in type of protection „Intrinsic Safety“ Ex ia IIC  
Only for connection to a certified intrinsically safe circuit

Maximum values:

$U_i = 17.5\text{ V}$   
 $I_i = 500\text{ mA}$   
 $P_i = 5.5\text{ W}$

The apparatus is suitable for connection to a field bus system according to the FISCO model (IEC 60079-11)

or

$U_i = 24\text{ V}$   
 $I_i = 250\text{ mA}$   
 $P_i = 1.2\text{ W}$

The effective internal capacitance is negligibly small.

The effective internal inductance, 1 chamber housing, is negligibly small.

In execution with the 2 chamber housing:  $5\text{ }\mu\text{H}$

In the execution with connection cable mounted fixed, the following values have to be observed additionally:

$L_i^* = 0.62\text{ }\mu\text{H/m}$   
 $C_{i\text{ wire/wire}}^* = 150\text{ pF/m}$   
 $C_{i\text{ wire/shield}}^* = 270\text{ pF/m}$

VEGADIF DF85 for installation in a 2 chamber housing with the electronics H/A and the additional electronics PLISZEZSA (2<sup>nd</sup> current output)

Supply and signal circuit I  
(Terminals 1[+], 2[-] in terminal housing)

in type of protection „Intrinsic Safety“ Ex ia IIC  
Only for connection to a certified intrinsically safe circuit

Maximum values:

$U_i = 30\text{ V}$   
 $I_i = 131\text{ mA}$   
 $P_i = 983\text{ mW}$

The effective internal capacitance is negligibly small.

Effective internal inductance:  $5\text{ }\mu\text{H}$

In the execution with connection cable mounted fixed, the following values have to be observed additionally:

$L_i^* = 0.62\text{ }\mu\text{H/m}$   
 $C_{i\text{ wire/wire}}^* = 150\text{ pF/m}$   
 $C_{i\text{ wire/shield}}^* = 270\text{ pF/m}$

Schedule to EU-Type Examination Certificate No. TÜV 16 ATEX 190806 X

Issue 02

Supply and signal circuit II  
(Terminals 7[+], 8[-] in terminal housing)

in type of protection „Intrinsic Safety“ Ex ia IIC  
Only for connection to a certified intrinsically safe circuit

Maximum values:

$U_i = 30 \text{ V}$

$I_i = 131 \text{ mA}$

$P_i = 983 \text{ mW}$

The effective internal capacitance is negligibly small.

Effective internal inductance:  $5 \mu\text{H}$

In the execution with connection cable mounted fixed,  
the following values have to be observed additionally:

$L_i' = 0.62 \mu\text{H/m}$

$C_{i, \text{wire/wire}}' = 150 \text{ pF/m}$

$C_{i, \text{wire/shield}}' = 270 \text{ pF/m}$

Operation and indication circuit  
(Terminals 5, 6, 7, 8 in the housing for the electronics resp. in the terminal housing in the execution with 2 chamber housing)

in type of protection „Intrinsic Safety“ Ex ia IIC  
Only for connection to the intrinsically safe circuit of the  
belonging external VEGA indication unit type  
VEGADIS61 or VEGADIS81

The rules for the interconnection of intrinsically safe  
circuits between the VEGADIF DF85 and the  
VEGADIS 61/ VEGADIS 81 are adhered to, if the  
complete inductance and capacitance of the connection  
cable between VEGADIF DF85 and the VEGADIS 61/  
VEGADIS 81 does not exceed the following values:

Electronics Z, H, A:

$L_{\text{cable}} = 330 \mu\text{H}$

$C_{\text{cable}} = 1.98 \mu\text{F}$

Electronics P, F:

$L_{\text{cable}} = 212 \mu\text{H}$

$C_{\text{cable}} = 1.98 \mu\text{F}$

If the connection cable supplied by the manufacturer is  
used, the following values have to be observed:

$L_i' = 0.62 \mu\text{H/m}$

$C_{i, \text{wire/wire}}' = 150 \text{ pF/m}$

$C_{i, \text{wires/shield}}' = 270 \text{ pF/m}$

Operation and indication module circuit ....  
(Spring contacts in the housing for the electronics and additionally in the terminal housing in the execution with 2 chamber housing)

in type of protection „Intrinsic Safety“ Ex ia IIC  
Only for connection to the VEGA operation and  
indication module PLICSCOM or the interface adapter  
VEGACONNECT or an interface adapter with equal or  
less critical safety data

The intrinsically safe circuits for external connections are safe galvanically separated from the parts which can be earthed.

The intrinsically safe circuits to the measuring sensor are galvanically connected with earth potential.

**Thermal data:**

If the differential pressure measuring devices are used in explosion hazardous areas for EPL Ga, Ga/Gb or Gb applications, the permissible temperature range in the area of the electronics/at the measuring sensor dependent on the temperature class has to be taken from the following table:

Temperature class	Medium temperature range	Ambient temperature range
T6	-40 °C ... +46 °C	-40°C ... +46 °C
T5	-40 °C ... +55 °C *	
T4	-40 °C ... +85 °C	-40 °C ... +80 °C
T3		
T2		
T1		

\* For the remote sensor variant; for medium temperatures above 46 °C, a sufficient thermal decoupling between medium and converter-unit has to be ensured.

(16) Drawings and documents are listed in the ATEX Assessment Report No. 20 203 284714

**(17) Specific Conditions for Use:**

- The permissible ambient resp. medium temperature range depends on the variant of the apparatus and on the temperature class, for which the apparatus shall be used (see thermal data). The limits of the permissible ambient temperature range may be restricted by the used O-ring material. The used O-ring material is included in the marking. The permissible temperature ranges in dependence of the material have to be taken from the manufacturer's instructions.
- For use as Ga/Gb-apparatus:  
For functional reasons, the partition wall (membrane) to the wetted area has a wall thickness < 1 mm. In the application, it has to be ensured, that an impairment of the separation wall e.g. by aggressive media or mechanical hazards is excluded.  
For variants with standard process connections:  
The installation of the meter bodies shall provide as a minimum degree of protection IP67 according to EN 60529 for the process connections and vents.  
For variants with capillary connections:  
The capillary connections are designed to be connected to a capillary with diaphragm seal. The filling holes are intended to bring in a fill fluid.  
To prevent a zone entrainment from Zone 0, the diaphragm seal resp. the diaphragm seal and capillary have to be suitably designed. The pressure transfer system has to be technically tight. The filling hole has to be tightly sealed.
- At the plastic parts there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.
- At the metallic parts made of light metal there is a danger of ignition by impact or friction. Observe manual of the manufacturer.
- For the execution with separate housing, potential equalization has to exist in the complete course of the erection of the connecting cable between the electronics housing and the measuring sensor housing.

Schedule to EU-Type Examination Certificate No. TÜV 16 ATEX 190806 X

issue 02

- (18) **Essential Health and Safety Requirements:**  
No additional ones

- End of Certificate -



Translation

(1) **EU-Type Examination Certificate**

**TUV NORD**

(2) Equipment and protective systems intended for use in potentially explosive atmospheres, **Directive 2014/34/EU**



(3) **Certificate Number** TÜV 16 ATEX 190806 X **Issue:** 01

(4) for the product: Differential pressure measuring device VEGADIF DF85(\*).\*C/U/O/H\*\*\*\*\*Z/H/A/P/F\*\*\*\*\*

(5) of the manufacturer: VEGA Grieshaber KG

(6) Address: Am Hohenstein 113, 77761 Schiltach, Germany

Order number: 8000483015

Date of issue: 2018-09-07

(7) The design of this product and any acceptable variation thereto are specified in the schedule to this EU-Type Examination Certificate and the documents therein referred to.

(8) The TÜV NORD CERT GmbH, Notified Body No. 0044, in accordance with Article 17 of the Directive 2014/34/EU of the European Parliament and the Council of 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.  
The examination and test results are recorded in the confidential ATEX Assessment Report No. 18 203 219335.

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:  
EN 60079-0:2012+A11:2013    EN 60079-11:2012    EN 60079-26:2015

except in respect of those requirements listed at item 18 of the schedule.

(10) If the sign "X" is placed after the certificate number, it indicates that the product is subject to the Specific Conditions for Use specified in the schedule to this certificate.

(11) This EU-Type Examination Certificate relates only to the design, and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this equipment. These are not covered by this certificate.

(12) The marking of the product shall include the following:

II 1 G resp. II 1/2 G resp. II 2 G Ex ia IIC T6 ... T1 Ga resp. Ga/Gb resp. Gb

TÜV NORD CERT GmbH, Langemarckstraße 20, 45141 Essen, notified by the central office of the countries for safety engineering (ZLS), Ident. Nr. 0044, legal successor of the TÜV NORD CERT GmbH & Co. KG Ident. Nr. 0032

The head of the notified body

Roder

Hanover office, Am TÜV 1, 30519 Hannover, Tel. +49 511 998-61455, Fax +49 511 998-61590



This certificate may only be reproduced without any change, schedule included.  
Excerpts or changes shall be allowed by the TÜV NORD CERT GmbH

(13) **SCHEDULE**

(14) **EU-Type Examination Certificate No. TÜV 16 ATEX 190806 X issue 01**

(15) Description of product

The differential pressure measuring devices type VEGADIF DF85(\*).\*C/U/O/H\*\*\*\*\*Z/H/A/P/F\*\*\*\*\* are used for differential pressure measurement of liquids and gases.

The Differential pressure measuring devices type VEGADIF DF85(\*).\*C/U/O/H\*\*\*\*\*Z/H/A/P/F\*\*\*\*\* consist of an electronics housing, a differential pressure measuring element and the process connections. Optionally, also an indication and operation module may be installed.

The following electronic versions are available:

VEGADIF DF85(\*).\*C/U/O/H\*\*\*\*\*Z\*\*\*\*\*: 2 wire 4 ... 20 mA transmitters

VEGADIF DF85(\*).\*C/U/O/H\*\*\*\*\*H\*\*\*\*\*: 2 wire 4 ... 20 mA transmitters with superposed HART signal

VEGADIF DF85(\*).\*C/U/O/H\*\*\*\*\*A\*\*\*\*\*: 2 wire 4 ... 20 mA transmitters with superposed HART signal and additional SIL qualification

VEGADIF DF85(\*).\*C/U/O/H\*\*\*\*\*P\*\*\*\*\*: With electronics for Profibus PA

VEGADIF DF85(\*).\*C/U/O/H\*\*\*\*\*F\*\*\*\*\*: With electronics for Foundation Fieldbus

Electrical data

VEGADIF DF85 with built-in electronics Z,H,A

Supply and signal circuit .....  
(Terminals 1[+], 2[-] in the Ex-i electronics compartment, in the execution with 2 chamber housing in the terminal housing)

in type of protection „Intrinsic Safety“ Ex ia IIC  
Only for connection to a certified intrinsically safe circuit

Maximum values:

$$U_i = 30 \text{ V}$$

$$I_i = 131 \text{ mA}$$

$$P_i = 983 \text{ mW}$$

The effective internal capacitance is negligibly small.

$$\text{Effective internal inductance: } 5 \mu\text{H}$$

$$\text{In execution with the 2 chamber housing: } 10 \mu\text{H}$$

In the execution with connection cable mounted fixed, the following values have to be observed additionally:

$$L_i' = 0.62 \mu\text{H/m}$$

$$C_i' \text{ wire/wire} = 150 \text{ pF/m}$$

$$C_i' \text{ wire/shield} = 270 \text{ pF/m}$$

VEGADIF DF85 with built-in electronics P, F

Supply and signal circuit .....  
(Terminals 1[+], 2[-] in the Ex-i electronics compartment, in the execution with 2 chamber housing in the terminal housing)

in type of protection „Intrinsic Safety“ Ex ia IIC  
Only for connection to a certified intrinsically safe circuit

Maximum values:

$$U_i = 17.5 \text{ V}$$

$$I_i = 500 \text{ mA}$$

$$P_i = 5.5 \text{ W}$$



Schedule to EU-Type Examination Certificate No. TÜV 16 ATEX 190806 X issue 01

The apparatus is suitable for connection to a field bus system according to the FISCO model (IEC 60079-11)

or

$$\begin{aligned}U_i &= 24 \text{ V} \\I_i &= 250 \text{ mA} \\P_i &= 1.2 \text{ W}\end{aligned}$$

The effective internal capacitance is negligibly small.

The effective internal inductance, 1 chamber housing, is negligibly small.

In execution with the 2 chamber housing: 5  $\mu$ H

In the execution with connection cable mounted fixed, the following values have to be observed additionally:

$$\begin{aligned}L_i^* &= 0.62 \text{ } \mu\text{H/m} \\C_i^* \text{ wire/wire} &= 150 \text{ pF/m} \\C_i^* \text{ wire/shield} &= 270 \text{ pF/m}\end{aligned}$$

VEGADIF DF85 for installation in a 2 chamber housing with the electronics H/A and the additional electronics PLISZEZSA (2<sup>nd</sup> current output)

Supply and signal circuit I.....  
(Terminals 1[+], 2[-] in terminal housing)

in type of protection „Intrinsic Safety“ Ex ia IIC  
Only for connection to a certified intrinsically safe circuit

Maximum values:

$$\begin{aligned}U_i &= 30 \text{ V} \\I_i &= 131 \text{ mA} \\P_i &= 983 \text{ mW}\end{aligned}$$

The effective internal capacitance is negligibly small.

Effective internal inductance: 5  $\mu$ H

In the execution with connection cable mounted fixed, the following values have to be observed additionally:

$$\begin{aligned}L_i^* &= 0.62 \text{ } \mu\text{H/m} \\C_i^* \text{ wire/wire} &= 150 \text{ pF/m} \\C_i^* \text{ wire/shield} &= 270 \text{ pF/m}\end{aligned}$$

Schedule to EU-Type Examination Certificate No. TÜV 16 ATEX 190806 X issue 01

Supply and signal circuit II.....  
(Terminals 7[+], 8[-] in terminal housing)

in type of protection „Intrinsic Safety“ Ex ia IIC  
Only for connection to a certified intrinsically safe circuit

Maximum values:

$$U_i = 30 \text{ V}$$

$$I_i = 131 \text{ mA}$$

$$P_i = 983 \text{ mW}$$

The effective internal capacitance is negligibly small.  
Effective internal inductance: 5  $\mu\text{H}$

In the execution with connection cable mounted fixed, the following values have to be observed additionally:

$$L_i^* = 0.62 \text{ } \mu\text{H/m}$$

$$C_i^{\text{wire/wire}} = 150 \text{ pF/m}$$

$$C_i^{\text{wire/shield}} = 270 \text{ pF/m}$$

Operation and indication circuit .....  
(Terminals 5, 6, 7, 8 in the housing for the electronics resp. in the terminal housing in the execution with 2 chamber housing)

in type of protection „Intrinsic Safety“ Ex ia IIC  
Only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61 or VEGADIS81

The rules for the interconnection of intrinsically safe circuits between the VEGADIF DF85 and the VEGADIS 61/ VEGADIS 81 are adhered to, if the complete inductance and capacitance of the connection cable between VEGADIF DF85 and the VEGADIS 61/ VEGADIS 81 does not exceed the following values:

Electronics Z, H, A:

$$L_{\text{cable}} = 330 \text{ } \mu\text{H}$$

$$C_{\text{cable}} = 1.98 \text{ } \mu\text{F}$$

Electronics P, F:

$$L_{\text{cable}} = 212 \text{ } \mu\text{H}$$

$$C_{\text{cable}} = 1.98 \text{ } \mu\text{F}$$

If the connection cable supplied by the manufacturer is used, the following values have to be observed:

$$L_i^* = 0.62 \text{ } \mu\text{H/m}$$

$$C_i^{\text{wire/wire}} = 150 \text{ pF/m}$$

$$C_i^{\text{wires/shield}} = 270 \text{ pF/m}$$

**Schedule to EU-Type Examination Certificate No. TÜV 16 ATEX 190806 X issue 01**

Operation and indication module circuit .... in type of protection „Intrinsic Safety“ Ex ia IIC  
 (Spring contacts in the housing for the Only for connection to the VEGA operation and  
 electronics and additionally in the terminal indication module PLICSCOM  
 housing in the execution with 2 chamber or the interface adapter VEGACONNECT  
 housing) or an interface adapter with equal or less critical safety  
 data

The intrinsically safe circuits for external connections are safe galvanically separated from the parts which can be earthed.  
 The intrinsically safe circuits to the measuring sensor are galvanically connected with earth potential,

Thermal data:

If the differential pressure measuring devices are used in explosion hazardous areas for EPL Ga, Ga/Gb or Gb applications, the permissible temperature range in the area of the electronics/at the measuring sensor dependent on the temperature class has to be taken from the following table:

Temperature class	Medium temperature range	Ambient temperature range
T6	-40 °C ... +46 °C	-40°C ... +46 °C
T5	-40 °C ... +55 °C *	
T4	-40 °C ... +85 °C	-40 °C ... +80 °C
T3		
T2		
T1		

\* For the remote sensor variant; for medium temperatures above 46 °C, a sufficient thermal decoupling between medium and converter-unit has to be ensured.

The measuring sensors and the electronics are allowed to be operated in an explosion hazardous area, only if atmospheric conditions exist

(temperature: -20 °C to +60 °C, pressure: 0.8 bar to 1.1 bar, air with normal oxygen content: typically 21 % v/v).

If no explosion hazardous atmospheres exist, the permissible operating temperatures and pressures have to be taken from the manufacturer's data (manual).

(16) Drawings and documents are listed in the ATEX Assessment Report No. 18 203 219335

(17) Specific Conditions for Use

1. The permissible ambient resp. medium temperature range depends on the variant of the apparatus and on the temperature class, for which the apparatus shall be used (see thermal data).  
 The limits of the permissible ambient temperature range may be restricted by the used O-ring material. The used O-ring material is included in the marking. The permissible temperature ranges in dependence of the material have to be taken from the manufacturer's instructions.

## Schedule to EU-Type Examination Certificate No. TÜV 16 ATEX 190806 X issue 01

### 2. For use as Ga/Gb-apparatus:

For functional reasons, the partition wall (membrane) to the wetted area has a wall thickness <1 mm. In the application, it has to be ensured, that an impairment of the separation wall e.g. by aggressive media or mechanical hazards is excluded.

For variants with standard process connections:

The installation of the meter bodies shall provide as a minimum degree of protection IP67 according to EN 60529 for the process connections and vents.

For variants with capillary connections:

The capillary connections are designed to be connected to a capillary with diaphragm seal.

The filling holes are intended to bring in a fill fluid.

To prevent a zone entrainment from Zone 0, the diaphragm seal resp. the diaphragm seal and capillary have to be suitably designed. The pressure transfer system has to be technically tight. The filling hole has to be tightly sealed.

### 3. At the plastic parts there is a danger of ignition by electrostatic discharge.

Observe manual of the manufacturer and warning label.

### 4. At the metallic parts made of light metal there is a danger of ignition by impact or friction. Observe manual of the manufacturer.

### 5. For the execution with separate housing, potential equalization has to exist in the complete course of the erection of the connecting cable between the electronics housing and the measuring sensor housing.

## (18) Essential Health and Safety Requirements

no additional ones

- End of Certificate -

Translation

(1) **EU-Type Examination Certificate**

- (2) Equipment and protective systems intended for use in potentially explosive atmospheres, **Directive 2014/34/EU**



(3) **Certificate Number** TÜV 16 ATEX 190806 X **issue:** 00

(4) for the product: Differential pressure measuring device  
VEGADIF DF85(\*). \*C/U/O/H\*\*\*\*\*Z/H/A/P/F\*\*\*\*\*

(5) of the manufacturer: VEGA Grieshaber KG

(6) Address: Am Hohenstein 113, 77761 Schiltach

Order number: 8000466380

Date of issue: 2016-12-06

(7) The design of this product and any acceptable variation thereto are specified in the schedule to this EU-Type Examination Certificate and the documents therein referred to.

(8) The TÜV NORD CERT GmbH, Notified Body No. 0044, in accordance with Article 17 of the Directive 2014/34/EU of the European Parliament and the Council of 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.  
The examination and test results are recorded in the confidential ATEX Assessment Report No. 16 203 190806.

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 60079-0:2012+A11:2013

EN 60079-11:2012

EN 60079-26:2015

except in respect of those requirements listed at item 18 of the schedule.

(10) If the sign "X" is placed after the certificate number, it indicates that the product is subject to the Specific Conditions for Use specified in the schedule to this certificate.

(11) This EU-Type Examination Certificate relates only to the design, and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this equipment. These are not covered by this certificate.

(12) The marking of the product shall include the following:

 II 1 G resp. II 1/2 G resp. II 2 G Ex ia IIC T6 ... T1 Ga resp. Ga/Gb resp. Gb

TÜV NORD CERT GmbH, Langemarkstraße 20, 45141 Essen, notified by the central office of the countries for safety engineering (ZLS), Ident. Nr. 0044, legal successor of the TÜV NORD CERT GmbH & Co. KG Ident. Nr. 0032

The head of the notified body



Meyer

Hanover office, Am TÜV 1, 30519 Hannover, Tel. +49 511 998-61455, Fax +49 511 998-61590

This certificate may only be reproduced without any change, schedule included.  
Excerpts or changes shall be allowed by the TÜV NORD CERT GmbH

## (13) SCHEDULE

(14) EU-Type Examination Certificate No. TÜV 16 ATEX 190806 X issue 00

(15) Description of product

The differential pressure measuring devices type VEGADIF DF85(\*).C/U/O/H\*\*\*\*\*Z/H/A/P/F\*\*\*\*\* are used for differential pressure measurement of liquids and gases.

The Differential pressure measuring devices type VEGADIF DF85(\*).C/U/O/H\*\*\*\*\*Z/H/A/P/F\*\*\*\*\* consist of an electronics housing, a differential pressure measuring element and the process connections. Optionally, also an indication and operation module may be installed.

The following electronic versions are available:

VEGADIF DF85(\*).C/U/O/H\*\*\*\*\*Z\*\*\*\*\*: 2 wire 4 ... 20 mA transmitters

VEGADIF DF85(\*).C/U/O/H\*\*\*\*\*H\*\*\*\*\*: 2 wire 4 ... 20 mA transmitters with superposed HART signal

VEGADIF DF85(\*).C/U/O/H\*\*\*\*\*A\*\*\*\*\*: 2 wire 4 ... 20 mA transmitters with superposed HART signal and additional SIL qualification

VEGADIF DF85(\*).C/U/O/H\*\*\*\*\*P\*\*\*\*\*: With electronics for Profibus PA

VEGADIF DF85(\*).C/U/O/H\*\*\*\*\*F\*\*\*\*\*: With electronics for Foundation Fieldbus

### Electrical data

#### VEGADIF DF85 with built-in electronics Z,H,A

Supply and signal circuit .....  
(Terminals 1[+], 2[-] in the Ex-i electronics compartment, in the execution with 2 chamber housing in the terminal housing)

in type of protection „Intrinsic Safety“ Ex ia IIC  
Only for connection to a certified intrinsically safe circuit

Maximum values:

$$U_i = 30 \text{ V}$$

$$I_i = 131 \text{ mA}$$

$$P_i = 983 \text{ mW}$$

The effective internal capacitance is negligibly small.

Effective internal inductance: 5  $\mu\text{H}$

In execution with the 2 chamber housing: 10  $\mu\text{H}$

In the execution with connection cable mounted fixed, the following values have to be observed additionally:

$$L_i^* = 0.62 \text{ } \mu\text{H/m}$$

$$C_i^* \text{ wire/wire} = 150 \text{ pF/m}$$

$$C_i^* \text{ wire/shield} = 270 \text{ pF/m}$$

#### VEGADIF DF85 with built-in electronics P, F

Supply and signal circuit .....  
(Terminals 1[+], 2[-] in the Ex-i electronics compartment, in the execution with 2 chamber housing in the terminal housing)

in type of protection „Intrinsic Safety“ Ex ia IIC  
Only for connection to a certified intrinsically safe circuit

Maximum values:

$$U_i = 17.5 \text{ V}$$

$$I_i = 500 \text{ mA}$$

$$P_i = 5.5 \text{ W}$$

Schedule to EU-Type Examination Certificate No. TÜV 16 ATEX 190806 X issue 00

The apparatus is suitable for connection to a field bus system according to the FISCO model (IEC 60079-11)

or

$$\begin{aligned} U_i &= 24 \text{ V} \\ I_i &= 250 \text{ mA} \\ P_i &= 1.2 \text{ W} \end{aligned}$$

The effective internal capacitance is negligibly small.

The effective internal inductance, 1 chamber housing, is negligibly small.

In execution with the 2 chamber housing:  $5 \mu\text{H}$

In the execution with connection cable mounted fixed, the following values have to be observed additionally:

$$\begin{aligned} L_i^* &= 0.62 \mu\text{H/m} \\ C_i^* \text{ wire/wire} &= 150 \text{ pF/m} \\ C_i^* \text{ wire/shield} &= 270 \text{ pF/m} \end{aligned}$$

VEGADIF DF85 for installation in a 2 chamber housing with the electronics H/A and the additional electronics PLISZEZSA (2<sup>nd</sup> current output)

Supply and signal circuit I.....  
(Terminals 1[+], 2[-] in terminal housing)

in type of protection „Intrinsic Safety“ Ex ia IIC  
Only for connection to a certified intrinsically safe circuit

Maximum values:

$$\begin{aligned} U_i &= 30 \text{ V} \\ I_i &= 131 \text{ mA} \\ P_i &= 983 \text{ mW} \end{aligned}$$

The effective internal capacitance is negligibly small.

Effective internal inductance:  $5 \mu\text{H}$

In the execution with connection cable mounted fixed, the following values have to be observed additionally:

$$\begin{aligned} L_i^* &= 0.62 \mu\text{H/m} \\ C_i^* \text{ wire/wire} &= 150 \text{ pF/m} \\ C_i^* \text{ wire/shield} &= 270 \text{ pF/m} \end{aligned}$$

**Schedule to EU-Type Examination Certificate No. TÜV 16 ATEX 190806 X issue 00**

Supply and signal circuit II.....  
(Terminals 7[+], 8[-] in terminal housing)

in type of protection „Intrinsic Safety“ Ex ia IIC  
Only for connection to a certified intrinsically safe circuit

Maximum values:

$$U_i = 30 \text{ V}$$

$$I_i = 131 \text{ mA}$$

$$P_i = 983 \text{ mW}$$

The effective internal capacitance is negligibly small.

Effective internal inductance:  $5 \mu\text{H}$

In the execution with connection cable mounted fixed, the following values have to be observed additionally:

$$L_i' = 0.62 \mu\text{H/m}$$

$$C_{i \text{ wire/wire}} = 150 \text{ pF/m}$$

$$C_{i \text{ wire/shield}} = 270 \text{ pF/m}$$

Operation and indication circuit .....  
(Terminals 5, 6, 7, 8 in the housing for the electronics resp. in the terminal housing in the execution with 2 chamber housing)

in type of protection „Intrinsic Safety“ Ex ia IIC  
Only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61 or VEGADIS81

The rules for the interconnection of intrinsically safe circuits between the VEGADIF DF85 and the VEGADIS 61/ VEGADIS 81 are adhered to, if the complete inductance and capacitance of the connection cable between VEGADIF DF85 and the VEGADIS 61/ VEGADIS 81 does not exceed the following values:

Electronics Z, H, A:

$$L_{\text{cable}} = 330 \mu\text{H}$$

$$C_{\text{cable}} = 1.98 \mu\text{F}$$

Electronics P, F:

$$L_{\text{cable}} = 212 \mu\text{H}$$

$$C_{\text{cable}} = 1.98 \mu\text{F}$$

If the connection cable supplied by the manufacturer is used, the following values have to be observed:

$$L_i' = 0.62 \mu\text{H/m}$$

$$C_{i \text{ wire/wire}} = 150 \text{ pF/m}$$

$$C_{i \text{ wires/shield}} = 270 \text{ pF/m}$$



**Schedule to EU-Type Examination Certificate No. TÜV 16 ATEX 190806 X issue 00**

Operation and indication module circuit ....  
(Spring contacts in the housing for the electronics and additionally in the terminal housing in the execution with 2 chamber housing)

in type of protection „Intrinsic Safety“ Ex ia IIC  
Only for connection to the VEGA operation and indication module PLICSCOM  
or the interface adapter VEGACONNECT  
or an interface adapter with equal or less critical safety data

The intrinsically safe circuits for external connections are safe galvanically separated from the parts which can be earthed.  
The intrinsically safe circuits to the measuring sensor are galvanically connected with earth potential,

Thermal data:

If the differential pressure measuring devices are used in explosion hazardous areas for EPL Ga, Ga/Gb or Gb applications, the permissible temperature range in the area of the electronics/at the measuring sensor dependent on the temperature class has to be taken from the following table:

Temperature class	Medium temperature range	Ambient temperature range
T6	-40 °C ... +46 °C	-40°C ... +46 °C
T5	-40 °C ... +55 °C *	
T4	-40 °C ... +85 °C	-40 °C ... +80 °C
T3		
T2		
T1		

\* For the remote sensor variant; for medium temperatures above 46 °C, a sufficient thermal decoupling between medium and converter-unit has to be ensured.

The measuring sensors and the electronics are allowed to be operated in an explosion hazardous area, only if atmospheric conditions exist  
(temperature: -20 °C to +60 °C, pressure: 0.8 bar to 1.1 bar, air with normal oxygen content: typically 21 % v/v).

If no explosion hazardous atmospheres exist, the permissible operating temperatures and pressures have to be taken from the manufacturer's data (manual).

(16) Drawings and documents are listed in the ATEX Assessment Report No. 16 203 190806

(17) Specific Conditions for Use

1. The permissible ambient resp. medium temperature range depends on the variant of the apparatus and on the temperature class, for which the apparatus shall be used (see thermal data).  
The limits of the permissible ambient temperature range may be restricted by the used O-ring material. The used O-ring material is included in the marking. The permissible temperature ranges in dependence of the material have to be taken from the manufacturer's instructions.

**Schedule to EU-Type Examination Certificate No. TÜV 16 ATEX 190806 X issue 00**

2. For use as Ga/Gb-apparatus:

For functional reasons, the partition wall (membrane) to the wetted area has a wall thickness <1 mm. In the application, it has to be ensured, that an impairment of the separation wall e.g. by aggressive media or mechanical hazards is excluded.

For variants with standard process connections:

The installation of the meter bodies shall provide as a minimum degree of protection IP67 according to EN 60529 for the process connections and vents.

For variants with capillary connections:

The capillary connections are designed to be connected to a capillary with diaphragm seal.

The filling holes are intended to bring in a fill fluid.

To prevent a zone entrainment from Zone 0, the diaphragm seal resp. the diaphragm seal and capillary have to be suitably designed. The pressure transfer system has to be technically tight. The filling hole has to be tightly sealed.

3. At the plastic parts there is a danger of ignition by electrostatic discharge.  
Observe manual of the manufacturer and warning label.

4. At the metallic parts made of light metal there is a danger of ignition by impact or friction. Observe manual of the manufacturer.

5. For the execution with separate housing, potential equalization has to exist in the complete course of the erection of the connecting cable between the electronics housing and the measuring sensor housing.

(18) Essential Health and Safety Requirements

no additional ones

- End of Certificate -



