



# IECEX Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: **IECEX TUN 05.0018X** issue No.: **5**

Status: **Current**

Date of Issue: **2017-07-31** Page 1 of 6

Certificate history:  
Issue No. 5 (2017-7-31)  
Issue No. 4 (2008-10-17)  
Issue No. 3 (2008-10-17)  
Issue No. 2 (2007-11-22)  
Issue No. 1 (2006-12-13)

Applicant: **VEGA Grieshaber KG**  
Am Hohenstein 13  
77761 Schiltach  
Germany

Equipment: **Capacitive continuous level measurement sensors type VEGACAL CL6\*.DI \*\*\*H/P/F\*\*\*\***  
Optional accessory: **--**

Type of Protection: **Flameproof Enclosures and Intrinsic Safety**

Marking: **Ex ia/db ia IIC T6 ... T1 Ga/Gb**  
**Ex db ia IIC T6 ... T1 Gb**

Approved for issue on behalf of the IECEx Certification Body: **Andreas Meyer**

Position: **Head of IECEx CB**

Signature:  
(for printed version)

Date:

  
2017-07-31

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

**TÜV NORD CERT GmbH**  
Hanover Office  
Am TÜV 1, 30519 Hannover  
Germany





# IECEx Certificate of Conformity

Certificate No.: IECEx TUN 05.0018X

Date of Issue: 2017-07-31

Issue No.: 5

Page 2 of 6

Manufacturer: **VEGA Grieshaber KG**  
Am Hohenstein 13  
77761 Schiltach  
Germany

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

<b>IEC 60079-0 : 2011</b> Edition: 6.0	Explosive atmospheres - Part 0: General requirements
<b>IEC 60079-1 : 2014-06</b> Edition: 7.0	Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
<b>IEC 60079-11 : 2011</b> Edition: 6.0	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
<b>IEC 60079-26 : 2014-10</b> Edition: 3.0	Explosive atmospheres – Part 26: Equipment with Equipment Protection Level (EPL) Ga

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

#### TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

IECEx ATR:  
DE/TUN/ExTR08.0035/01  
IECEx QAR:  
DE/TUN/QAR06.0002/07

File Reference:  
17 217 204727  
  
16 216 178638



# IECEX Certificate of Conformity

Certificate No.: IECEX TUN 05.0018X

Date of Issue: 2017-07-31

Issue No.: 5

Page 3 of 6

## Schedule

### EQUIPMENT:

*Equipment and systems covered by this certificate are as follows:*

The capacitive continuous level measurement sensors type VEGACAL CL6\*.DI \*\*\*H/P/F\*\*\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

The capacitive continuous level measurement sensors type VEGACAL CL6\*.DI \*\*\*H/P/F\*\*\*\* consist of an electronic housing for the barriers with an Ex-d connection room, an Ex-i connection room with inserted measuring electronics, a process adapting element and a measuring sensor.

Mechanical basic execution of the electrodes:

Type	Electrodes
VEGACAL CL62	partly insulated rod electrode, optionally with screening tube or concentric tube
VEGACAL CL63	fully insulated rod electrode, optionally plated
VEGACAL CL64	fully insulated rod electrode for viscous and adhesive filling materials
VEGACAL CL65	partly insulated cable electrode optionally with abrasion protection
VEGACAL CL66	fully insulated cable electrode

For further details see attachment.

### SPECIFIC CONDITIONS OF USE: YES as shown below:

1. At the plastic parts of the capacitive continuous level measurement sensors there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.
2. For zone 0/1 applications and at risks by pendulum or vibration the respective parts of the capacitive continuous level measurement sensors have to be secured effectively against these dangers. Observe manual of the manufacturer.
3. For zone 0/1 applications, at the metallic electrode parts of the capacitive continuous level measurement sensors made of light metal there is a danger of ignition by impact or friction. Observe manual of the manufacturer.
4. For zone 0/1 applications the medium tangent materials have to be resistant to the media.
5. The flameproof terminal box (Ex-d connection room) of this equipment must be provided with cable entries and filler plugs resp. conduits which are certified according to IEC 60079-0 and IEC 60079-1.
6. The PA terminal of the capacitive continuous level measurement sensors with the barriers P2-2LH and KLEMP2-2LPAFFD (internal or external screw terminal) has to be connected with the potential equalization of the explosion hazardous area.



# IECEX Certificate of Conformity

Certificate No.: IECEx TUN 05.0018X

Date of Issue: 2017-07-31

Issue No.: 5

Page 4 of 6

**EQUIPMENT(continued):**

See attachment.



# IECEx Certificate of Conformity

Certificate No: IECEx TUN 05.0018X

Issue No: 5

Date of Issue: 2017-07-31

Page 5 of 6

**DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):**

- Standard update to IEC 60079-11 and IEC 60079-26
- Data from CoC TUN 05.0018 X (version "H") also valid for CoC TUN 05.0019 X (version "P/F")
- actual PLICSCOM module permissible to be installed; CoC TUN 16.0002 U
- new thermal data
- Ex-d-housing and installed barriers certified according to CoC TUN 05.0015U, issue 08



# IECEx Certificate of Conformity

Certificate No.: IECEx TUN 05.0018X

Date of Issue: 2017-07-31

Issue No.: 5

Page 6 of 6

**Additional information:**

See attachment.

Annex: Attachment\_VEGACAL\_H\_P\_F\_d ia\_TUN05.0018X.pdf

The capacitive continuous level measurement sensors type VEGACAL CL6\*.DI \*\*\*H/P/F\*\*\*\* are used for monitoring or control of filling levels in explosion hazardous areas. The measuring media are allowed to be combustible liquids, gases, mists or vapours. The capacitive continuous level measurement sensors type VEGACAL CL6\*.DI \*\*\*H/P/F\*\*\*\* consist of an electronic housing for the barriers with an Ex-d connection room, an Ex-i connection room with inserted measuring electronics, a process adapting element and a measuring sensor.

Mechanical basic execution of the electrodes:

Type	Electrodes
VEGACAL CL62	partly insulated rod electrode, optionally with screening tube or concentric tube
VEGACAL CL63	fully insulated rod electrode, optionally plated
VEGACAL CL64	fully insulated rod electrode for viscous and adhesive filling materials
VEGACAL CL65	partly insulated cable electrode optionally with abrasion protection
VEGACAL CL66	fully insulated cable electrode

Electrical data

**Type VEGACAL CL6\*.DI \*\*\*H\*\*\*\***

Supply and signal circuit .....  
 (Terminals 1[+], 2[-]  
 in the Ex-d connection room)

with barrier P3-2LH:  
 $U = 14 \dots 36 \text{ V d. c.}$   
 $U_m = 253 \text{ V a. c.}$

with barrier P2-2LH:  
 $U = 20 \dots 36 \text{ V d. c.}$   
 $U_m = 253 \text{ V a. c.}$

Operation and indication circuit .....  
 (Terminals 5, 6, 7, 8 or plug connection in  
 the "i" connection room)

in type of protection „Intrinsic Safety“ Ex ia IIC

only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61/81

The interconnection of the both intrinsically safe circuits was taken into account.

maximum values of the connection cable:

$C_o = 2.4 \text{ }\mu\text{F}$   
 $L_o = 160 \text{ }\mu\text{H}$

Operation  
 and indication module circuit .....  
 (Spring contacts in the housing for the  
 electronics)

in type of protection „Intrinsic Safety“ Ex ia IIC  
 only for connection to the VEGA operation and  
 indication module (PLICSCOM)

Communication circuit .....  
 (I<sup>2</sup>C bus in the "i" connection room))

in type of protection „Intrinsic Safety“ Ex ia IIC

only for connection to the intrinsically safe signal  
 circuit of the VEGA interface converter type  
 VEGACONNECT

If  
- the VEGA interface converter type VEGACONNECT and  
- the external VEGA indication unit type VEGADIS61/81  
are connected, the following maximum values of the connection cable to the VEGADIS61/81 do  
result:

$$C_o = 2.8 \mu\text{F}$$

$$L_o = 100 \mu\text{H}$$

A length of the triax cable resp. coax cable between the housing for the electronics and the  
terminal housing of 10 m is permissible.

All intrinsically safe circuits of the capacitive continuous level measurement sensors with built-in  
barrier P3-2LH are safe galvanically separated from the non intrinsically safe supply and signal  
circuit and the parts which can be earthed.

All intrinsically safe circuits of the capacitive measuring probes with built-in barrier P2-2LH are  
galvanically connected with the earth potential (measuring circuit excluded).

**Type VEGACAL CL6\*.DI \*\*\*P/F\*\*\*\***

Electrical data

Supply and signal circuit ..... with barrier P3-2LPAFF:  
(Terminals K11/1, K11/2; U = 14 ... 32 V d. c.  
"Ex d"-connection room) U<sub>m</sub> = 253 V a. c.

with barrier KLEMP2-2LPAFFD:  
U = 16 ... 32 V d. c.  
U<sub>m</sub> = 253 V a. c.

Operation and indication circuit .... in type of protection „Intrinsic Safety“ Ex ia IIC  
(Terminals 5, 6, 7, 8 in the "Ex i"- only for connection to the intrinsically safe circuit of the  
connection room) belonging external VEGA indication unit type VEGADIS61/81

The interconnection of the both intrinsically safe circuits was  
taken into account.  
maximum values of the connection cable:  
C<sub>o</sub> = 2.4 μF  
L<sub>o</sub> = 160 μH

Operation and indication module circuit ..... in type of protection „Intrinsic Safety“ Ex ia IIC  
(Spring contacts in the "Ex i"- only for connection to the VEGA operation and indication  
connection room) module (PLICSCOM)

Communication circuit ..... in type of protection „Intrinsic Safety“ Ex ia IIC  
(I<sup>2</sup>C bus in the "Ex i"-connection only for connection to the intrinsically safe signal circuit of the  
room)



VEGA interface converter type VEGACONNECT

If

- the VEGA interface converter type VEGACONNECT and  
 - the external VEGA indication unit type VEGADIS61/81  
 are connected, the following maximum values of the connection cable to the VEGADIS61/81 do result:

$$C_o = 2.8 \mu\text{F}$$

$$L_o = 100 \mu\text{H}$$

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

All intrinsically safe circuits of the capacitive continuous level measurement sensors with built-in barrier P3-2LPAFF and P3-2LH are safe galvanically separated from the non intrinsically safe supply and signal circuit and the parts which can be earthed.

All intrinsically safe circuits of the capacitive measuring probes with built-in barrier KLEMP2-2LPAFFD and P2-2LH are galvanically connected with the earth potential (measuring circuit excluded).

Thermal data

**Type VEGACAL CL6\*.DI \*\*\*H\*\*\*\***

If the capacitive continuous level measurement sensors are mounted in the partition wall between explosion hazardous areas which require apparatus of the category 1 (electrode) and category 2 (electronics), the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

Temperature class	Ambient temperature range	Medium temperature range at measuring sensor
T6	-40 °C ... +46 °C	-20 °C ...+60 °C
T5	-40 °C ...+60 °C	
T4		
T3		
T2		
T1		

The electrodes of the capacitive continuous level measurement sensors are allowed to be operated in an explosion hazardous area, that requires apparatus of the category 1, only if atmospheric conditions exist (pressure from 0.8 bar to 1.1 bar).

If no explosion hazardous atmospheres exist, the permissible operating temperatures and pressures have to be taken from the manufacturer's data (manual).

If the sensors of the capacitive continuous level measurement sensors are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of

ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.

If the capacitive continuous level measurement sensors are mounted in explosion hazardous areas which require apparatus of the category 2 the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

Temperature class	Ambient temperature range	Medium temperature range at measuring sensor		
		PE insulation	PTFE insulation	PTFE insulation with temperature adapter
T6	-40 °C ... +46 °C	-40 °C ... +80 °C	-50 °C ... +85 °C	-50 °C ... +85 °C
T5			-50 °C ... +100 °C	-50 °C ... +100 °C
T4			-50 °C ... +135 °C	-50 °C ... +135 °C
T3			-50 °C ... +150 °C	-50 °C ... +200 °C
T2				
T1				

If the sensors of the capacitive continuous level measurement sensors are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.

#### Type VEGACAL CL6\*.DI \*\*\*P/F\*\*\*\*

If the capacitive continuous level measurement sensors are mounted in the partition wall between explosion hazardous areas which require apparatus of the category 1 (electrode) and category 2 (electronics), the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

Temperature class	Ambient temperature range	Medium temperature range at measuring sensor
T6	-40 °C ... +38 °C	-20 °C ... +60 °C
T5	-40 °C ... +53 °C	
T4	-40 °C ... +60 °C	
T3		
T2		
T1		

The electrodes of capacitive continuous level measurement sensors are allowed to be operated in an explosion hazardous area, that requires apparatus of the category 1, only if atmospheric conditions exist (pressure from 0.8 bar to 1.1 bar).

If no explosion hazardous atmospheres exist, the permissible operating temperatures and pressures have to be taken from the manufacturer's data (manual).

If the sensors of the capacitive continuous level measurement sensors are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.

If the capacitive continuous level measurement sensors are mounted in explosion hazardous areas which require apparatus of the category 2 the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

Temperature class	Ambient temperature range	Medium temperature range at measuring sensor		
		PE insulation	PTFE insulation	PTFE insulation with temperature adapter
T6	-40 °C ... +38 °C	-40 °C ... +80 °C	-50 °C ... +85 °C	-50 °C ... +85 °C
T5	-40 °C ... +53 °C		-50 °C ... +100 °C	-50 °C ... +100 °C
T4	-40 °C ... +60 °C		-50 °C ... +135 °C	-50 °C ... +135 °C
T3			-50 °C ... +150 °C	-50 °C ... +200 °C
T2				
T1				

If the sensors of the capacitive continuous level measurement sensors are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.

### Specific Conditions of Use

1. At the plastic parts of the capacitive continuous level measurement sensors there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.
2. For zone 0/1 applications and at risks by pendulum or vibration the respective parts of the capacitive continuous level measurement sensors have to be secured effectively against these dangers. Observe manual of the manufacturer.
3. For zone 0/1 applications, at the metallic electrode parts of the capacitive continuous level measurement sensors made of light metal there is a danger of ignition by impact or friction. Observe manual of the manufacturer.
4. For zone 0/1 applications the medium tangent materials have to be resistant to the media.
5. The flameproof terminal box (Ex-d connection room) of this equipment must be provided with cable entries and filler plugs resp. conduits which are certified according to IEC 60079-0 and IEC 60079-1.

6. The PA terminal of the capacitive continuous level measurement sensors with the barriers P2-2LH and KLEMP2-2LPAFFD (internal or external screw terminal) has to be connected with the potential equalization of the explosion hazardous area.

Since the intrinsically safe circuits are galvanically connected with the earth potential, potential compensation has to exist in the complete course of the erection of the intrinsically safe operation and indication circuit.



# IECEx Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: IECEx TUN 05.0018X issue No.: 4

Status: **Current**

Date of Issue: 2008-10-17 Page 1 of 6

Applicant: **VEGA Grieshaber KG**  
Am Hohenstein 13  
77761 Schiltach  
Germany

**Certificate history:**

Issue No. 4 (2008-10-17)  
Issue No. 3 (2008-10-17)  
Issue No. 2 (2007-11-22)  
Issue No. 1 (2006-12-13)

Electrical Apparatus: **Capacitive Measuring Probe type VEGACAL CL6\*.DI\*\*\*H\*\*\*\***  
Optional accessory: --

Type of Protection: **Flameproof Enclosures and Intrinsic Safety**

Marking: **Zone 0/1 Ex d ia IIC T6**

Approved for issue on behalf of the IECEx Certification Body: Karl-Heinz Schwedt

Position: Head of IECEx CB

Signature:  
(for printed version)

Date:

2008-10-17

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

**TÜV NORD CERT GmbH**  
Hanover Office  
Am TÜV 1  
30519 Hannover  
Germany





# IECEx Certificate of Conformity

Certificate No.: IECEx TUN 05.0018X

Date of Issue: 2008-10-17

Issue No.: 4

Page 2 of 6

Manufacturer: **VEGA Grieshaber KG**  
Am Hohenstein 13  
77761 Schiltach  
Germany

**Manufacturing location(s):**

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

**STANDARDS:**

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

<b>IEC 60079-0 : 2004</b> Edition: 4.0	Electrical apparatus for explosive gas atmospheres - Part 0: General requirements
<b>IEC 60079-1 : 2003</b> Edition: 5	Electrical apparatus for explosive gas atmospheres - Part 1: Flameproof enclosure 'd'
<b>IEC 60079-11 : 2006</b> Edition: 5	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
<b>IEC 60079-26 : 2004</b> Edition: 1	Electrical apparatus for explosive gas atmospheres - Part 26: Construction, test and marking of Group II Zone 0 electrical apparatus

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

**TEST & ASSESSMENT REPORTS:**

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

IECEx ATR:  
DE/TUN/EXTR08.0035/00

File Reference:  
08 204 554741



# IECEx Certificate of Conformity

Certificate No.: IECEx TUN 05.0018X

Date of Issue: 2008-10-17

Issue No.: 4

Page 3 of 6

## Schedule

### EQUIPMENT:

*Equipment and systems covered by this certificate are as follows:*

The capacitive measuring probes type VEGACAL CL6\*.DI\*\*HD\* are used for monitoring or control of filling levels in explosi  
The measuring media are allowed to be combustible liquids, gases, mists or vapours.

The capacitive measuring probes type VEGACAL CL6\*.DI\*\*HD\* consist of an electronic housing for the barriers with an Ex-d connection room, an Ex-i connection room with inserted measuring electronics, a process adapting element and a measuring sensor.

Mechanical execution of the capacitive measuring probes:

type	electrodes
CL62.DI**HD*	partly insulated electrode, optionally with screening tube or concentric tube
CL63.DI**HD*	fully insulated electrode, optionally plated
CL64.DI**HD*	fully insulated electrode, optionally with screening tube, concentric tube or plated
CL65.DI**HD*	partly insulated cable electrode optionally with additionally insulated cable
CL66.DI**HD*	fully insulated cable electrode

### CONDITIONS OF CERTIFICATION: YES as shown below:

Only changes regarding the formatting; see annex



# IECEx Certificate of Conformity

Certificate No.: IECEX TUN 05.0018X

Date of Issue: 2008-10-17

Issue No.: 4

Page 4 of 6

**EQUIPMENT(continued):**

Only changes regarding the formatting; see annex





# IECEx Certificate of Conformity

Certificate No.: IECEx TUN 05.0018X

Date of Issue: 2008-10-17

Issue No.: 4

Page 5 of 6

## DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

See annexe issue 3



# IECEx Certificate of Conformity

Certificate No.: IECEx TUN 05.0018X

Date of Issue: 2008-10-17

Issue No.: 4

Page 6 of 6

**Additional information:**

Only changes regarding the formatting; see annexe



## IECEx Certificate of Conformity

### INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.:	IECEx TUN 05.0018X	Issue No.:	3	<b>Certificate history:</b> Issue No. 4 (2008-10-17) Issue No. 3 (2008-10-17) Issue No. 2 (2007-11-22) Issue No. 1 (2006-12-13)
Status:	Cancelled			
Date of Issue:	2008-10-17	Page 1 of 6		
Applicant:	<b>VEGA Grieshaber KG</b> Am Hohenstein 13 77761 Schiltach Germany			
Electrical Apparatus:	<b>Capacitive Measuring Probe type VEGACAL CL6"DI"HD"</b>			
Optional accessory:	--			
Type of Protection:	<b>Flameproof Enclosures and Intrinsic Safety</b>			
Marking:	<b>Ex d ia IIC T6</b>			
Approved for issue on behalf of the IECEx Certification Body:		Karl-Heinz Schwedt		
Position:		Head of IECEx CB		
Signature: (for printed version)	_____			
Date:	_____			

- This certificate and schedule may only be reproduced in full.
- This certificate is not transferable and remains the property of the issuing body.
- The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

**TÜV NORD CERT GmbH**  
 Hanover Office  
 Am TÜV 1  
 30519 Hannover  
 Germany



## IECEx Certificate of Conformity

Certificate No.: IECEx TUN 05.0018X  
 Date of Issue: 2008-10-17  
 Issue No.: 3  
 Page 2 of 6

Manufacturer: **VEGA Grieshaber KG**  
 Am Hohenstein 13  
 77761 Schiltach  
 Germany

Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx '02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

<b>IEC 60079-0 : 2004</b> Edition: 4.0	Electrical apparatus for explosive gas atmospheres - Part 0: General requirements
<b>IEC 60079-1 : 2003</b> Edition: 5	Electrical apparatus for explosive gas atmospheres - Part 1: Flameproof enclosure 'd'
<b>IEC 60079-11 : 2006</b> Edition: 5	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
<b>IEC 60079-26 : 2004</b> Edition: 1	Electrical apparatus for explosive gas atmospheres - Part 26: Construction, test and marking of Group II Zone 0 electrical apparatus

*This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

#### TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

IECEx ATR:  
DE/TUNExTR08.0035/00

File Reference:  
08 204 554741





## IECEx Certificate of Conformity

Certificate No.: IECEx TUN 05.0018X

Date of Issue: 2008-10-17

Issue No.: 3

Page 3 of 6

### Schedule

#### EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The capacitive measuring probes type VEGACAL CL6\*.DI\*\*HD\* are used for monitoring or control of filling levels in explosion hazardous areas. The measuring media are allowed to be combustible liquids, gases, mists or vapours. The capacitive measuring probes type VEGACAL CL6\*.DI\*\*HD\* consist of an electronic housing for the barriers with an Ex-d connection room, an Ex-i connection room with inserted measuring electronics, a process adapting element and a measuring sensor.

Mechanical execution of the capacitive measuring probes:

type	electrodes
CL62.DI**HD*	partly insulated electrode, optionally with screening tube or concentric tube
CL63.DI**HD*	fully insulated electrode, optionally plated
CL64.DI**HD*	fully insulated electrode, optionally with screening tube, concentric tube or plated
CL65.DI**HD*	partly insulated cable electrode optionally with additionally insulated cable
CL66.DI**HD*	fully insulated cable electrode

#### CONDITIONS OF CERTIFICATION: YES as shown below:

Only changes regarding the formatting; see annexe



## IECEx Certificate of Conformity

Certificate No.: IECEx TUN 05.0018X


Date of Issue: 2008-10-17


Issue No.: 3



Page 4 of 6

#### EQUIPMENT(continued):

Only changes regarding the formatting; see annexe



		<b>IECEX Certificate of Conformity</b>	
Certificate No.:	IECEX TUN 05.0018X	Issue No.:	3
Date of Issue:	2008-10-17	Page	5 of 6
<b>DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):</b>			
See annexe for issue 2			

		<b>IECEX Certificate of Conformity</b>	
Certificate No.:	IECEX TUN 05.0018X	Issue No.:	3
Date of Issue:	2008-10-17	Page	6 of 6
<b>Additional information:</b>			
Only changes regarding the formatting; see annexe			



**Annexe:** 2nd supplement\_COC\_VEGACAL CL6\_DI\_H.pdf, CoC IECEX TUN 05.0018X\_complete inclusive of Special Conditions.pdf,  
IEg\_COC\_CAL CL6-DI-HD--pdf



IECEx TR:	File reference:
DE/TUN/ExTR08.0035/00	08 204 554741
IECEx QAR:	File reference:
DE/QAR/TUN/06.0002/00	QAR/TUN/QAR06.0002/00

The capacitive measuring probes type VEGACAL CL6\*.DI\*\*\*H\*\*\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

The capacitive measuring probes type VEGACAL CL6\*.DI\*\*\*H\*\*\*\* consist of an electronic housing for the barrier with an Ex-d connection room, an Ex-i connection room with inserted measuring electronics, a process adapting element and a measuring sensor.

The changes refer to the type designation mentioned above, the mechanical construction, the temperature range in the area of the electronics/of the medium, the electrical data, the special conditions for safe use and the marking.

The marking reads as follows: Zone 0/1 Ex d ia IIC Tx (see tables for temperature ranges).

Type designation and mechanical execution of the measuring probes:

Type	Electrodes
CL62.DI***H****	partly insulated electrode, optionally with screening tube or concentric tube
CL63.DI***H****	fully insulated electrode, optionally plated
CL64.DI***H****	fully insulated electrode, optionally with screening tube, concentric tube or plated
CL65.DI***H****	partly insulated cable electrode optionally with additionally insulated cable
CL66.DI***H****	fully insulated cable electrode
CL69.DI***H****	fully insulated 2-rod electrode

If the capacitive measuring probes are mounted in explosion hazardous areas of the zone 1, the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

Temperature class	Ambient temperature range on the electronics/housing	Medium temperature range for electrodes with PE-insulation	Medium temperature range for other electrodes
T6	- 40°C... + 57°C	- 40°C... + 80°C	-50°C... +85 °C
T5	- 40°C... + 60°C	- 40°C... + 80°C	-50°C... +100 °C
T4	- 40°C... + 60°C	- 40°C... + 80°C	-50°C... +135 °C
T3*, T2*, T1*	- 40°C... + 60°C	- 40°C... + 80°C	-50°C... +150 °C

\* with temperature adapter for medium temperatures > 150°C... 200°C

If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.

If the capacitive measuring probes are mounted in the partition wall between explosion hazardous areas of the zone 0 (electrode) and zone 1 (electronics), the permissible temperature range in the area of the electronics/of the medium has to be taken from the following table:

Temperature class	Ambient temperature range	Medium temperature range
T6	-40 °C ... +57 °C	-20°C ... +60 °C
T5 ... T1	-40 °C ... +60 °C	-20°C ... +60 °C

The electrodes of the capacitive measuring probes are allowed to be operated in an explosion hazardous area of the zone 0, only if atmospheric conditions exist (pressure from 0.8 bar to 1.1 bar).

If no explosion hazardous atmospheres exist, the permissible operating temperatures and pressures have to be taken from the manufacturer's data (manual).

If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature at the electronics/housing must not exceed the values as mentioned in the a.m. table.

Electrical data

Supply and signal circuit ..... U = 20 ... 36V d. c.  
 (Terminals K11/1, K11/2; Um = 253 V a. c.  
 Ex-d connection room)

PA terminal of the capacitive measuring probe with barrier P2-2LH ..... Connection to the potential equalisation in the explosion hazardous area  
 (Screw terminal)

Operation and indication circuit ..... in type of protection „Intrinsic Safety“ Ex ia IIC  
 (Terminals 5, 6, 7, 8 in the “i”-connection room resp. plug connection)  
 only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61 (IECEx PTB 06.0048)  
 The interconnection of the both intrinsically safe circuits was taken into account.  
 maximum values of the connection cable:  
 Co = 2.4 µF  
 Lo = 160 µH

Operation and indication module circuit .... in type of protection „Intrinsic Safety“ Ex ia IIC  
 (Spring contacts in the “i”-connection room)  
 only for connection to the VEGA operation and indication module (Plicscom)

Communication circuit ..... in type of protection „Intrinsic Safety“ Ex ia IIC  
 (I<sup>2</sup>C bus in the “i”-connection room)  
 only for connection to the intrinsically safe signal circuit of the VEGA interface converter type VEGACONNECT

If

- the VEGA interface converter type VEGACONNECT and
  - the external VEGA indication unit type VEGADIS61 (IECEx PTB 06.0048)
- are connected, the following maximum values of the connection cable to the VEGADIS61 do result:

$$\begin{array}{rcl} C_o = & 2.8 & \mu\text{F} \\ L_o = & 100 & \mu\text{H} \end{array}$$

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

All intrinsically safe circuits of the capacitive measuring probe with built-in barrier P2-2LH are galvanically connected with the earth potential (measuring circuit excluded)

#### Special conditions for safe use:

1. At the plastic parts of the capacitive measuring probes type VEGACAL CP6\*.DI\*\*\*H\*\*\*\* there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.
2. For zone 0/1 applications and at risks by pendulum or vibration the respective parts of the capacitive measuring probes type VEGACAL CP65.DI\*\*\*H\*\*\*\* and type VEGACAL CP66.DI\*\*\*H\*\*\*\* have to be secured effectively against these dangers. Observe manual of the manufacturer.
3. For zone 0/1 applications, at the metallic electrode parts of the capacitive measuring probes type VEGACAL CP6\*.DI\*\*\*H\*\*\*\* made of light metal there is a danger of ignition by impact or friction. Observe manual of the manufacturer.
4. For zone 0/1 applications the medium tangent materials have to be resistant to the media.
5. The PA terminal of the capacitive measuring probes (internal or external screw terminal) has to be connected with the potential equalization of the explosion hazardous area.
6. The flameproof terminal box (Ex-d connection room) of this equipment must be provided with cable entries and filler plugs resp. conduits which are certified according to IEC 60 079-0 and IEC 60 079-1.
7. The connection cables, the cable entries and filler plugs resp. the conduits have to be suitable for the lowest ambient temperature.



# IECEx Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.:	IECEx TUN 05.0018X	issue No.: 2	Certificate history: Issue No. 2 (2007-11-22) Issue No. 1 (2006-12-13)
Status:	Current		
Date of Issue:	2007-11-22	Page 1 of 6	
Applicant:	VEGA Grieshaber KG Am Hohenstein 13 77761 Schiltach Germany		
Electrical Apparatus: Optional accessory:	Capacitive Measuring Probe type VEGACAL CL6*.DI**HD* --		
Type of Protection:	Flameproof Enclosures and Intrinsic Safety		
Marking:	Ex d ia IIC T6		
Approved for issue on behalf of the IECEx Certification Body:		Karl-Heinz Schwedt	
Position:		Head of IECEx CB	
Signature: (for printed version)			
Date:		<u>2007-11-22</u>	

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by

TÜV NORD CERT GmbH & Co. KG  
Am TÜV1  
D-30519 Hannover  
Germany





# IECEx Certificate of Conformity

Certificate No.: IECEX TUN 05 0018X

Date of Issue: 2007-11-22

Issue No. 2

Page 2 of 6

Manufacturer: **VEGA Grieshaber KG**  
Am Hohenstein 13  
77761 Schiltach  
Germany

Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2004 Edition: 4.0	Electrical apparatus for explosive gas atmospheres - Part 0: General requirements
IEC 60079-1 : 2003 Edition: 5	Electrical apparatus for explosive gas atmospheres - Part 1: Flameproof enclosure 'd'
IEC 60079-11 : 1999 Edition: 4	Electrical apparatus for explosive gas atmospheres - Part 11: Intrinsic safety 'i'

*This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

#### TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

IECEx ATR  
DE/TUN/05/551830  
DE/TUN/05/552075-1

File Reference:  
05YEX551830  
05YEX552075-1



# IECEx Certificate of Conformity

Certificate No.: IECEx TUN 05.0018X

Date of Issue: 2007-11-22

Issue No.: 2

Page 3 of 6

## Schedule

### EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The capacitive measuring probes type VEGACAL CL6\* DI\*\*HD\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

The capacitive measuring probes type VEGACAL CL6\* DI\*\*HD\* consist of an electronic housing for the barriers with an Ex-d connection room, an Ex-i connection room with inserted measuring electronics,

a process adapting element and a measuring sensor.

Mechanical execution of the capacitive measuring probes:

type	electrodes
CL62 DI**HD*	partly insulated electrode, optionally with screening tube or concentric tube
CL63 DI**HD*	fully insulated electrode, optionally plated
CL64 DI**HD*	fully insulated electrode, optionally with screening tube, concentric tube or plated
CL65 DI**HD*	partly insulated cable electrode optionally with additionally insulated cable
CL66 DI**HD*	fully insulated cable electrode

CONDITIONS OF CERTIFICATION: YES as shown below:

Only changes regarding the formatting, see annex



# IECEX Certificate of Conformity

Certificate No.: IECEX TUN 05.0018X

Date of Issue: 2007-11-22

Issue No.: 2

Page 4 of 6

**EQUIPMENT(continued):**

Only changes regarding the formatting, see annexe



# IECEX Certificate of Conformity

Certificate No.: IECEX TUN 05.0018X

Date of Issue: 2007-11-22

Issue No.: 2

Page 5 of 6

**DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):**

Only changes regarding the formatting; see annexe





# IECEX Certificate of Conformity

Certificate No.: IECEX TUN 05 0018X

Date of Issue: 2007-11-22

Issue No.: 2

Page 6 of 6

**Additional information:**

Only changes regarding the formatting, see annexe

**Annexe:** CoC IECEX TUN 05.0018X\_complete inclusive of Special Conditions.pdf, 1Erg\_COC\_CAL CL6-DI--HD--.pdf

The capacitive measuring probes type VEGACAL CL6\*.DI\*\*HD\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

The capacitive measuring probes type VEGACAL CL6\*.DI\*\*HD\* consist of an electronic housing for the barriers with an Ex-d connection room, an Ex-i connection room with inserted measuring electronics, a process adapting element and a measuring sensor.

Mechanical execution of the capacitive measuring probes:

type	electrodes
CL62.DI**HD*	partly insulated electrode, optionally with screening tube or concentric tube
CL63.DI**HD*	fully insulated electrode, optionally plated
CL64.DI**HD*	fully insulated electrode, optionally with screening tube, concentric tube or plated
CL65.DI**HD*	partly insulated cable electrode optionally with additionally insulated cable
CL66.DI**HD*	fully insulated cable electrode

The permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

temperature class	ambient temperature range on the electronics/housing	medium temperature range for electrodes with PE/PA-insulation	medium temperature range for other electrodes
T6	- 40°C... + 57°C	- 40°C... + 80°C	-50°C ... +85 °C
T5	- 40°C... + 60°C	- 40°C... + 80°C	-50°C ... +100 °C
T4	- 40°C... + 60°C	- 40°C... + 80°C	-50°C ... +135 °C
T3*, T2*, T1*	- 40°C... + 60°C	- 40°C... + 80°C	-50°C ... +150 °C

\* with temperature adapter for medium temperatures > 150°C ... 200°C

If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.

Electrical data

Supply and signal circuit  
(Terminals K11/1, K11/2;  
Ex-d connection room)

U = 20 ... 36 V d. c.  
U<sub>m</sub> = 253 V a. c.

PA terminal of the capacitive measuring probe with barrier P2-2LH  
(Screw terminal)

Connection to the potential equalisation in the explosion hazardous area

Operation and indication circuit  
(Terminals 5, 6, 7, 8 in the "i"-connection room resp., plug connection)

in type of protection „Intrinsic Safety“ Ex ia IIC  
only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61  
The interconnection of the both intrinsically safe circuits was taken into account.  
maximum values of the connection cable:  
Co = 2,4 µF  
Lo = 160 µH

Operation and indication module circuit  
(Spring contacts in the "i"-connection room) in type of protection „Intrinsic Safety“ Ex ia IIC  
only for connection to the VEGA operation and indication module (Plicscom)

Communication circuit  
(PC bus in the "i"-connection room) in type of protection „Intrinsic Safety“ Ex ia IIC  
only for connection to the intrinsically safe signal circuit of the VEGA interface converter type VEGACONNECT

The VEGA interface converter may only be operated together with the capacitive measuring probe, if no explosion hazardous atmosphere exists.

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

All intrinsically safe circuits of the capacitive measuring probes with built-in barrier KLEMP2-2LHD are safe galvanically separated from the non intrinsically safe supply and signal circuit and the parts which can be earthed. All intrinsically safe circuits of the capacitive measuring probe with built-in barrier P2-2LH are galvanically connected with the earth potential (measuring circuit excluded).

#### Conditions of Certification

1. At the plastic parts of the capacitive measuring probes type VEGACAL CL6\*.DI\*\*HD\* there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.
2. The flameproof terminal box (Ex-d connection room) of this equipment must be provided with cable entries and filler plugs resp. conduits which are certified according to IEC 60 079-0 and IEC 60 079-1.
3. The connection cables, the cable entries and filler plugs resp. the conduits have to be suitable for the lowest ambient temperature.
4. The PA terminal of the capacitive measuring probes with the barrier P2-2LH (internal or external screw terminal) has to be connected with the potential equalization of the explosion hazardous area. Since the intrinsically safe circuits are galvanically connected with the earth potential, potential compensation has to exist in the complete course of the erection of the intrinsically safe operation and indication circuit.
5. The intrinsically signal circuit of the barrier type KLEMP2-2LHD is safe galvanically separated from the non intrinsically safe supply and signal circuit up to a peak crest value of the voltage of 375 V. The intrinsically safe signal circuit of the barrier type P2-2LH is galvanically connected with the earth potential.

 <h2 style="text-align: center;">IECEx Certificate of Conformity</h2>	
<b>INTERNATIONAL ELECTROTECHNICAL COMMISSION</b> <b>IEC Certification Scheme for Explosive Atmospheres</b> <small>for rules and details of the IECEx Scheme visit <a href="http://www.iecex.com">www.iecex.com</a></small>	
Certificate No.:	IECEx TUN 05.0018X <span style="float: right;">Issue No.:1</span>
Status:	<b>Current</b>
Date of Issue:	<b>2006-12-13</b> <span style="float: right;">Page 1 of 6</span>
Applicant:	<b>VEGA Grieshaber KG</b> Am Hohenstein 13 77761 Schiltach Germany
Electrical Apparatus:	<b>Capacitive Measuring Probe type VEGACAL CL6"DI"HD"</b>
Optional accessory:	--
Type of Protection:	<b>Flameproof Enclosures and Intrinsic Safety</b>
Marking:	<b>Ex d ia IIC T6</b>
Approved for issue on behalf of the IECEx Certification Body:	Karl-Heinz Schwedt
Position:	Head of IECEx CB
Signature: (for printed version)	_____
Date:	_____
<p>1. This certificate and schedule may only be reproduced in full.            2. This certificate is not transferable and remains the property of the issuing body.            3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.</p>	
Certificate issued by: <div style="display: flex; justify-content: space-between; align-items: center;"> <div style="text-align: center;"> <p><b>TÜV NORD CERT GmbH &amp; Co. KG</b> Am TÜV1 D-30519 Hannover Germany</p> </div> <div style="text-align: center;">  </div> </div>	
 <h2 style="text-align: center;">IECEx Certificate of Conformity</h2>	
Certificate No.:	IECEx TUN 05.0018X <span style="float: right;">Issue No.: 1</span>
Date of Issue:	<b>2006-12-13</b> <span style="float: right;">Page 2 of 6</span>
Manufacturer:	<b>VEGA Grieshaber KG</b> Am Hohenstein 13 77761 Schiltach Germany
Manufacturing location(s):	
<p>This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx '02' and Operational Documents as amended.</p>	
<p><b>STANDARDS:</b>            The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:</p>	
<b>IEC 60079-0 : 2004</b> Edition: 4.0	Electrical apparatus for explosive gas atmospheres - Part 0: General requirements
<b>IEC 60079-1 : 2003</b> Edition: 5	Electrical apparatus for explosive gas atmospheres - Part 1: Flameproof enclosure 'd'
<b>IEC 60079-11 : 1999</b> Edition: 4	Electrical apparatus for explosive gas atmospheres - Part 11: Intrinsic safety 'i'
<p><i>This Certificate <b>does not</b> indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.</i></p>	
<p><b>TEST &amp; ASSESSMENT REPORTS:</b>            A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in</p>	
IECEx ATR: DE/TUN05/551830 DE/TUN05/552075-1	File Reference: 05YEX551830 05YEX552075-1



IEC		IECEX		<b>IECEX Certificate of Conformity</b>	
Certificate No.:	IECEX TUN 05.0018X				
Date of Issue:	2006-12-13	Issue No.:	1		
		Page	3 of 6		
<b>Schedule</b>					
<b>EQUIPMENT:</b>					
Equipment and systems covered by this certificate are as follows:					
The capacitive measuring probes type VEGACAL CL6 <sup>*</sup> DI <sup>**</sup> HD <sup>*</sup> are used for monitoring or control of filling levels in explosi The measuring media are allowed to be combustible liquids, gases, mists or vapours. The capacitive measuring probes type VEGACAL CL6 <sup>*</sup> DI <sup>**</sup> HD <sup>*</sup> consist of an electronic housing for the barriers with an Ex- connection room with inserted measuring electronics, a process adapting element and a measuring sensor. Mechanical execution of the capacitive measuring probes:					
type	electrodes				
CL62 DI <sup>**</sup> HD <sup>*</sup>	partly insulated electrode, optionally with screening tube or concentric tube				
CL63 DI <sup>**</sup> HD <sup>*</sup>	fully insulated electrode, optionally plated				
CL64 DI <sup>**</sup> HD <sup>*</sup>	fully insulated electrode, optionally with screening tube, concentric tube or plated				
CL65 DI <sup>**</sup> HD <sup>*</sup>	partly insulated cable electrode optionally with additionally insulated cable				
CL66 DI <sup>**</sup> HD <sup>*</sup>	fully insulated cable electrode				
<b>CONDITIONS OF CERTIFICATION: YES as shown below:</b>					
1. At the plastic parts of the capacitive measuring probes type VEGACAL CL6 <sup>*</sup> DI <sup>**</sup> HD <sup>*</sup> there is a danger of ig manual of the manufacturer and warning label.					
2. The flameproof terminal box (Ex-d connection room) of this equipment must be provided with cable entries and filler pl IEC 60 079-0 and IEC 60 079-1.					
3. The connection cables, the cable entries and filler plugs resp. the conduits have to be suitable for the lowest ambient t 4. The PA terminal of the capacitive measuring probes with the barrier P2-2LH (internal or external screw terminal) has t the explosion hazardous area.					
Since the intrinsically safe circuits are galvanically connected with the earth potential, potential compensation has to exist in intrinsically safe operation and indication circuit.					
5. The intrinsically signal circuit of the barrier type KLEMP2-2LHD is safe galvanically separated from the non intrinsically value of the voltage of 375 V.					
The intrinsically safe signal circuit of the barrier type P2-2LH is galvanically connected with the earth potential.					

IEC		IECEX		<b>IECEX Certificate of Conformity</b>	
Certificate No.:	IECEX TUN 05.0018X				
Date of Issue:	2006-12-13	Issue No.:	1		
		Page	4 of 6		
<b>EQUIPMENT(continued):</b>					
The permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:					
temperature class	ambient temperature range on the electronics/housing	medium temperature range for electrodes with PE/PA-insulation	medium tempera for other elec		
T6	-40°C... +57°C	-40°C... +80°C	-50°C ... +8		
T5	-40°C... +60°C	-40°C... +80°C	-50°C ... +1		
T4	-40°C... +60°C	-40°C... +80°C	-50°C ... +3		
T3*, T2*, T1*	-40°C... +60°C	-40°C... +80°C	-50°C ... +1		
* with temperature adapter for medium temperatures > 150°C ... 200°C					
If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.					
<b>Electrical data</b>					
Supply and signal circuit (Terminals K11/1, K11/2; Ex-d connection room)	U = 20 ... 36 V d.c. U <sub>m</sub> = 253 V a.c.	Connection to the potential equalisation in the explosion hazardous area			
PA terminal of the capacitive measuring probe with barrier P2-2LH (Screw terminal)	in type of protection „Intrinsic Safety“ Ex ia IIC only for connection to the intrinsically safe circuit of the				
Operation and indication circuit (Terminals 5, 6, 7, 8 in the "T"					

connection room resp., plug connection)

belonging external VEGA indication unit type VEGADIS61  
The interconnection of the both intrinsically safe circuits was  
taken into account.  
maximum values of the connection cable:  
Co = 2,4 µF  
Lo = 160 µH

IEC		IECEx		<b>IECEx Certificate of Conformity</b>	
Certificate No.:	IECEX TUN 05.0018X				
Date of Issue:	2006-12-13	Issue No.:	1		
			Page 5 of 6		
<b>DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):</b>					
See annexe					

IEC		IECEx		<b>IECEx Certificate of Conformity</b>	
Certificate No.:	IECEX TUN 05.0018X				
Date of Issue:	2006-12-13	Issue No.:	1		
			Page 6 of 6		
<b>Additional information:</b>					
Operation and indication module circuit (Spring contacts in the "T"-connection room)	in type of protection „Intrinsic Safety“ only for connection to the VEGA operation and indication mod (Plicocom)	Ex ia IIC			
Communication circuit (PC bus in the "T"-connection room)	in type of protection „Intrinsic Safety“ only for connection to the intrinsically safe signal circuit of the interface converter type VEGACONNECT	Ex ia IIC			
The VEGA interface converter may only be operated together with the capacitive measuring probe, if no hazardous atmosphere exists.					
A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing is permissible.					
All intrinsically safe circuits of the capacitive measuring probes with built-in barrier KLEMP2-2LHD are galvanically separated from the non intrinsically safe supply and signal circuit and the parts which can be connected with the earth potential (measuring circuit excluded).					





Annexe: 1Erg\_COE\_CAL CL6-DI-HD-pdf

IECEx ATR:	File reference:
DE/TUN/ExTR06.0043/01	06 TUN 553278
IECEx QAR:	File reference:
DE/QAR/TUN/06.0002/00	QAR TUN 04.0002

The capacitive measuring probes type VEGACAL CL6\*.DI\*\*HD\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

The changes refer to the mechanical and electrical construction of the measuring probes as well as to the electrical data.

Mechanical execution of the measuring probes

Type	Electrodes
CL62. DI **HD**	partly insulated electrode, optionally with screening tube or concentric tube
CL63. DI **HD**	fully insulated electrode, optionally plated
CL64. DI **HD**	fully insulated electrode, optionally with screening tube, concentric tube or plated
CL65. DI **HD**	partly insulated cable electrode optionally with additionally insulated cable
CL66. DI **HD**	fully insulated cable electrode
CL69. DI **HD**	fully insulated 2-rod electrode

Electrical data

Supply and signal circuit ..... U = 20 ... 36 V d. c.  
 (Terminals K11/1, K11/2; Um = 253 V a. c.  
 Ex-d connection room)

PA terminal of the  
 capacitive measuring probe with barrier  
 P2-2LH ..... Connection to the potential equalisation in the  
 (Screw terminal) explosion hazardous area

Operation and indication circuit ..... (Terminals 5, 6, 7, 8 in the "i"-connection room resp., plug connection)	in type of protection „Intrinsic Safety“ Ex ia IIC  only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61 (IECEX PTB 06.0048) The interconnection of the both intrinsically safe circuits was taken into account. maximum values of the connection cable: Co = 2.4 $\mu$ F Lo = 160 $\mu$ H
Operation and indication module circuit .... (Spring contacts in the "i"-connection room)	in type of protection „Intrinsic Safety“ Ex ia IIC only for connection to the VEGA operation and indication module (Plicscom)
Communication circuit ..... (I <sup>2</sup> C bus in the "i"-connection room)	in type of protection „Intrinsic Safety“ Ex ia IIC only for connection to the intrinsically safe signal circuit of the VEGA interface converter type VEGACONNECT

If

- the VEGA interface converter type VEGACONNECT and
  - the external VEGA indication unit type VEGADIS61 (IECEX PTB 06.0048)
- are connected, the following maximum values of the connection cable to the VEGADIS61 do result:

$$\begin{aligned} C_o &= 2.8 & \mu\text{F} \\ L_o &= 100 & \mu\text{H} \end{aligned}$$

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

All intrinsically safe circuits of the capacitive measuring probes with built-in barrier KLEMP2-2LHD are safe galvanically separated from the non intrinsically safe supply and signal circuit and the parts which can be earthed.

All intrinsically safe circuits of the capacitive measuring probe with built-in barrier P2-2LH are galvanically connected with the earth potential (measuring circuit excluded)



# IECEx Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: **IECEx TUN 05.0019X** issue No.: **3**

Status: **Current**

Date of Issue: **2014-08-07** Page 1 of 4

Certificate history:  
Issue No. 3 (2014-8-7)  
Issue No. 2 (2008-10-17)  
Issue No. 1 (2006-11-7)

Applicant: **VEGA Grieshaber KG**  
Am Hohenstein 13  
77761 Schiltach  
Germany

Electrical Apparatus: **Capacitive Measuring Probe type VEGACAL CL6\*(\*)..DI\*\*\*P/F\*\*\*\*(\*)(\*)**  
Optional accessory: **--**

Type of Protection: **Flameproof Enclosures and Intrinsic Safety**

Marking: **Ex d ia IIC T6 Ga/Gb, Gb**

Approved for issue on behalf of the IECEx Certification Body: **Meyer**

Position: **Head of IECEx Certification Body**

Signature:  
(for printed version)

Date:

  
2014-08-07

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

**TÜV NORD CERT GmbH**  
Hanover Office  
Am TÜV 1  
30519 Hannover  
Germany





# IECEx Certificate of Conformity

Certificate No.: IECEx TUN 05.0019X

Date of Issue: 2014-08-07

Issue No.: 3

Page 2 of 4

Manufacturer: **VEGA Grieshaber KG**  
Am Hohenstein 13  
77761 Schiltach  
Germany

Additional Manufacturing location  
(s):

**VEGA Americas, Inc**  
4241 Allendorf Drive  
Cincinnati, Ohio 45209  
United States of America

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

<b>IEC 60079-0 : 2011</b> Edition: 6.0	Explosive atmospheres - Part 0: General requirements
<b>IEC 60079-1 : 2007-04</b> Edition: 6	Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
<b>IEC 60079-11 : 2011</b> Edition: 6.0	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
<b>IEC 60079-26 : 2006</b> Edition: 2	Explosive atmospheres - Part 26: Equipment with equipment protection level (EPL) Ga

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

#### TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

IECEx ATR:  
DE/TUN/ExTR 08.0036/01  
IECEx QAR:  
DE/TUN/QAR06.0002/05

File Reference:  
14 217 141381



# IECEx Certificate of Conformity

Certificate No.: IECEx TUN 05.0019X

Date of Issue: 2014-08-07

Issue No.: 3

Page 3 of 4

## Schedule

### EQUIPMENT:

*Equipment and systems covered by this certificate are as follows:*

see annexe

### CONDITIONS OF CERTIFICATION: YES as shown below:

see annexe



# IECEx Certificate of Conformity

Certificate No.: IECEx TUN 05.0019X

Date of Issue: 2014-08-07

Issue No.: 3

Page 4 of 4

## DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

see annexe

Annex: Annexe\_COC\_VEGACALC\_issue 3\_TUN05.0019X\_pdf

IECEx TR:	File reference:
DE/TUN/ExTR08.0036/01	14 217 141381
IECEx QAR:	
DE/TUN/QAR/06.0002/05	

In the future, the following changes are performed for Capacitive Measuring Probe type VEGACAL CL6\*(\*) .DI\*\*\*P/F\*\*\*\*(\*) (\*):

1. Update to actual standards
2. Changes regarding technical and electrical data
3. Changes regarding electric diagram
4. Changes to the layout
5. New components used
6. Application with PLICSCOM 02 added
7. Application with VEGADIS81 added
8. Introduction of new cables
9. Changes of the type code/markings
10. New manufacturing location added

### Electrical data

#### **Non-intrinsically safe circuits**

VEGACAL CL6\*(\*) .DI\*\*\*H\*\*\*\*(\*) (\*) U = 20 ... 36 V DC

Supply and signal circuit U<sub>m</sub> = 253 V AC

(terminal 1[+], 2[-] in the Ex-d connection compartment)

VEGACAL CL6\*(\*) .DI\*\*\*P/F\*\*\*\*(\*) (\*) U = 16 ... 36 V DC

Supply and signal circuit U<sub>m</sub> = 253 V AC

(terminal 1[+], 2[-] in the Ex-d connection compartment)

#### **Intrinsically safe circuits**

Indicating and adjustment circuit:  
 (terminals 5, 6, 7, 8 in Ex-i connection compartment or plug connection)

Ignition protection type intrinsic safety  
 Ex ia IIC. For connection to the intrinsically safe circuit of the associated external indicating instrument VEGADIS 61 (IECEx PTB 06.0048).

The rules for the interconnection of intrinsically safe circuits between VEGACAL CL6\*(\*) .DI\*\*\* and the external indicating and adjustment unit VEGADIS 61 are maintained if the total inductance and total capacitance of the connection cable between VEGACAL CL6\*(\*) .DI\*\*\* and the external indicating unit VEGADIS 61/81 L<sub>cable</sub> = 100µH and



Page 2 of 4  
Annexe to IECEx TUN 05.0019X Issue 3

$C_{\text{cable}}=2.8\mu\text{F}$  are not exceeded.  
The indication and adjustment module integrated in CL6\*(\*)DI\*\*\* and the connected VEGACONNECT are taken into account.

Communication circuit  
(I<sup>2</sup>C bus socket in “Ex-i” connection compartment)

In ignition protection intrinsic safety Ex ia IIC.

Only for connection to the intrinsically safe signal circuit of a certified VEGA interface converter VEGACONNECT. The VEGA communication unit VEGACONNECT may only be operated on VEGACAL CL6\*(\*)DI\*\*\*H/P/F\*\*\*\*(\*)(\*), if there is no explosive atmosphere.

Indicating and adjustment module circuit  
(spring contacts in the “Ex i” connection compartment)

Ignition protection intrinsic safety Ex ia IIC.  
Only for connection to the indicating and adjustment module.

Capacitive measuring circuit: (separate electronics version)

Ignition protection intrinsic safety Ex ia IIC.  
For the version with separate housing the length of the triax or coax connection cable between electronics housing and electrode housing (remote housing) may not exceed 10 m.

The intrinsically safe circuits of the VEGACAL CL6\*(\*)DI\*\*\*P/F\*\*\*\*(\*)(\*) are reliably galvanically separated from the non-intrinsically safe signal and supply circuits and parts which can be grounded.

Permissible ambient temperatures:

**EPL-Ga/Gb instruments:**

**VEGACAL CL6\*(\*)DI\*\*\*H\*\*\*\*(\*)(\*)**

Temperature class	Permissible ambient temperature on the electronics	Permissible ambient temperature on the sensor
T6	-40°C ... +57°C	-20°C ... +60°C
T5 ... T1	-40°C ... +60°C	-20°C ... +60°C

For applications requiring instruments EPL-Ga/Gb the pressure at the sensor probe must be between 0.8 bar to 1.1 bar.

The permissible operating temperatures and pressures without explosive atmosphere are mentioned in the respective manufacturer instructions for each probe type.

**VEGACAL CL6\*(\*)DI\*\*\*P/F\*\*\*\*(\*)(\*)**

Temperature class	Permissible ambient temperature on the electronics	Permissible ambient temperature on the sensor
T6	-40°C ... +38°C	-20°C ... +60°C
T5	-40°C ... +53°C	-20°C ... +60°C
T4 ... T1	-40°C ... +60°C	-20°C ... +60°C

For applications requiring instruments EPL-Ga/Gb the pressure at the sensor probe must be between 0.8 bar to 1.1 bar.

The permissible operating temperatures and pressures without explosive atmosphere are mentioned in the respective manufacturer instructions for each probe type.

**EPL-Gb instruments:**

**VEGACAL CL6\*(\*)DI\*\*\*H\*\*\*\*(\*)(\*)**

Temperature class	Permissible ambient temperature on the electronics	Permissible ambient temperature on the sensor with PE/PA insulation	Permissible ambient temperature on the other sensors without temperature adapter	Permissible ambient temperature on the other sensors with temperature adapter
T6	-40°C ... +57°C	-40°C ... +80°C	-50°C ... +85°C	-50°C ... +85°C
T5	-40°C ... +60°C	-40°C ... +80°C	-50°C ... +100°C	-50°C ... +100°C
T4	-40°C ... +60°C	-40°C ... +80°C	-50°C ... +135°C	-50°C ... +135°C
T3, T2, T1	-40°C ... +60°C	-40°C ... +80°C	-50°C ... +150°C	-50°C ... +200°C

Page 4 of 4  
 Annexe to IECEx TUN 05.0019X Issue 3

If the sensors of the capacitive probes are operated at temperatures higher than those specified in the above table, appropriate measures need to be performed that the danger of ignition caused by these hot surfaces is excluded.

The permissible operating temperatures and pressures without explosive atmosphere are mentioned in the respective manufacturer instructions for each probe type.

**VEGACAL CL6\*(\*)-DI\*\*\*P/F\*\*\*\*(\*)(\*)**

Temperature class	Permissible ambient temperature on the electronics	Permissible ambient temperature on the sensor with PE/PA insulation	Permissible ambient temperature on the other sensors without temperature adapter	Permissible ambient temperature on the other sensors with temperature adapter
T6	-40°C ... +38°C	-40°C ... +80°C	-50°C ... +85°C	-50°C ... +85°C
T5	-40°C ... +53°C	-40°C ... +80°C	-50°C ... +100°C	-50°C ... +100°C
T4	-40°C ... +60°C	-40°C ... +80°C	-50°C ... +135°C	-50°C ... +135°C
T3, T2, T1	-40°C ... +60°C	-40°C ... +80°C	-50°C ... +150°C	-50°C ... +200°C

If the sensors of the capacitive probes are operated at temperatures higher than those specified in the above table, appropriate measures need to be performed that the danger of ignition caused by these hot surfaces is excluded.

The permissible operating temperatures and pressures without explosive atmosphere are mentioned in the respective manufacturer instructions for each probe type.



# IECEx Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: IECEx TUN 05.0019X issue No.:2

Status: **Current**

Certificate history:  
Issue No. 2 (2008-10-17)  
Issue No. 1 (2006-11-7)

Date of Issue: **2008-10-17** Page 1 of 4

Applicant: **VEGA Grieshaber KG**  
Am Hohenstein 13  
77761 Schiltach  
Germany

Electrical Apparatus: **Capacitive Measuring Probe type VEGACAL CL6\*.DI\*\*\*P/F\*\*\*\***  
Optional accessory: **--**

Type of Protection: **Flameproof Enclosures and Intrinsic Safety**

Marking: **Zone 0/1 Ex d ia IIC T6**

Approved for issue on behalf of the IECEx Certification Body: **Karl-Heinz Schwedt**

Position: **Head of IECEx CB**

Signature:  
(for printed version)

Date:

2008-10-17

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

**TÜV NORD CERT GmbH**  
Hanover Office  
Am TÜV 1  
30519 Hannover  
Germany





# IECEX Certificate of Conformity

Certificate No.: IECEX TUN 05.0019X

Date of Issue: 2008-10-17

Issue No.: 2

Page 2 of 4

Manufacturer: **VEGA Grieshaber KG**  
Am Hohenstein 13  
77781 Schiltach  
Germany

**Manufacturing location(s):**

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

**STANDARDS:**

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

<b>IEC 60079-0 : 2004</b> Edition: 4.0	Electrical apparatus for explosive gas atmospheres - Part 0: General requirements
<b>IEC 60079-1 : 2003</b> Edition: 5	Electrical apparatus for explosive gas atmospheres - Part 1: Flameproof enclosure 'd'
<b>IEC 60079-11 : 2006</b> Edition: 5	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
<b>IEC 60079-26 : 2004</b> Edition: 1	Electrical apparatus for explosive gas atmospheres - Part 26: Construction, test and marking of Group II Zone 0 electrical apparatus

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

**TEST & ASSESSMENT REPORTS:**

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

IECEX ATR:  
**DE/TUN/ExTR 08.0036.00**

File Reference:  
**08 204 554740**



# IECEx Certificate of Conformity

Certificate No.: IECEx TUN 05.0019X

Date of Issue: 2008-10-17

Issue No.: 2

Page 3 of 4

## Schedule

### EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The capacitive measuring probes type VEGACAL CL6\*.DI\*\*P/FD\* are used for monitoring or control of filling levels in explosion hazardous areas. The measuring media are allowed to be combustible liquids, gases, mists or vapours. The capacitive measuring probes type VEGACAL CL6\*.DI\*\*P/FD\* consist of an electronic housing for the barriers with an Ex-d connection room, an Ex-i connection room with inserted measuring electronics, a process adapting element and a measuring sensor.

Mechanical execution of the capacitive measuring probes:

type	electrodes
CL62.D **P/FD*	partly insulated electrode, optionally with screening tube or concentric tube
CL63.D **P/FD*	fully insulated electrode, optionally plated
CL64.D **P/FD*	fully insulated electrode, optionally with screening tube, concentric tube or plated
CL65.D **P/FD*	partly insulated cable electrode optionally with additionally insulated cable
CL66.D **P/FD*	fully insulated cable electrode

### CONDITIONS OF CERTIFICATION: YES as shown below:

1. At the plastic parts of the capacitive measuring probes type VEGACALP CL6\*.CI\*\*P/FD\* there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.
2. The flameproof terminal box (Ex-d connection room) of this equipment must be provided with cable entries and filler plugs resp. conduits which are certified according to IEC 60 079-0 and IEC 60 079-1.
3. The connection cables, the cable entries and filler plugs resp. the conduits have to be suitable for the lowest ambient temperature.



# IECEx Certificate of Conformity

Certificate No.: IECEx TUN 05.0019X

Date of Issue: 2008-10-17

Issue No.: 2

Page 4 of 4

## DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

See annexe

Annexe: 2nd supplement\_COC\_VEGACAL CL6\_DI\_P\_F.pdf

IECEx TR:	File reference:
DE/TUN/ExTR08.0036/00	08 204 554740
IECEx QAR:	File reference:
DE/QAR/TUN/06.0002/00	QAR/TUN/QAR06.0002/00

The capacitive measuring probes type VEGACAL CL6\*.DI\*\*\*P/F\*\*\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

The capacitive measuring probes type VEGACAL CL6\*.DI\*\*\*P/F\*\*\*\* consist of an electronic housing for the barrier with an Ex-d connection room, an Ex-i connection room with inserted measuring electronics, a process adapting element and a measuring sensor.

The changes refer to the type designation mentioned above, the mechanical construction, the temperature range in the area of the electronics/of the medium, the electrical data, the special conditions for safe use and the marking.

The marking reads as follows: Zone 0/1 Ex d ia IIC Tx (see tables for temperature ranges).

Type designation and mechanical execution of the measuring probes:

Type	Electrodes
CL62.DI***P/F****	partly insulated electrode, optionally with screening tube or concentric tube
CL63.DI*** P/F ****	fully insulated electrode, optionally plated
CL64.DI*** P/F ****	fully insulated electrode, optionally with screening tube, concentric tube or plated
CL65.DI*** P/F ****	partly insulated cable electrode optionally with additionally insulated cable
CL66.DI*** P/F ****	fully insulated cable electrode
CL69.DI*** P/F ****	fully insulated 2-rod electrode

If the capacitive measuring probes are mounted in explosion hazardous areas of the zone 1, the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

Temperature class	Ambient temperature range	Medium temperature range for electrodes with PE-insulation	Medium temperature range for other electrodes
T6	- 40°C... + 47°C	- 40°C... + 80°C	-50°C ... +85 °C
T5	- 40°C... + 60°C	- 40°C... + 80°C	-50°C ... +100 °C
T4	- 40°C... + 60°C	- 40°C... + 80°C	-50°C ... +135 °C
T3*, T2*, T1*	- 40°C... + 60°C	- 40°C... + 80°C	-50°C ... +150 °C

\* with temperature adapter for medium temperatures > 150°C ... 200°C

If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.



If the capacitive measuring probes are mounted in the partition wall between explosion hazardous areas of the zone 0 (electrode) and zone 1 (electronics), the permissible temperature range in the area of the electronics/of the medium has to be taken from the following table:

Temperature class	Ambient temperature range	Medium temperature range
T6	-40 °C ... +47 °C	-20°C ... +60 °C
T5	-40 °C ... +60 °C	-20°C ... +60 °C
T4, T3, T2, T1	-40 °C ... +60 °C	-20°C ... +60 °C

The electrodes of the capacitive measuring probes are allowed to be operated in an explosion hazardous area of the zone 0, only if atmospheric conditions exist (pressure from 0.8 bar to 1.1 bar).

If no explosion hazardous atmospheres exist, the permissible operating temperatures and pressures have to be taken from the manufacturer's data (manual).

If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature at the electronics/housing must not exceed the values as mentioned in the a.m. table.

#### Electrical data

Supply and signal circuit ..... U = 16 ... 32V d. c.  
(Terminals K11[+], K12[-]; U<sub>m</sub> = 253 V a. c.  
Ex-d connection room)

PA terminal of the capacitive measuring probe with barrier  
KLEMP2-2LPA/FFD ..... Connection to the potential equalisation in the  
(Screw terminal) explosion hazardous area

Operation and indication circuit ..... in type of protection „Intrinsic Safety“ Ex ia IIC  
(Terminals 5, 6, 7, 8 in the "i"-connection room resp. plug connection)  
only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61 (IECEx PTB 06.0048)  
The interconnection of the both intrinsically safe circuits was taken into account.  
maximum values of the connection cable:  
C<sub>o</sub> = 2.4 µF  
L<sub>o</sub> = 160 µH

Operation and indication module circuit ..... in type of protection „Intrinsic Safety“ Ex ia IIC  
(Spring contacts in the "i"-connection room) only for connection to the VEGA operation and indication module (Plicscom)

Communication circuit ..... in type of protection „Intrinsic Safety“ Ex ia IIC  
(I<sup>2</sup>C bus in the "i"-connection room) only for connection to the intrinsically safe signal circuit of the VEGA interface converter type VEGACONNECT

If

- the VEGA interface converter type VEGACONNECT and  
- the external VEGA indication unit type VEGADIS61 (IECEX PTB 06.0048)  
are connected, the following maximum values of the connection cable to the VEGADIS61 do result:

$$\begin{array}{rcl} C_o = & 2.8 & \mu\text{F} \\ L_o = & 100 & \mu\text{H} \end{array}$$

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

All intrinsically safe circuits of the capacitive measuring probe with built-in barrier KLEMP2-2LPA/FFD are galvanically connected with the earth potential (measuring circuit excluded)

Special conditions for safe use:

1. At the plastic parts of the capacitive measuring probes type VEGACAL CP6\*.DI\*\*\* P/F \*\*\*\* there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.
2. For zone 0/1 applications and at risks by pendulum or vibration the respective parts of the capacitive measuring probes type VEGACAL CP65.DI\*\*\* P/F \*\*\*\* and type VEGACAL CP66.DI\*\*\* P/F \*\*\*\* have to be secured effectively against these dangers. Observe manual of the manufacturer.
3. For zone 0/1 applications, at the metallic electrode parts of the capacitive measuring probes type VEGACAL CP6\*.DI\*\*\* P/F \*\*\*\* made of light metal there is a danger of ignition by impact or friction. Observe manual of the manufacturer.
4. For zone 0/1 applications the medium tangent materials have to be resistant to the media.
5. The PA terminal of the capacitive measuring probes (internal or external screw terminal) has to be connected with the potential equalization of the explosion hazardous area.
6. The flameproof terminal box (Ex-d connection room) of this equipment must be provided with cable entries and filler plugs resp. conduits which are certified according to IEC 60 079-0 and IEC 60 079-1.
7. The connection cables, the cable entries and filler plugs resp. the conduits have to be suitable for the lowest ambient temperature.

IECEx TR:	File reference:
DE/TUN/ExTR08.0036/00	08 204 554740
IECEx QAR:	File reference:
DE/QAR/TUN/06.0002/00	QAR/TUN/QAR06.0002/00

The capacitive measuring probes type VEGACAL CL6\*.DI\*\*\*P/F\*\*\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

The capacitive measuring probes type VEGACAL CL6\*.DI\*\*\*P/F\*\*\*\* consist of an electronic housing for the barrier with an Ex-d connection room, an Ex-i connection room with inserted measuring electronics, a process adapting element and a measuring sensor.

The changes refer to the type designation mentioned above, the mechanical construction, the temperature range in the area of the electronics/of the medium, the electrical data, the special conditions for safe use and the marking.

The marking reads as follows: Zone 0/1 Ex d ia IIC Tx (see tables for temperature ranges).

Type designation and mechanical execution of the measuring probes:

Type	Electrodes
CL62.DI***P/F****	partly insulated electrode, optionally with screening tube or concentric tube
CL63.DI*** P/F ****	fully insulated electrode, optionally plated
CL64.DI*** P/F ****	fully insulated electrode, optionally with screening tube, concentric tube or plated
CL65.DI*** P/F ****	partly insulated cable electrode optionally with additionally insulated cable
CL66.DI*** P/F ****	fully insulated cable electrode
CL69.DI*** P/F ****	fully insulated 2-rod electrode

If the capacitive measuring probes are mounted in explosion hazardous areas of the zone 1, the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

Temperature class	Ambient temperature range	Medium temperature range for electrodes with PE-insulation	Medium temperature range for other electrodes
T6	- 40°C... + 47°C	- 40°C... + 80°C	-50°C... +85 °C
T5	- 40°C... + 60°C	- 40°C... + 80°C	-50°C... +100 °C
T4	- 40°C... + 60°C	- 40°C... + 80°C	-50°C... +135 °C
T3*, T2*, T1*	- 40°C... + 60°C	- 40°C... + 80°C	-50°C... +150 °C

\* with temperature adapter for medium temperatures > 150°C... 200°C

If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.

If the capacitive measuring probes are mounted in the partition wall between explosion hazardous areas of the zone 0 (electrode) and zone 1 (electronics), the permissible temperature range in the area of the electronics/of the medium has to be taken from the following table:

Temperature class	Ambient temperature range	Medium temperature range
T6	-40 °C ... +47 °C	-20°C ... +60 °C
T5	-40 °C ... +60 °C	-20°C ... +60 °C
T4, T3, T2, T1	-40 °C ... +60 °C	-20°C ... +60 °C

The electrodes of the capacitive measuring probes are allowed to be operated in an explosion hazardous area of the zone 0, only if atmospheric conditions exist (pressure from 0.8 bar to 1.1 bar).

If no explosion hazardous atmospheres exist, the permissible operating temperatures and pressures have to be taken from the manufacturer's data (manual).

If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature at the electronics/housing must not exceed the values as mentioned in the a.m. table.

Electrical data

Supply and signal circuit ..... U = 16... 32V d. c.  
 (Terminals K11[+], K12[-]; U<sub>m</sub> = 253 V a. c.  
 Ex-d connection room)

PA terminal of the capacitive measuring probe with barrier  
 KLEMP2-2LPA/FFD ..... Connection to the potential equalisation in the  
 (Screw terminal) explosion hazardous area

Operation and indication circuit ..... in type of protection „Intrinsic Safety“ Ex ia IIC  
 (Terminals 5, 6, 7, 8 in the “i”-connection room resp. plug connection)  
 only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61 (IECEx PTB 06.0048)  
 The interconnection of the both intrinsically safe circuits was taken into account.  
 maximum values of the connection cable:  
 C<sub>0</sub> = 2.4 µF  
 L<sub>0</sub> = 160 µH

Operation and indication module circuit ..... in type of protection „Intrinsic Safety“ Ex ia IIC  
 (Spring contacts in the “i”-connection room) only for connection to the VEGA operation and indication module (Plicscom)

Communication circuit ..... in type of protection „Intrinsic Safety“ Ex ia IIC  
 (I<sup>2</sup>C bus in the “i”-connection room) only for connection to the intrinsically safe signal circuit of the VEGA interface converter type VEGACONNECT

If

- the VEGA interface converter type VEGACONNECT and
  - the external VEGA indication unit type VEGADIS61 (IECEx PTB 06.0048)
- are connected, the following maximum values of the connection cable to the VEGADIS61 do result:

$$\begin{array}{rcl} C_o = & 2.8 & \mu\text{F} \\ L_o = & 100 & \mu\text{H} \end{array}$$

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

All intrinsically safe circuits of the capacitive measuring probe with built-in barrier KLEMP2-2LPA/FFD are galvanically connected with the earth potential (measuring circuit excluded)

Special conditions for safe use:

1. At the plastic parts of the capacitive measuring probes type VEGACAL CP6\*.DI\*\*\* P/F \*\*\*\* there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.
2. For zone 0/1 applications and at risks by pendulum or vibration the respective parts of the capacitive measuring probes type VEGACAL CP65.DI\*\*\* P/F \*\*\*\* and type VEGACAL CP66.DI\*\*\* P/F \*\*\*\* have to be secured effectively against these dangers. Observe manual of the manufacturer.
3. For zone 0/1 applications, at the metallic electrode parts of the capacitive measuring probes type VEGACAL CP6\*.DI\*\*\* P/F \*\*\*\* made of light metal there is a danger of ignition by impact or friction. Observe manual of the manufacturer.
4. For zone 0/1 applications the medium tangent materials have to be resistant to the media.
5. The PA terminal of the capacitive measuring probes (internal or external screw terminal) has to be connected with the potential equalization of the explosion hazardous area.
6. The flameproof terminal box (Ex-d connection room) of this equipment must be provided with cable entries and filler plugs resp. conduits which are certified according to IEC 60 079-0 and IEC 60 079-1.
7. The connection cables, the cable entries and filler plugs resp. the conduits have to be suitable for the lowest ambient temperature.



# IECEX Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEX Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: **IECEX TUN 05.0019X** Issue No.: **1**

Status: **Current**

Date of Issue: **2006-11-07** Page 1 of 6

Applicant: **VEGA Grieshaber KG**  
Am Hohenstein 13  
77761 Schiltach  
Germany

Electrical Apparatus: **Capacitive Measuring Probe type VEGACAL CL6\*.DI\*\*P/FD\***  
Optional accessory: **-**

Type of Protection: **Flameproof Enclosures and Intrinsic Safety**

Marking: **Ex d ia IIC T6**

Approved for issue on behalf of the IECEX  
Certification Body:

Karl-Heinz Schwedt

Position:

Head of IECEX CB

Signature:  
(for printed version)

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the Official IECEX Website.

Certificate issued by:

**TÜV NORD CERT GmbH & Co.**  
**KG**

Am TÜV1  
D-30519 Hannover  
Germany



**TUV NORD**



# IECEX Certificate of Conformity

Certificate No.: **IECEX TUN 05.0019X**

Date of Issue: **2006-11-07**

Issue No.: 1

Page 2 of 6

Manufacturer: **VEGA Grieshaber KG**  
Am Hohenstein 13  
77761 Schiltach  
Germany

Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacture's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

<b>IEC 60079-0 : 2004</b> Edition: 4.0	Electrical apparatus for explosive gas atmospheres - Part 0: General requirements
<b>IEC 60079-1 : 2003</b> Edition: 5	Electrical apparatus for explosive gas atmospheres - Part 1: Flameproof enclosure 'd'
<b>IEC 60079-11 : 1999</b> Edition: 4	Electrical apparatus for explosive gas atmospheres - Part 11: Intrinsic safety 'i'

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

#### TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

IECEX ATR:  
**DE/TUN/05/551830**  
**DE/TUN/05/552076-1**

File Reference:  
**05YEX551830**  
**05YEX552076-1**



# IECEX Certificate of Conformity

Certificate No.: **IECEX TUN 05.0019X**

Date of Issue: **2006-11-07**

Issue No.: **1**

Page **3** of **6**

## Schedule

### EQUIPMENT:

*Equipment and systems covered by this certificate are as follows:*

The capacitive measuring probes type VEGACAL CL6\*.DI\*\*P/FD\* are used

for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

The capacitive measuring probes type VEGACAL CL6\*.DI\*\*P/FD\* consist

of an electronic housing for the barriers with an Ex-d connection room,

an Ex-i connection room with inserted measuring electronics,

a process adapting element and a measuring sensor.

Mechanical execution of the capacitive measuring probes:

type	electrodes
CL62.D **P/FD*	partly insulated electrode, optionally with screening tube or concentric tube
CL63.D **P/FD*	fully insulated electrode, optionally plated
CL64.D **P/FD*	fully insulated electrode, optionally with screening tube, concentric tube or plated
CL65.D **P/FD*	partly insulated cable electrode optionally with additionally insulated cable
CL66.D **P/FD*	fully insulated cable electrode

### CONDITIONS OF CERTIFICATION: YES as shown below:

1. At the plastic parts of the capacitive measuring probes type

VEGACALP CL6\*.CI\*\*P/FD\* there is a danger of ignition by electrostatic discharge.  
Observe manual of the manufacturer and warning label.

2. The flameproof terminal box (Ex-d connection room) of this equipment must be provided with cable entries and filler plugs resp. conduits which are certified according to IEC 60 079-0 and IEC 60 079-1.

3. The connection cables, the cable entries and filler plugs resp. the conduits have to be suitable for the lowest ambient temperature.





# IECEX Certificate of Conformity

Certificate No.: **IECEX TUN 05.0019X**

Date of Issue: **2006-11-07**

Issue No.: **1**

Page 4 of 6

## EQUIPMENT(continued):

The permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

temperature class	ambient temperature range on the electronics/housing	medium temperature range for electrodes with PE/PA-insulation	medium temperature range for other electrodes
T6	- 40°C... + 47°C	- 40°C... + 80°C	-50°C ... +85 °C
T5	- 40°C... + 60°C	- 40°C... + 80°C	-50°C ... +100 °C
T4	- 40°C... + 60°C	- 40°C... + 80°C	-50°C ... +135 °C
T3*, T2*, T1*	- 40°C... + 60°C	- 40°C... + 80°C	-50°C ... +150 °C

\* with temperature adapter for medium temperatures > 150°C ... 200°C

If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.

### Electrical data

Supply and signal circuit  
(Terminals K1/1, K1/2;  
Ex-d connection room)

U = 9 ... 36 V d. c.  
U<sub>m</sub> = 253 V a. c.

Operation and indication circuit  
(Terminals 5, 6, 7, 8 resp. plug  
connection in the "I"-connection  
room)

in type of protection „Intrinsic Safety “ Ex ia IIC  
only for connection to the intrinsically safe circuit of the belonging  
external VEGA indication unit type VEGADIS61  
The interconnection of the both intrinsically safe circuits was taken  
into account.  
maximum values of the connection cable:  
C<sub>0</sub> = 2,4 μF  
L<sub>0</sub> = 160 μH

Operation and indication module  
circuit  
(Spring contacts in the "I"-connection  
room)

in type of protection „Intrinsic Safety“ Ex ia IIC  
only for connection to the VEGA operation and indication module  
(Plicscom)



# IECEX Certificate of Conformity

Certificate No.: **IECEX TUN 05.0019X**

Date of Issue: **2006-11-07**

Issue No.: 1

Page 5 of 6

**DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):**

See annexe



# IECEX Certificate of Conformity

Certificate No.: **IECEX TUN 05.0019X**

Date of Issue: **2006-11-07**

Issue No.: **1**

Page **6** of **6**

## Additional information:

Communication circuit (I<sup>2</sup>C bus in the "I"-connection room) in type of protection „Intrinsic Safety“ Ex ia IIC only for connection to the intrinsically safe signal circuit of the VEGA interface converter type VEGACONNECT3

The VEGA interface converter may only be operated together with the capacitive measuring probe, if no explosion hazardous atmosphere exists.

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

All intrinsically safe circuits of the capacitive measuring probes with built-in barrier KLEMP2-2LPAD are safe galvanically separated from the non intrinsically safe supply and signal circuit and the parts which can be earthed.

IECEx ATR:	File reference:
DE/TUN/ExTR06.0042/01	06 TUN 553280
IECEx QAR:	File reference:
DE/QAR/TUN/06.0002/00	QAR/TUN/QAR06.0002/00

The capacitive measuring probes type VEGACAL CL6\*.DI\*\*P/FD\*\* are used for monitoring or control of filling levels in explosion hazardous areas.  
 The measuring media are allowed to be combustible liquids, gases, mists or vapours.

The changes refer to the mechanical and electrical construction of the measuring probes as well as to the electrical data.

Mechanical execution of the measuring probes

Type	Electrodes
CL62.DI**P/FD**	partly insulated electrode, optionally with screening tube or concentric tube
CL63.DI**P/FD**	fully insulated electrode, optionally plated
CL64.DI**P/FD**	fully insulated electrode, optionally with screening tube, concentric tube or plated
CL65.DI**P/FD**	partly insulated cable electrode optionally with additionally insulated cable
CL66.DI**P/FD**	fully insulated cable electrode
CL69.DI**P/FD**	fully insulated 2-rod electrode

Electrical data

Supply and signal circuit ..... U = 16 ... 32 V d. c.  
 (Terminals K1[+], K2[-]; U<sub>m</sub> = 253 V a. c.  
 Ex-d connection room)

PA terminal ..... Connection to the potential equalisation in the explosion hazardous area

Operation and indication circuit ..... in type of protection „Intrinsic Safety“ Ex ia IIC  
 (Terminals 5, 6, 7, 8

resp.  
 plug connection  
 in the "i" connection room)

only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61 (IECEx PTB 06.0048)  
 The interconnection of the both intrinsically safe circuits was taken into account.  
 maximum values of the connection cable:  
 C<sub>o</sub> = 2.4 µF  
 L<sub>o</sub> = 160 µH

Communication circuit ..... in type of protection „Intrinsic Safety“ Ex ia IIC  
(I<sup>2</sup>C bus in the “i” connection room)

only for connection to the intrinsically safe signal circuit  
of the VEGA interface converter type VEGACONNECT3

If

- the VEGA interface converter type VEGACONNECT3 and
  - the external VEGA indication unit type VEGADIS61 (IECEx PTB 06.0048)
- are connected, the following maximum values of the connection cable to the VEGADIS61 do result:

$$C_o = 2.8 \mu F$$
$$L_o = 100 \mu H$$

All other details as well as the “Special conditions for safe” use apply unchanged for this supplement.

IECEX ATR:	File reference:
DE/TUN/ExTR06.0042/01	06 TUN 553280
IECEX QAR:	File reference:
DE/QAR/TUN/06.0002/00	QAR/TUN/QAR06.0002/00

The capacitive measuring probes type VEGACAL CL6\*.DI\*\*P/FD\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

The changes refer to the mechanical and electrical construction of the measuring probes as well as to the electrical data.

Mechanical execution of the measuring probes

Type	Electrodes
CL62.DI**P/FD**	partly insulated electrode, optionally with screening tube or concentric tube
CL63.DI**P/FD**	fully insulated electrode, optionally plated
CL64.DI**P/FD**	fully insulated electrode, optionally with screening tube, concentric tube or plated
CL65.DI**P/FD**	partly insulated cable electrode optionally with additionally insulated cable
CL66.DI**P/FD**	fully insulated cable electrode
CL69.DI**P/FD**	fully insulated 2-rod electrode

Electrical data

Supply and signal circuit ..... U = 16... 32V d. c.  
 (Terminals KI1[+], KI2[-]; U<sub>m</sub> = 253 V a. c.  
 Ex-d connection room)

PA terminal ..... Connection to the potential equalisation in the explosion hazardous area

Operation and indication circuit ..... in type of protection „Intrinsic Safety“ Ex ia IIC  
 (Terminals 5, 6, 7, 8

resp.

plug connection

in the “I” connection room)

only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61

(IECEX PTB 06.0048)

The interconnection of the both intrinsically safe circuits was taken into account.

maximum values of the connection cable:

C<sub>0</sub> = 2.4 µF

L<sub>0</sub> = 160 µH

Communication circuit ..... in type of protection „Intrinsic Safety“ Ex ia IIC  
(I<sup>2</sup>C bus in the “I” connection room)

only for connection to the intrinsically safe signal circuit  
of the VEGA interface converter type VEGACONNECT3

If

- the VEGA interface converter type VEGACONNECT3 and
  - the external VEGA indication unit type VEGADIS61 (IECEx PTB 06.0048)
- are connected, the following maximum values of the connection cable to the VEGADIS61 do result:

$$C_o = 2.8 \mu\text{F}$$
$$L_o = 100 \mu\text{H}$$

All other details as well as the “Special conditions for safe” use apply unchanged for this supplement.

