

The manufacturer may use the mark:



Revision 2.0 February 24, 2015



Certificate / Certificat Zertifikat / 合格証

VEGA 100981C P0011 C001

exida hereby confirms that the:

VEGAVIB / VEGAWAVE 60 Level Switch Output C, R,T, N, Z

VEGA Grieshaber KG Schiltach - Germany

Has been assessed per the relevant requirements of:

IEC 61508: 2000 Parts 1-7

and meets requirements providing a level of integrity to:

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type B Element

SIL 2 @ HFT = 0; SIL 3 @ HFT = 1; Route 1_H

PFD_{AVG} and Architecture Constraints must be verified for each application

Safety Function:

The VEGAVIB / VEGAWAVE 60 will de-energize its output (C,R, T & N) or set current (Z) to fail-safe output when the level goes above (or below) the trip point within the stated safety accuracy.

Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.



Evaluating Assessor

Certifying Assessor

Certificate / Certificat / Zertifikat / 合格証

VEGA 100981C P0011 C001

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type B Element

SIL 2 @ HFT = 0; SIL 3 @ HFT = 1; Route 1_H

PFD_{AVG} and Architecture Constraints must be verified for each application

Systematic Capability:

The Product has met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element.

Versions:

See listing in the assessment report

IEC 61508 Failure Rates

Fail-Safe state	$\lambda_{ extsf{SD}}$	λ_{SU}	λ_{DD}	λ_{DU}
Out De-energized	0	506	124	41
Out De-energized	0	481	135	56
Out De-energized	0	586	124	27
Out De-energized	0	565	135	37
Out De-energized	0	487	124	30
Out De-energized	0	466	135	40
Out < 1.0 mA	12	160	390	47
Out < 1.0 mA	36	155	366	52
Out > 12.5 mA	49	387	163	18
Out < 11.5 mA	39	352	182	43
	Out De-energized Out < 1.0 mA Out < 1.0 mA Out > 12.5 mA	Out De-energized 0 Out < 1.0 mA	Out De-energized 0 506 Out De-energized 0 481 Out De-energized 0 586 Out De-energized 0 565 Out De-energized 0 487 Out De-energized 0 466 Out < 1.0 mA	Out De-energized 0 506 124 Out De-energized 0 481 135 Out De-energized 0 586 124 Out De-energized 0 565 135 Out De-energized 0 487 124 Out De-energized 0 466 135 Out < 1.0 mA

All failure rates are given in FIT (failures / 10⁹ hours)

SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFD_{AVG} considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

Assessment Report: VEGA 03/05-08 R005 V3R2

Safety Manuals: VEGAVIB / VEGAWAVE 60:

C: 32002 / 32363 R: 32003 / 32364 T: 32004 / 32365

N: 32005 / 32366 Z: 32006 / 32367

VEGAVIB / VEGAWAVE 60 Level Switch



64 N Main St Sellersville, PA 18960

T-002, V3R8

Page 2 of 2