

## Manufacturer Information

Software and hardware changes (according to NAMUR recommendation NE 53)

### 1. Type of instrument

1. Field device
  2. Signal processing instrument  
 3. Display/adjustment system
  4. Adjustment software

**Manufacturer:** VEGA Grieshaber  
KG

**Instr.:** VEGADIF 85

**Type**  
: Profibus PA

### 2. Software

Previous software version: 

	1

 . 

	2

 . 

	1

 from November 2018

New software version: 

	1

 . 

	2

 . 

	2

 from June 2020

Description of the modification in comparison with the predecessor version:

- Access rights adapted to requirements for profile 3.02:

For detailed information see overview of the versions in the download area under [www.vega.com/downloads](http://www.vega.com/downloads).

### 3. Hardware

Previous hardware version: 

	1

 . 

	0

 . 

	0

 from July 2018

New hardware version: 


 . 


 . 


 from \_\_\_\_\_

Description of the modification in comparison with the predecessor version:

- None

For detailed information see overview of the versions in the download area under [www.vega.com/downloads](http://www.vega.com/downloads).

### 4. Software compatibility

Is a software update necessary?

- No  
 Yes, reason:

Is downward compatibility given after installation of the new software?

- Yes  
 No, description:

How can the software update be carried out? (description of the procedure)

See operating instructions, chapter "Software update"

## 4. Operating instructions

Was the operating instructions changed due to the software/hardware modification?

Yes,

Instrument type	New instruction no.	Date

No,

Instrument type	Previous instruction no.	Date
VEGADIF 85	53569	2019-08-19

## 5. Price

Did the price change?

No

Yes

Previous list price of the instrument: 1298 ... 1800 €

New list price of the instrument: \_\_\_\_\_ €

Price for an update (without installation): \_\_\_\_\_ €

2020-06-26  
Date

*J. V. Thomas*  
Signature