



**Government of India**  
**Ministry of Commerce & Industry**  
**Petroleum & Explosives Safety Organisation (PESO)**  
**5th Floor, A-Block, CGO Complex, Seminary Hills,**  
**Nagpur - 440006**

E-mail : [explosives@explosives.gov.in](mailto:explosives@explosives.gov.in)  
 Phone/Fax No : 0712 -2510248, Fax-2510577

**Approval No : A/P/HQ/MH/104/6499 (P479231)**

**Dated : 28/07/2020**

To,  
**M/s. VEGA Grieshaber KG,**  
**AM HOHENSTEIN 113 ,Schiltach**  
**77761**  
**GERMANY**

**Sub :** Approval of Flame Proof Type Adjustment And Indication Unit. under Petroleum Rules 2002- Regarding.

Sir(s),  
 Please refer to your letter No. **OIN520348** dated **09/07/2020** on the subject.

The following Ex electrical equipment(s) manufactured by you according to **IEC 60079-0 : 2011, IEC 60079-1 : 2014**, standards and covered under **DEKRA EXAM GmbH** Test reports mentioned below is/are approved for use in **Zone 1** of Gas **IIC** hazardous areas coming under the the Petroleum Rules, 2002 administered by this Organization.

Sr. No	Description	Safety Protection	Equipment reference Number	Test Agency			Drawing no
				Name	Certificate No.	Certificate Date	
1	Adjustment and indication unit with integrated adjustment and indicating module type VEGADIS DIS81(*).IE *****	Ex db IIC T6 Gb	<b>P479231/1</b>	DEKRA EXAM GmbH	IECEX BVS 13.0069 Issue No 1	11/09/2017	ZT41585 Rev 3

This Approval is granted subject to observance of the following conditions:-

- 1)The design and construction of the equipment shall be strictly in accordance with description, condition and drawings as mentioned in the DEKRA EXAM GmbH Test Reports referred to above.
  - 2)The equipment shall be used only with approved type of accessories and associated apparatus.
  - 3)Each equipment shall be marked either by raised lettering cast integrally or by plate attached permanently to the main structure to indicate conspicuously:-
    - (a) Name of the manufacturer
    - (b) Name and number by which the equipment is identified.
    - (c) Number & date of the test report of the DEKRA EXAM GmbH applicable to the equipment.
    - (d) Equipment reference number of this letter by which use of apparatus is approved.
    - (e) Protection level.
  - 4) A certificate to the effect that the equipment has been manufactured strictly in accordance with the drawing referred to in the DEKRA EXAM GmbH Test report and is identical with the one tested and certified at DEKRA EXAM GmbH shall be furnished with each equipment.
  - 5) The customer shall be supplied with a copy of this letter, an extract of the conditions and maintenance schedule, if recommended by DEKRA EXAM GmbH in their test reports and copy of instructions booklet detailing operation maintenance of the equipment so as to maintain its Flame Proof characteristics.
- After sales service and maintenance of subject equipment shall be looked after by your representative M/s.



Vega India Level & Pressure Measurement Private Limited, PLOT NO. 1, GAT NO.181,VILLAGE FULGAON TAL. HAVELI PLOT NO. 1, Village : FULGAON, City : Haveli, Taluka / Tahsil : Haveli, District : PUNE State : Maharashtra Pincode : 412216

This approval also covers the permissible variations as approved under the DEKRA EXAM GmbH test reports referred above. This approval is liable to be cancelled if any of the conditions of the approval is violated or not complied with . The approval may also be amended or withdrawn at any time, if considered necessary in the interest of safety.

The field performance report from actual users/your customers of the subject equipment may please be collected and furnished to this office for verification and record on annual basis.

The Approval is Valid upto **31/12/2024**

Yours faithfully,

**(R.A.GUJAR)**  
**Dy. Chief Controller of Explosives**  
**For Chief Controller of Explosives**  
**Nagpur**

Copy to :

1. Jt. Chief Controller of Explosives, West Circle, MUMBAI
2. M/s. Vega India Level & Pressure Measurement Private Limited,PLOT NO. 1, GAT NO.181,VILLAGE FULGAON TAL. HAVELI PLOT NO. 1, Village : FULGAON, City : Haveli, Taluka / Tahsil : Haveli, District : PUNE State : Maharashtra Pincode : 412216

**for Chief Controller of Explosives**  
**Nagpur**

(For more information regarding status,fees and other details please visit our website <http://peso.gov.in>)

**This is System Generated document. Signature is not required.**

**Note:- Please submit the revalidation application one month before the date of Expiry of approval otherwise approval will be treated as cancelled and a fresh application for approval will be considered for the approval.**

**Disclaimer : This page gives the latest action taken by this organization on your application. This page is made available for the information of concerned applicant/licensee only. For documentary purposes, only the original documents issued under the seal and signature of the respective offices of Petroleum & Explosives Safety Organization shall be valid. All efforts have been made to secure this information. However, PESO will not be responsible for any misuse of the information by unauthorized persons including the hackers.**



**Government of India**  
**Ministry of Commerce & Industry**  
**Petroleum & Explosives Safety Organisation (PESO)**  
**5th Floor, A-Block, CGO Complex, Seminary Hills,**  
**Nagpur - 440006**

E-mail : [explosives@explosives.gov.in](mailto:explosives@explosives.gov.in)  
 Phone/Fax No : 0712 -2510248, Fax-2510577

**Approval No : A/P/HQ/MH/104/6500 (P479234)**

**Dated : 28/07/2020**

To,  
 M/s. VEGA Americas Inc.,  
 4241 ALLENDORF DRIVE CINCINNATI OHIO ,Cincinnati  
 45209  
 U.S.A

**Sub :** Approval of Flame Proof Type Adjustment And Indication Unit under Petroleum Rules 2002- Regarding.

Sir(s),  
 Please refer to your letter No. **OIN521902** dated **09/07/2020** on the subject.

The following Ex electrical equipment(s) manufactured by you according to **IEC 60079-0 : 2011, IEC 60079-1 : 2014-06**, standards and covered under **DEKRA EXAM GmbH** Test reports mentioned below is/are approved for use in **Zone 1** of Gas **IIC** hazardous areas coming under the the Petroleum Rules, 2002 administered by this Organization.

Sr. No	Description	Safety Protection	Equipment reference Number	Test Agency			Drawing no
				Name	Certificate No.	Certificate Date	
1	Adjustment and indication unit with integrated adjustment and indicating module type VEGADIS DIS81(*).IE *****	Ex db IIC T6 Gb	<b>P479234/1</b>	DEKRA EXAM GmbH	IECEX BVS 13.0069 Issue No 1	11/09/2017	ZT41585 Rev 3

This Approval is granted subject to observance of the following conditions:-

- 1)The design and construction of the equipment shall be strictly in accordance with description, condition and drawings as mentioned in the DEKRA EXAM GmbH Test Reports referred to above.
- 2)The equipment shall be used only with approved type of accessories and associated apparatus.
- 3)Each equipment shall be marked either by raised lettering cast integrally or by plate attached permanently to the main structure to indicate conspicuously:-
  - (a) Name of the manufacturer
  - (b) Name and number by which the equipment is identified.
  - (c) Number & date of the test report of the DEKRA EXAM GmbH applicable to the equipment.
  - (d) Equipment reference number of this letter by which use of apparatus is approved.
  - (e) Protection level.
- 4) A certificate to the effect that the equipment has been manufactured strictly in accordance with the drawing referred to in the DEKRA EXAM GmbH Test report and is identical with the one tested and certified at DEKRA EXAM GmbH shall be furnished with each equipment.
- 5) The customer shall be supplied with a copy of this letter, an extract of the conditions and maintenance schedule, if any, recommended by DEKRA EXAM GmbH in their test reports and copy of instructions booklet detailing operation & maintenance of the equipment so as to maintain its Flame Proof characteristics.
- 6) The After sales service and maintenance of subject equipment shall be looked after by your representative M/s.

Vega India Level & Pressure Measurement Private Limited, PLOT NO. 1, GAT NO.181,VILLAGE FULGAON TAL. HAVELI, Village : FULGAON, City : Haveli, Taluka / Tahsil : Haveli, District : PUNE State : Maharashtra Pincode : 412216 Phone : 20-67314000

This approval also covers the permissible variations as approved under the DEKRA EXAM GmbH test reports referred above. This approval is liable to be cancelled if any of the conditions of the approval is violated or not complied with . The approval may also be amended or withdrawn at any time, if considered necessary in the interest of safety.

The field performance report from actual users/your customers of the subject equipment may please be collected and furnished to this office for verification and record on annual basis.

The Approval is Valid upto **31/12/2024**

Yours faithfully,

**(R.A.GUJAR)**  
**Dy. Chief Controller of Explosives**  
**For Chief Controller of Explosives**  
**Nagpur**

Copy to :

1. Jt. Chief Controller of Explosives, West Circle, MUMBAI
2. M/s. Vega India Level & Pressure Measurement Private Limited,PLOT NO. 1, GAT NO.181,VILLAGE FULGAON TAL. HAVELI, Village : FULGAON, City : Haveli, Taluka / Tahsil : Haveli, District : PUNE State : Maharashtra Pincode : 412216 Phone : 20-67314000

**for Chief Controller of Explosives**  
**Nagpur**

(For more information regarding status,fees and other details please visit our website <http://peso.gov.in>)

**This is System Generated document. Signature is not required.**

**Note:- Please submit the revalidation application one month before the date of Expiry of approval otherwise approval will be treated as cancelled and a fresh application for approval will be considered for the approval.**

**Disclaimer : This page gives the latest action taken by this organization on your application. This page is made available for the information of concerned applicant/licensee only. For documentary purposes, only the original documents issued under the seal and signature of the respective offices of Petroleum & Explosives Safety Organization shall be valid. All efforts have been made to secure this information. However, PESO will not be responsible for any misuse of the information by unauthorized persons including the hackers.**