

CERTIFICATE OF COMPLIANCE

Certificate Number E490658
Report Reference E490658-20210709
Date 2021-July-16

Issued to: VEGA Grieshaber KG
Am Hohenstein 113
Schiltach 77761 DE

**This is to certify that
representative samples of**

PROGRAMMABLE CONTROLLERS FOR USE IN
HAZARDOUS LOCATIONS
PROGRAMMABLE CONTROLLERS FOR USE IN ZONE
CLASSIFIED HAZARDOUS LOCATIONS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: See Addendum Page for Standard(s)

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations>.



CERTIFICATE OF COMPLIANCE

Certificate Number E490658
Report Reference E490658-20210709
Date 2021-July-16

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

USL - Associated Apparatus for use in Unclassified Locations,
[AEx ia Ga] IIC, [AEx ia Da] IIIC.

CNL - Associated Apparatus for use in Unclassified Locations,
[Ex ia Ga] IIC X, [Ex ia Da] IIIC X.

Programmable, industrial controller model/Cat. Nos. VEGAMET 14; followed by 1 or 2, providing intrinsically safe circuits for use in Hazardous Locations Class I, Division 1, Groups A, B, C and D; Class II, Division 1, Groups E, F and G; Class III, Division 1; and Class I, Zone 0, Group IIC and Zone 20, Group IIIC when installed in accordance with Control Drawing 63696.

Standard(s) for Safety:

| Standard | Title | Edition or Publication Date | Revision Date |
|----------------------------|---|-----------------------------|---------------|
| UL 913 | Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III, Division 1, Hazardous (Classified) Locations | Ed. 8 | 12/06/2019 |
| UL 60079-0 | Explosive Atmospheres - Part 0: Equipment - General Requirements | Ed. 7 | 04/15/2020 |
| UL 60079-11 | EXPLOSIVE ATMOSPHERES - PART 11: EQUIPMENT PROTECTION BY INTRINSIC SAFETY "I" | Ed. 6 | 09/14/2018 |
| CAN/CSA C22.2 No. 60079-0 | Electrical Apparatus for Explosive Gas Atmospheres - Part 0: General Requirements | Ed. 4 | 02/2019 |
| CAN/CSA C22.2 No. 60079-11 | Explosive Atmospheres - Part 11: Equipment Protection by Intrinsic Safety "I" | Ed. 2 | 02/2014 |



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations>.



