

Manufacturer information week 02/2023

Software and hardware changes (according to NAMUR recommendation NE 53)

1. Type of instrument

- Field device
 Display/adjustment system
 Signal processing instrument
 Adjustment software

Manufacturer: VEGA Grieshaber
KG

Instr.: VEGAPOINT 24

Type
: 3-wire with IO-Link

2. Software

Previous software version:

	1	.		0	.		0
	1	.		1	.		0

Dated April 2021

New software version:

	1	.		1	.		0
	1	.		1	.		0

Dated January 2023

Description of the modification in comparison with the predecessor version:

- Hysteresis of the switching outputs did not work if the switch-on or switch-off delay was exactly 0 seconds
- Software update did not work with simultaneous IO-Link communication
- With datastorage IO-Link, the switching points were not written into the sensor
- The Upload Flag was not set correctly with IO-Link
- During the start phase, sensors without Bluetooth are flashing blue
- Default values are stored for customised live adjustment

For detailed information see overview of the versions in the download area under www.vega.com/downloads.

3. Hardware I

Previous hardware version:

	1	.		0	.		0
	1	.		1	.		0

Dated April 2021

New hardware version:

	1	.		1	.		0
	1	.		1	.		0

Dated September 2022

Description of the modification in comparison with the predecessor version:

- IO-Link communication optimised with slow reduction of the supply voltage

For detailed information see overview of the versions in the download area under www.vega.com/downloads.

4. Software compatibility

Is a software update necessary?

- No
 Yes, reason:

Is downward compatibility given after installation of the new software?

- Yes
 No, description:

How can the software update be carried out? (description of the procedure)

The implementation of the software update is described in the operating instructions.

4. Operating instructions

Was the operating instructions changed due to the software/hardware modification?

Yes,

Instrument type	New instruction no.	Dated

No,

Instrument type	Previous instruction no.	Dated
VEGAPOINT 24	64725-DE-210701	2021-07-01

5. Price

Did the price change?

No

Yes

Previous list price of the instrument: _____ €

New list price of the instrument: _____ €

Price for an update (without installation): _____ €

2023-01-09

Date

J. V. Thomas
Signature