



# IECEx Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: **IECEx TUN 04.0022X** issue No.: **3**

Status: **Current**

Date of Issue: **2009-02-03** Page 1 of 4

Certificate history:

Issue No. 3 (2009-2-3)  
Issue No. 2 (2008-8-4)  
Issue No. 1 (2007-7-11)  
Issue No. 0 (2004-9-6)

Applicant: **VEGA Grieshaber KG**  
Am Hohenstein 113  
77761 Schiltach  
Germany  
**Germany**

Electrical Apparatus: **Capacitive Level Switch**  
Optional accessory: **Type: VEGACAP CP6\*.CI\*\*\*Z\*\*\***

Type of Protection: **Intrinsic safety**

Marking: **Zone 0, 0/1 Ex ia IIC T6**

Approved for issue on behalf of the IECEx  
Certification Body: **Karl-Heinz Schwedt**

Position: **Head of the IECExCB**

Signature:  
(for printed version)

Date:

2009-02-03

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

**TÜV NORD CERT GmbH**  
Hanover Office  
Am TÜV 1  
30519 Hannover  
Germany





# IECEX Certificate of Conformity

Certificate No.: IECEX TUN 04.0022X

Date of Issue: 2009-02-03

Issue No.: 3

Page 2 of 4

Manufacturer: **VEGA Grieshaber KG**  
Am Hohenstein 113  
77761 Schiltach  
Germany  
Germany

Manufacturing location(s):

**VEGA Grieshaber KG**  
Am Hohenstein 113  
77761 Schiltach  
Germany

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

<b>IEC 60079-0 : 2004</b> Edition: 4.0	Electrical apparatus for explosive gas atmospheres - Part 0: General requirements
<b>IEC 60079-11 : 2006</b> Edition: 5	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
<b>IEC 60079-26 : 2004</b> Edition: 1	Electrical apparatus for explosive gas atmospheres - Part 26: Construction, test and marking of Group II Zone 0 electrical apparatus

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

#### TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

IECEX ATR:  
EXTR DE/TUN/08.0023/01

File Reference:  
09 204 555126



# IECEx Certificate of Conformity

Certificate No.: IECEx TUN 04.0022X

Date of Issue: 2009-02-03

Issue No.: 3

Page 3 of 4

## Schedule

### EQUIPMENT:

*Equipment and systems covered by this certificate are as follows:*

The capacitive level switches type VEGACAP CP6\*.CI\*\*Z\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

Mechanical execution of the capacitive level switches:

type	electrodes
CP62.CI**Z**	partly insulated electrode, optionally with screening tube or concentric tube
CP63.CI**Z**	fully insulated electrode, optionally plated
CP64.CI**Z**	fully insulated electrode, optionally with screening tube, concentric tube or plated
CP65.CI**Z**	partly insulated cable electrode
CP66.CI**Z**	insulated cable electrode

CONDITIONS OF CERTIFICATION: YES as shown below:

At the plastic parts of the capacitive level switches type VEGACAP CP6\*.CI\*\*Z\*\* there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.



# IECEx Certificate of Conformity

Certificate No.: IECEx TUN 04.0022X

Date of Issue: 2009-02-03

Issue No.: 3

Page 4 of 4

**DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):**

see annexe

Annexe: 3rd supplement\_COC\_VEGACAP CP6C\_Z\_TUN 04.0022X.pdf

IECEX ExTR:	File reference:
DE/TUN/ExTR08.0023/01	09 204 555126
IECEX QAR:	File reference:
DE/QAR/TUN/06.0002/00	QAR TUN 04.0002

The capacitive level switches type VEGACAP CP6\*.CI\*\*\*Z\*\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

The changes refer to the mounting of an additional printed circuit board for shielding and the modification of an internal plug connection.

All other details remain unchanged.



# IECEX Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: **IECEX TUN 04.0022X** Issue No.: **2**

Status: **Current**

Certificate history:  
Issue No. 2 (2008-8-4)  
Issue No. 1 (2007-7-11)  
Issue No. 0 (2004-9-6)

Date of Issue: **2008-08-04** Page 1 of 5

Applicant: **VEGA Grieshaber KG**  
Am Hohenstein 113  
77761 Schiltach  
Germany  
Germany

Electrical Apparatus: **Capacitive Level Switch**  
Optional accessory: **Type: VEGACAP CP6\*.CI\*\*Z\*\***

Type of Protection: **Intrinsic safety**

Marking: **Ex ia IIC T6**


Approved for issue on behalf of the IECEx  
Certification Body:

Karl-Heinz Schwedt

Position:

Head of the IECExCB

Signature:  
(for printed version)

  
4.8.2008

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

TÜV NORD CERT GmbH  
Hanover Office  
Am TÜV 1  
30519 Hannover  
Germany





# IECEX Certificate of Conformity

Certificate No.: IECEX TUN 04.0022X

Date of Issue: 2008-08-04

Issue No.: 2

Page 2 of 5

Manufacturer: **VEGA Grieshaber KG**  
Am Hohenstein 113  
77761 Schiltach  
Germany  
Germany

Manufacturing location(s):  
**VEGA Grieshaber KG**  
Am Hohenstein 113  
77761 Schiltach  
Germany

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

<b>IEC 60079-0 : 2004</b> Edition: 4.0	Electrical apparatus for explosive gas atmospheres - Part 0: General requirements
<b>IEC 60079-11 : 2006</b> Edition: 5	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "I"
<b>IEC 60079-26 : 2004</b> Edition: 1	Electrical apparatus for explosive gas atmospheres - Part 26: Construction, test and marking of Group II Zone 0 electrical apparatus

*This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

#### TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

IECEX ATR:  
**ExTR 08.0023/00**

File Reference:  
**08 204 554575**



# IECEx Certificate of Conformity

Certificate No.:

IECEx TUN 04.0022X

Date of Issue:

2008-08-04

Issue No.: 2

Page 3 of 5

## Schedule

### EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The capacitive level switches type VEGACAP CP6\*.CI\*\*Z\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

Mechanical execution of the capacitive level switches:

type	electrodes
CP62.CI**Z**	partly insulated electrode, optionally with screening tube or concentric tube
CP63.CI**Z**	fully insulated electrode, optionally plated
CP64.CI**Z**	fully insulated electrode, optionally with screening tube, concentric tube or plated
CP65.CI**Z**	partly insulated cable electrode
CP66.CI**Z**	insulated cable electrode

### CONDITIONS OF CERTIFICATION: YES as shown below:

At the plastic parts of the capacitive level switches type VEGACAP CP6\*.CI\*\*Z\*\* there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.





# IECEX Certificate of Conformity

Certificate No.:

IECEX TUN 04.0022X

Date of Issue:

2008-08-04

Issue No.: 2

Page 4 of 5

**DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):**

See annexe



# IECEX Certificate of Conformity

Certificate No.:

IECEX TUN 04.0022X

Date of Issue:

2008-08-04

Issue No.: 2

Page 5 of 5

**Additional information:**

see annexe

IECEx ExTR:	File reference:
DE/TUN/ExTR08.0023/00	08 204 554575
IECEx QAR:	File reference:
DE/QAR/TUN/06.0002/00	QAR TUN 04.0002

The capacitive level switches type VEGACAP CP6\*.CI\*\*\*Z\*\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

The changes refer to the type designation, the mechanical and electrical construction, the temperature range in the area of the electronics/of the medium, the special conditions for safe use and the marking.

The marking reads as follows: Zone 0, 0/1 Ex ia IIC Tx (see tables for temperature ranges).

Type designation and mechanical execution of the level switches:

Type	Electrodes
CP62.CI***Z***	partly insulated electrode, optionally with screening tube or concentric tube
CP63.CI***Z***	fully insulated electrode, optionally plated
CP64.CI***Z***	fully insulated electrode, optionally with screening tube, concentric tube or plated
CP65.CI***Z***	partly insulated cable electrode optionally with additionally insulated cable
CP66.CI***Z***	fully insulated cable electrode
CP69.CI***Z***	fully insulated 2-rod electrode

If the capacitive level switches are used in explosion hazardous areas of zone 0, the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

Temperature class	Ambient temperature range	Medium temperature range
T6	-20 °C ... +58 °C	-20°C ... +58 °C
T5, T4, T3, T2, T1	-20 °C ... +60 °C	-20°C ... +60 °C

The capacitive level switches are allowed to be operated in an explosion hazardous area of the zone 0, only if atmospheric conditions exist (pressure from 0.8 bar to 1.1 bar).

If no explosion hazardous atmospheres exist, the permissible operating temperatures and pressures have to be taken from the manufacturer's data (manual).

If the capacitive level switches are mounted in the partition wall between explosion hazardous areas of the zone 0 (electrode) and zone 1 (electronics), the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

Temperature class	Ambient temperature range	Medium temperature range
T6	-40 °C ... +58 °C	-20°C ... +60 °C
T5	-40 °C ... +73 °C	-20°C ... +60 °C
T4, T3, T2, T1	-40 °C ... +80 °C	-20°C ... +60 °C

The electrodes of the capacitive level switches are allowed to be operated in an explosion hazardous area of the zone 0, only if atmospheric conditions exist (pressure from 0.8 bar to 1.1 bar).

If no explosion hazardous atmospheres exist, the permissible operating temperatures and pressures have to be taken from the manufacturer's data (manual).

If the sensors of the capacitive level switches are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature at the electronics/housing must not exceed the values as mentioned in the a.m. table.

If the capacitive level switches are mounted in explosion hazardous areas of the zone 1, the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

temperature class	ambient temperature range	medium temperature range for electrodes with PE-insulation	medium temperature range for other electrodes
T6	- 40°C... + 58°C	- 40°C... + 80°C	-50°C ... +85 °C
T5	- 40°C... + 73°C	- 40°C... + 80°C	-50°C ... +100 °C
T4	- 40°C... + 80°C	- 40°C... + 80°C	-50°C ... +135 °C
T3*, T2*, T1*	- 40°C... + 80°C	- 40°C... + 80°C	-50°C ... +150 °C

\* with temperature adapter for medium temperatures > 150°C ... 200°C

If the sensors of the capacitive level switches are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.

Special conditions for safe use:

1. At the plastic parts of the capacitive level switches type VEGACAP CP6\*.CI\*\*\*Z\*\*\* there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.
2. For zone 0 applications, at the metallic parts of the capacitive level switches type VEGACAP CP6\*.CI\*\*\*Z\*\*\* made of light metal there is a danger of ignition by impact or friction. Observe manual of the manufacturer.
3. For zone 0 resp. zone 0/1 applications and at risks by pendulum or vibration the respective parts of the capacitive level switches type VEGACAP CP65.CI\*\*\*Z\*\*\* and type VEGACAP CP66.CI\*\*\*Z\*\*\* have to be secured effectively against these dangers. Observe manual of the manufacturer.

All other details remain unchanged.

IECEx ExTR:	File reference:
DE/TUN/ExTR08.0023/00	08 204 554575
IECEx QAR:	File reference:
DE/QAR/TUN/06.0002/00	QAR TUN 04.0002

The capacitive level switches type VEGACAP CP6\*.CI\*\*\*Z\*\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

The changes refer to the type designation, the mechanical and electrical construction, the temperature range in the area of the electronics/of the medium, the special conditions for safe use and the marking.

The marking reads as follows: Zone 0, 0/1 Ex ia IIC Tx (see tables for temperature ranges).

Type designation and mechanical execution of the level switches:

Type	Electrodes
CP62.CI***Z***	partly insulated electrode, optionally with screening tube or concentric tube
CP63.CI***Z***	fully insulated electrode, optionally plated
CP64.CI***Z***	fully insulated electrode, optionally with screening tube, concentric tube or plated
CP65.CI***Z***	partly insulated cable electrode optionally with additionally insulated cable
CP66.CI***Z***	fully insulated cable electrode
CP69.CI***Z***	fully insulated 2-rod electrode

If the capacitive level switches are used in explosion hazardous areas of zone 0, the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

Temperature class	Ambient temperature range	Medium temperature range
T6	-20 °C ... +58 °C	-20°C ... +58 °C
T5, T4, T3, T2, T1	-20 °C ... +60 °C	-20°C ... +60 °C

The capacitive level switches are allowed to be operated in an explosion hazardous area of the zone 0, only if atmospheric conditions exist (pressure from 0.8 bar to 1.1 bar).

If no explosion hazardous atmospheres exist, the permissible operating temperatures and pressures have to be taken from the manufacturer's data (manual).

If the capacitive level switches are mounted in the partition wall between explosion hazardous areas of the zone 0 (electrode) and zone 1 (electronics), the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

Temperature class	Ambient temperature range	Medium temperature range
T6	-40 °C ... +58 °C	-20°C ... +60 °C
T5	-40 °C ... +73 °C	-20°C ... +60 °C
T4, T3, T2, T1	-40 °C ... +80 °C	-20°C ... +60 °C

The electrodes of the capacitive level switches are allowed to be operated in an explosion hazardous area of the zone 0, only if atmospheric conditions exist (pressure from 0.8 bar to 1.1 bar).

If no explosion hazardous atmospheres exist, the permissible operating temperatures and pressures have to be taken from the manufacturer's data (manual).

If the sensors of the capacitive level switches are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature at the electronics/housing must not exceed the values as mentioned in the a.m. table.

If the capacitive level switches are mounted in explosion hazardous areas of the zone 1, the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

temperature class	ambient temperature range	medium temperature range for electrodes with PE-insulation	medium temperature range for other electrodes
T6	- 40°C... + 58°C	- 40°C... + 80°C	-50°C... +85 °C
T5	- 40°C... + 73°C	- 40°C... + 80°C	-50°C... +100 °C
T4	- 40°C... + 80°C	- 40°C... + 80°C	-50°C... +135 °C
T3*, T2*, T1*	- 40°C... + 80°C	- 40°C... + 80°C	-50°C... +150 °C

\* with temperature adapter for medium temperatures > 150°C... 200°C

If the sensors of the capacitive level switches are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.

Special conditions for safe use:

1. At the plastic parts of the capacitive level switches type VEGACAP CP6\*.CI\*\*\*Z\*\*\* there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.
2. For zone 0 applications, at the metallic parts of the capacitive level switches type VEGACAP CP6\*.CI\*\*\*Z\*\*\* made of light metal there is a danger of ignition by impact or friction. Observe manual of the manufacturer.
3. For zone 0 resp. zone 0/1 applications and at risks by pendulum or vibration the respective parts of the capacitive level switches type VEGACAP CP65.CI\*\*\*Z\*\*\* and type VEGACAP CP66.CI\*\*\*Z\*\*\* have to be secured effectively against these dangers. Observe manual of the manufacturer.

All other details remain unchanged.





# IECEX Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.:	IECEX TUN 04.0022X	issue No.:	1	History
Status:	Current			Issue No. 1 (2007-7-11) Issue No. 0 (2004-9-6)
Date of Issue:	2007-07-11		Page 1 of 5	
Applicant:	<b>VEGA Grieshaber KG</b> Am Hohenstein 113 77761 Schiltach Germany Germany			
Electrical Apparatus:	<b>Capacitive Level Switch</b>			
Optional accessory:	Type: VEGACAP CP6.CI**Z**			
Type of Protection:	Intrinsic safety			
Marking:	Ex ia IIC T6			
Approved for issue on behalf of the IECEx Certification Body:	Herbert Stürwold			
Position:	Head of the IECEx CB			
Signature: (for printed version)				
Date:	<u>11 07 2007</u>			

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

TÜV NORD CERT GmbH & Co. KG  
Am TÜV1  
D-30519 Hannover  
Germany





# IECEX Certificate of Conformity

Certificate No.: IECEX TUN 04.0022X

Date of Issue: 2007-07-11

Issue No.: 1

Page 2 of 5

Manufacturer: **VEGA Grieshaber KG**  
Am Hohenstein 113  
77761 Schiltach  
Germany  
Germany

Manufacturing location(s):

**VEGA Grieshaber KG**  
Am Hohenstein 113  
77761 Schiltach  
Germany

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacture's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEX Quality system requirements. This certificate is granted subject to the conditions as set out in IECEX Scheme Rules, IECEX 02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

**IEC 60079-0 : 2000** Electrical apparatus for explosive gas atmospheres - Part 0: General requirements

Edition: 3.1

**IEC 60079-11 : 1999** Electrical apparatus for explosive gas atmospheres - Part 11: Intrinsic safety 'i'

Edition: 4

*This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

#### TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

IECEX ATR:  
DE/TUN/07.0012/00

File Reference:  
07203553200



# IECEX Certificate of Conformity

Certificate No.: IECEX TUN 04.0022X

Date of Issue: 2007-07-11

Issue No.: 1

Page 3 of 5

## Schedule

### EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The capacitive level switches type VEGACAP CP6\*.CI\*\*Z\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

Mechanical execution of the capacitive level switches:

type	electrodes
CP62.CI**Z**	partly insulated electrode, optionally with screening tube or concentric tube
CP63.CI**Z**	fully insulated electrode, optionally plated
CP64.CI**Z**	fully insulated electrode, optionally with screening tube, concentric tube or plated
CP65.CI**Z**	partly insulated cable electrode
CP66.CI**Z**	insulated cable electrode

CONDITIONS OF CERTIFICATION: YES as shown below:

At the plastic parts of the capacitive level switches type VEGACAP CP6\*.CI\*\*Z\*\* there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.



# IECEX Certificate of Conformity

Certificate No.: IECEX TUN 04.0022X

Date of Issue: 2007-07-11

Issue No.: 1

Page 4 of 5

**DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):**

see annexe



# IECEx Certificate of Conformity

Certificate No.:

IECEx TUN 04.0022X

Date of Issue:

2007-07-11

Issue No. : 1

Page 5 of 5

**Additional information:**

see annexe

**Annexe:** 1st supplement\_COC\_VEGACAP CP6C\_Z\_TUN 04 0022X.pdf

IECEX TR:	File reference:
DE/TUN/ExTR07.0012/00	07203553200
IECEX QAR:	File reference:
DE/QAR/TUN/06.0002/00	QAR/TUN/QAR06.0002/00

The capacitive level switches type VEGACAP CP6\*.CI\*\*Z\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases or vapours.

The changes regarding refer to:

- the electronic insert
- the electrical data regarding the fixed cable tail for types VEGACAP CP6\*.CI\*\*Z3/4/5/9\*\*
- the mechanical design of the housings and the electrodes
- the new type VEGACAP CP69.CI\*\*Z\*\* with 2 rod electrode

Mechanical execution of the capacitive level switches:

type	electrodes
CP62.CI**Z**	partly insulated electrode, optionally with screening tube or concentric tube
CP63.CI**Z**	fully insulated electrode, optionally plated
CP64.CI**Z**	fully insulated electrode, optionally with screening tube, concentric tube or plated
CP65.CI**Z**	partly insulated cable electrode
CP66.CI**Z**	insulated cable electrode
CP69.CI**Z**	fully insulated 2-rod electrode

Supply and signal circuit ..... in type of protection „Intrinsic Safety“ Ex ia IIC  
(Terminals K11[+], K12[-] in the housing  
for the electronics resp., in the  
execution with the 2 cell housing, in the  
terminal housing)

only for connection to a certified intrinsically safe  
circuit

maximum values:

$$\begin{aligned}
 U_i &= 30 \text{ V} \\
 I_i &= 131 \text{ mA} \\
 P_i &= 983 \text{ mW}
 \end{aligned}$$

The effective internal capacitances and inductances are negligibly small.

Additionally, in the execution VEGACAP CP6\*.CI\*\*Z3/4/5/9\* the following values for  $L'$  and  $C'$  of the connection cable mounted fixed have to be observed:

$L'$	=	0.55 $\mu\text{H}/\text{m}$
$C'$ wire/wire	=	58 pF/m
$C'$ wires/shield	=	270 pF/m

The intrinsically safe signal circuit is safe galvanically separated from the parts which can be earthed.

All other details remain unchanged.

IECEx TR:	File reference:
DE/TUN/ExTR07.0012/00	07203553200
IECEx QAR:	File reference:
DE/QAR/TUN/06.0002/00	QAR/TUN/QAR06.0002/00

The capacitive level switches type VEGACAP CP6\*.CI\*\*Z\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases or vapours.

The changes regarding refer to:

- the electronic insert
- the electrical data regarding the fixed cable tail for types VEGACAP CP6\*.CI\*\*Z3/4/5/9\*\*
- the mechanical design of the housings and the electrodes
- the new type VEGACAP CP69.CI\*\*Z\*\* with 2 rod electrode

Mechanical execution of the capacitive level switches:

type	electrodes
CP62.CI**Z**	partly insulated electrode, optionally with screening tube or concentric tube
CP63.CI**Z**	fully insulated electrode, optionally plated
CP64.CI**Z**	fully insulated electrode, optionally with screening tube, concentric tube or plated
CP65.CI**Z**	partly insulated cable electrode
CP66.CI**Z**	insulated cable electrode
CP69.CI**Z**	fully insulated 2-rod electrode

Supply and signal circuit ..... in type of protection „Intrinsic Safety“ Ex ia IIC  
 (Terminals K1[+], K2[-] in the housing  
 for the electronics resp., in the  
 execution with the 2 cell housing, in the  
 terminal housing)

only for connection to a certified intrinsically safe  
 circuit

maximum values:

$$\begin{aligned}
 U_i &= 30 \text{ V} \\
 I_i &= 131 \text{ mA} \\
 P_i &= 983 \text{ mW}
 \end{aligned}$$



The effective internal capacitances and inductances are negligibly small.

Additionally, in the execution VEGACAP CP6\*.CI\*\*Z3/4/5/9\* the following values for  $L'$  and  $C'$  of the connection cable mounted fixed have to be observed:

$L'$	=	0.55 $\mu\text{H}/\text{m}$
$C'$ wire/wire	=	58 pF/m
$C'$ wires/shield	=	270 pF/m

The intrinsically safe signal circuit is safe galvanically separated from the parts which can be earthed.

All other details remain unchanged.

 <h2 style="text-align: center;">IECEx Certificate of Conformity</h2>	
<b>INTERNATIONAL ELECTROTECHNICAL COMMISSION</b> <b>IEC Certification Scheme for Explosive Atmospheres</b> <small>for rules and details of the IECEx Scheme visit <a href="http://www.iecex.com">www.iecex.com</a></small>	
Certificate No.:	IECEx TUN 04.0022X <span style="float: right;">Issue No.: 0</span>
Status:	<b>Current</b>
Date of Issue:	<b>2004-09-06</b> <span style="float: right;">Page 1 of 4</span>
Applicant:	<b>VEGA Grieshaber KG</b> Am Hohenstein 113 77761 Schiltach Germany <b>Germany</b>
Electrical Apparatus:	<b>Capacitive Level Switch</b>
Optional accessory:	Type: VEGACAP CP6:CI**Z**
Type of Protection:	<b>Intrinsic safety</b>
Marking:	<b>Ex Ia IIC T6</b>
Approved for issue on behalf of the IECEx	Herbert Stürwold
Certification Body:	
Position:	Head of the IECExCB
Signature: (for printed version)	_____
Date:	_____
<p>1. This certificate and schedule may only be reproduced in full.            2. This certificate is not transferable and remains the property of the issuing body.            3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.</p>	
Certificate issued by: <div style="display: flex; justify-content: space-between; align-items: center;"> <div style="text-align: center;"> <p><b>TÜV NORD CERT GmbH &amp; Co. KG</b> Am TÜV 1 D-30519 Hannover Germany</p> </div>  </div>	
 <h2 style="text-align: center;">IECEx Certificate of Conformity</h2>	
Certificate No.:	IECEx TUN 04.0022X <span style="float: right;">Issue No.: 0</span>
Date of Issue:	<b>2004-09-06</b> <span style="float: right;">Page 2 of 4</span>
Manufacturer:	<b>VEGA Grieshaber KG</b> Am Hohenstein 113 77761 Schiltach Germany <b>Germany</b>
Manufacturing location(s):	<b>VEGA Grieshaber KG</b> Am Hohenstein 113 77761 Schiltach Germany
<p>This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.</p>	
<p><b>STANDARDS:</b>            The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:</p>	
<b>IEC 60079-0 : 2000</b>	Electrical apparatus for explosive gas atmospheres - Part 0: General requirements Edition: 3.1
<b>IEC 60079-11 : 1999</b>	Electrical apparatus for explosive gas atmospheres - Part 11: Intrinsic safety † Edition: 4
<p><i>This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.</i></p>	
<p><b>TEST &amp; ASSESSMENT REPORTS:</b>            A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in</p>	
IECEx ATR: <b>DETUN04/551591</b>	File Reference: <b>04 YEX 551591</b>



type	electrodes
CP62.CI**Z**	partly insulated electrode, optionally with screening tube or concentric tube
CP63.CI**Z**	fully insulated electrode, optionally plated
CP64.CI**Z**	fully insulated electrode, optionally with screening tube, concentric tube or plated
CP65.CI**Z**	partly insulated cable electrode
CP66.CI**Z**	insulated cable electrode

**IECEx Certificate of Conformity**

Certificate No.: IECEx TUN 04.0022X  
 Date of Issue: 2004-09-06  
 Issue No.: 0  
 Page 3 of 4

**Schedule**

**EQUIPMENT:**  
 Equipment and systems covered by this certificate are as follows:

The capacitive level switches type VEGACAP CP6\*.CI\*\*Z\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

Mechanical execution of the capacitive level switches:

type	electrodes
CP62.CI**Z**	partly insulated electrode, optionally with screening tube or concentric tube
CP63.CI**Z**	fully insulated electrode, optionally plated
CP64.CI**Z**	fully insulated electrode, optionally with screening tube, concentric tube or plated
CP65.CI**Z**	partly insulated cable electrode
CP66.CI**Z**	insulated cable electrode

**CONDITIONS OF CERTIFICATION: YES as shown below:**

At the plastic parts of the capacitive level switches type VEGACAP CP6\*.CI\*\*Z\*\* there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.

**IECEx Certificate of Conformity**

Certificate No.: IECEx TUN 04.0022X  
 Date of Issue: 2004-09-06  
 Issue No.: 0  
 Page 4 of 4

**EQUIPMENT(continued):**

The permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

Temperature class	ambient temperature range	medium temperature range
T6	-40°C ... +58 °C	-50°C ... +65 °C
T5	-40°C ... +73 °C	-50°C ... +100 °C
T4	-40°C ... +80 °C	-50°C ... +135 °C
T3*, T2*, T1*	-40°C ... +80 °C	-50°C ... +200 °C

\* with temperature adapter for medium temperatures  $\geq 150^{\circ}\text{C}$

**Electrical data**

Supply and signal circuit ..... in type of protection „Intrinsic Safety“ EEx ia IIC  
 (Terminals K1[+], K2[-] in the only for connection to a certified intrinsically safe circuit  
 housing for the electronics resp. in maximum values:  
 in the execution with the 2 cell housing, U<sub>i</sub> = 30 V  
 in the terminal housing) I<sub>i</sub> = 131 mA  
 P<sub>i</sub> = 983 mW

The effective internal capacitances and inductances are negligibly small.

The max. length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing (2 cell housing) is 28 m.

The intrinsically safe supply and signal circuit is safe galvanically separated from the parts which can be earthed.

