

Safety Manual

VEGABAR series 80

Two-wire 4 ... 20 mA/HART

and Secondary sensors

With SIL qualification



Document ID: 48369



VEGA

Contents

1 Document language	3
2 Scope	4
2.1 Instrument version	4
2.2 Application area	4
2.3 SIL conformity	5
3 Planning	6
3.1 Safety function	6
3.2 Safe state	6
3.3 Prerequisites for operation	6
4 Safety-related characteristics.....	7
4.1 Characteristics acc. to IEC 61508 for process pressure measurement or hydrostatic level measurement	7
4.2 Characteristics acc. to IEC 61508 for applications with Secondary sensor	8
4.3 Characteristics acc. to ISO 13849-1 for process pressure measurement or hydrostatic level measurement	10
4.4 Characteristics acc. to ISO 13849-1 for applications with Secondary sensor	11
4.5 Supplementary information	12
5 Setup	13
5.1 General information.....	13
5.2 Instrument parameter adjustment.....	13
6 Diagnostics and servicing	15
6.1 Behaviour in case of failure	15
6.2 Repair	15
7 Proof test	16
7.1 General information.....	16
7.2 Test 1: Without checking the process variable	16
7.3 Test 2: With check of the process variable	17
8 Appendix A: Test report	18
9 Appendix B: Term definitions.....	19
10 Supplement C: SIL conformity.....	20

1 Document language

DE	Das vorliegende <i>Safety Manual</i> für Funktionale Sicherheit ist verfügbar in den Sprachen Deutsch, Englisch, Französisch und Russisch.
EN	The current <i>Safety Manual</i> for Functional Safety is available in German, English, French and Russian language.
FR	Le présent <i>Safety Manual</i> de sécurité fonctionnelle est disponible dans les langues suivantes: allemand, anglais, français et russe.
RU	Данное руководство по функциональной безопасности <i>Safety Manual</i> имеется на немецком, английском, французском и русском языках.

2 Scope

2.1 Instrument version

This safety manual applies to pressure transmitters

VEGABAR 81, 82, 83, 86, 87

VEGABAR 81, 82, 83, 86, 87 Secondary-Sensor

Electronics types:

- Two-wire 4 ... 20 mA/HART with SIL qualification
- Two-wire 4 ... 20 mA/HART with SIL qualification and supplementary electronics "Additional current output 4 ... 20 mA"
- Secondary electronics for electronic differential pressure with SIL qualification

Valid versions:

- from HW Ver 1.0.0
- from SW Ver 1.0.0
- Secondary electronics from HW Ver 1.0.0



The climate-compensated versions are excluded from safety-relevant applications!

2.2 Application area

The pressure transmitter can be used in a safety-related system according to IEC 61508 in the modes *low demand mode* or *high demand mode* for the measurement of the following process variables:

- Process pressure measurement
- Hydrostatic level measurement

With Secondary sensor:

- Differential pressure measurement
- Flow measurement
- Density measurement
- Interface measurement

Due to the systematic capability SC3 this is possible up to:

- SIL2 in single-channel architecture
- SIL3 in multiple channel architecture

The following interface can be used to output the measured value:

- Current output: 4 ... 20 mA



The following interfaces are only permitted for parameter adjustment and for informative use:

- HART
- Display and adjustment module PLICSCOM (also via Bluetooth)
- VEGACONNECT (also via Bluetooth)
- Current output II ¹⁾

¹⁾ Only with instrument version with supplementary electronics "Additional current output 4 ... 20 mA".

2.3 SIL conformity

The SIL conformity was judged and certified independently by *TÜV Rheinland* according to IEC 61508:2010 (Ed.2) (verification documents see "*Supplement*").

SIL The certificate is valid for the entire service life of all instruments that were sold before the certificate expired!

3 Planning

3.1 Safety function

Safety function

The transmitter generates on its current output a signal between 3.8 mA and 20.5 mA corresponding to the process variable. This analogue signal is fed to a connected processing system to monitor the following conditions:

- Exceeding a defined limit value of the process variable
- Falling below a defined limit value of the process variable
- Monitoring of a defined range of the process variable

Safety tolerance

For the design of the safety function, the following aspects must be taken into account with regard to the tolerances:

- Due to undetected failures in the range between 3.8 mA and 20.5 mA, an incorrect output signal can be generated which deviates from the real measured value by up to 2 %
- Due to the special application conditions, increased measurement deviations can be caused (see Technical data in the operating instructions)

3.2 Safe state

Safe state

The safe state of the current output depends on the safety function and the characteristics set on the sensor.

Characteristics	Monitoring upper limit value	Monitoring lower limit value
4 ... 20 mA	Output current \geq Switching point	Output current \leq Switching point
20 ... 4 mA	Output current \leq Switching point	Output current \geq Switching point

Fault signals in case of malfunction

Possible fault currents:

- ≤ 3.6 mA ("fail low")
- > 21 mA ("fail high")

3.3 Prerequisites for operation

Instructions and restrictions

- The measuring system should be used appropriately taking pressure, temperature, density and chemical properties of the medium into account. The application-specific limits must be observed.
- The specifications according to the operating instructions manual, particularly the current load on the output circuits, must be kept within the specified limits
- Existing communication interfaces (e. g. HART, USB) are not used for transmission of the safety-relevant measured value
- The instructions in chapter " *Safety-related characteristics* ", paragraph " *Supplementary information* " must be noted
- All parts of the measuring chain must correspond to the planned " *Safety Integrity Level (SIL)* "

4 Safety-related characteristics

4.1 Characteristics acc. to IEC 61508 for process pressure measurement or hydrostatic level measurement

VEGABAR 82, 83, 86, 87

Parameter	Value
Safety Integrity Level	SIL2 in single-channel architecture SIL3 in multiple channel architecture ²⁾
Hardware fault tolerance	HFT = 0
Instrument type	Type B
Mode	Low demand mode, High demand mode
SFF	> 90 %
MTBF ³⁾	0.50 x 10 ⁸ h (57 years)
Diagnostic test interval ⁴⁾	< 30 min

Failure rates

λ_s	λ_{DD}	λ_{DU}	λ_H	λ_L	λ_{AD}
0 FIT	1121 FIT	44 FIT	9 FIT	59 FIT	34 FIT

PFD _{AVG}	0.037 x 10 ⁻²	(T1 = 1 year)
PFD _{AVG}	0.054 x 10 ⁻²	(T1 = 2 years)
PFD _{AVG}	0.106 x 10 ⁻²	(T1 = 5 years)
PFH	0.044 x 10 ⁻⁶ 1/h	

Proof Test Coverage (PTC)

Test type ⁵⁾	Remaining failure rate of dangerous undetected failures	PTC
Test 1	21 FIT	52 %
Test 2	2 FIT	95 %

VEGABAR 81

Parameter	Value
Safety Integrity Level	SIL2 in single-channel architecture SIL3 in multiple channel architecture ⁶⁾
Hardware fault tolerance	HFT = 0
Instrument type	Type B

²⁾ Homogeneous redundancy possible, because systematic capability SC3.

³⁾ Including errors outside the safety function.

⁴⁾ Time during which all internal diagnoses are carried out at least once.

⁵⁾ See section "Proof test".

⁶⁾ Homogeneous redundancy possible, because systematic capability SC3.

Parameter	Value
Mode	Low demand mode, High demand mode
SFF	> 90 %
MTBF ⁷⁾	0.57 x 10 ⁶ h (65 years)
Diagnostic test interval ⁸⁾	< 30 min

Failure rates

λ_s	λ_{DD}	λ_{DU}	λ_H	λ_L	λ_{AD}
0 FIT	981 FIT	77 FIT	9 FIT	59 FIT	34 FIT

PFD _{AVG}	0.065 x 10 ⁻²	(T1 = 1 year)
PFD _{AVG}	0.096 x 10 ⁻²	(T1 = 2 years)
PFD _{AVG}	0.188 x 10 ⁻²	(T1 = 5 years)
PFH	0.077 x 10 ⁻⁶ 1/h	

Proof Test Coverage (PTC)

Test type ⁹⁾	Remaining failure rate of dangerous undetected failures	PTC
Test 1	56 FIT	28 %
Test 2	2 FIT	97 %

4.2 Characteristics acc. to IEC 61508 for applications with Secondary sensor

Device combination consisting of VEGABAR 82, 83, 86 or 87

Parameter	Value
Safety Integrity Level	SIL2 in single-channel architecture SIL3 in multiple channel architecture ¹⁰⁾
Hardware fault tolerance	HFT = 0
Instrument type	Type B
Mode	Low demand mode, High demand mode
SFF	> 90 %
MTBF ¹¹⁾	0.39 x 10 ⁶ h (44 years)
Diagnostic test interval ¹²⁾	< 30 min

⁷⁾ Including errors outside the safety function.

⁸⁾ Time during which all internal diagnoses are carried out at least once.

⁹⁾ See section "Proof test".

¹⁰⁾ Homogeneous redundancy possible, because systematic capability SC3.

¹¹⁾ Including errors outside the safety function.

¹²⁾ Time during which all internal diagnoses are carried out at least once.

Failure rates

λ_S	λ_{DD}	λ_{DU}	λ_H	λ_L	λ_{AD}
0 FIT	1406 FIT	63 FIT	9 FIT	59 FIT	34 FIT

PFD _{AVG}	0.054 x 10 ⁻²	(T1 = 1 year)
PFD _{AVG}	0.079 x 10 ⁻²	(T1 = 2 years)
PFD _{AVG}	0.154 x 10 ⁻²	(T1 = 5 years)
PFH	0.063 x 10 ⁻⁶ 1/h	

Proof Test Coverage (PTC)

Test type ¹³⁾	Remaining failure rate of dangerous undetected failures	PTC
Test 1	40 FIT	36 %
Test 2	3 FIT	95 %

Device combination consisting of a VEGABAR 81 and a VEGABAR 82, 83, 86 or 87

Parameter	Value
Safety Integrity Level	SIL2 in single-channel architecture SIL3 in multiple channel architecture ¹⁴⁾
Hardware fault tolerance	HFT = 0
Instrument type	Type B
Mode	Low demand mode, High demand mode
SFF	> 90 %
MTBF ¹⁵⁾	0.43 x 10 ⁶ h (50 years)
Diagnostic test interval ¹⁶⁾	< 30 min

Failure rates

λ_S	λ_{DD}	λ_{DU}	λ_H	λ_L	λ_{AD}
0 FIT	1266 FIT	97 FIT	9 FIT	59 FIT	34 FIT

PFD _{AVG}	0.082 x 10 ⁻²	(T1 = 1 year)
PFD _{AVG}	0.120 x 10 ⁻²	(T1 = 2 years)
PFD _{AVG}	0.235 x 10 ⁻²	(T1 = 5 years)
PFH	0.097 x 10 ⁻⁶ 1/h	

¹³⁾ See section "Proof test".

¹⁴⁾ Homogeneous redundancy possible, because systematic capability SC3.

¹⁵⁾ Including errors outside the safety function.

¹⁶⁾ Time during which all internal diagnoses are carried out at least once.

Proof Test Coverag (PTC)

Test type ¹⁷⁾	Remaining failure rate of dangerous undetected failures	PTC
Test 1	75 FIT	22 %
Test 2	3 FIT	97 %

Device combination consisting of VEGABAR 81

Parameter	Value
Safety Integrity Level	SIL2 in single-channel architecture SIL3 in multiple channel architecture ¹⁸⁾
Hardware fault tolerance	HFT = 0
Instrument type	Type B
Mode	Low demand mode, High demand mode
SFF	> 90 %
MTBF ¹⁹⁾	0.49 x 10 ⁶ h (56 years)
Diagnostic test interval ²⁰⁾	< 30 min

Failure rates

λ_S	λ_{DD}	λ_{DU}	λ_H	λ_L	λ_{AD}
0 FIT	1124 FIT	132 FIT	9 FIT	59 FIT	34 FIT

PFD _{AVG}	0.111 x 10 ⁻²	(T1 = 1 year)
PFD _{AVG}	0.163 x 10 ⁻²	(T1 = 2 years)
PFD _{AVG}	0.320 x 10 ⁻²	(T1 = 5 years)
PFH	0.132 x 10 ⁻⁶ 1/h	

Proof Test Coverag (PTC)

Test type ²¹⁾	Remaining failure rate of dangerous undetected failures	PTC
Test 1	110 FIT	16 %
Test 2	4 FIT	97 %

4.3 Characteristics acc. to ISO 13849-1 for process pressure measurement or hydrostatic level measurement

The transmitter has been manufactured and verified using principles that demonstrate its suitability and reliability for safety-related applications. It can therefore be considered a "*proven component*" according to DIN EN ISO 13849-1.

¹⁷⁾ See section "Proof test".

¹⁸⁾ Homogeneous redundancy possible, because systematic capability SC3.

¹⁹⁾ Including errors outside the safety function.

²⁰⁾ Time during which all internal diagnoses are carried out at least once.

²¹⁾ See section "Proof test".

Derived from the safety-related characteristics, the following figures result according to ISO 13849-1 (safety of machinery): ²²⁾

VEGABAR 82, 83, 86, 87

Parameter	Value
MTTFd	90 years
DC	97 %
Performance Level	4.35 x 10 ⁻⁸ 1/h

VEGABAR 81

Parameter	Value
MTTFd	98 years
DC	93 %
Performance Level	7.75 x 10 ⁻⁸ 1/h

4.4 Characteristics acc. to ISO 13849-1 for applications with Secondary sensor

The transmitter has been manufactured and verified using principles that demonstrate its suitability and reliability for safety-related applications. It can therefore be considered a " *proven component*" according to DIN EN ISO 13849-1.

Derived from the safety-related characteristics, the following figures result according to ISO 13849-1 (safety of machinery): ²³⁾

Device combination consisting of VEGABAR 82, 83, 86 or 87

Parameter	Value
MTTFd	73 years
DC	96 %
Performance Level	6.33 x 10 ⁻⁸ 1/h

Device combination consisting of a VEGABAR 81 and a VEGABAR 82, 83, 86 or 87

Parameter	Value
MTTFd	78 years
DC	93 %
Performance Level	9.72 x 10 ⁻⁸ 1/h

Device combination consisting of VEGABAR 81

Parameter	Value
MTTFd	84 years
DC	90 %
Performance Level	1.32 x 10 ⁻⁷ 1/h

²²⁾ ISO 13849-1 was not part of the certification of the instrument.

²³⁾ ISO 13849-1 was not part of the certification of the instrument.

4.5 Supplementary information

Determination of the failure rates

The failure rates of the instruments were determined by an FMEDA according to IEC 61508. The calculations are based on failure rates of the components according to **SN 29500**:

All figures refer to an average ambient temperature of 40 °C (104 °F) during the operating time. For higher temperatures, the values should be corrected:

- Continuous application temperature > 50 °C (122 °F) by factor 1.3
- Continuous application temperature > 60 °C (140 °F) by factor 2.5

Similar factors apply if frequent temperature fluctuations are expected.

Assumptions of the FMEDA

- The failure rates are constant. Take note of the useful service life of the components according to IEC 61508-2.
- Multiple failures are not taken into account
- Wear on mechanical parts is not taken into account
- Failure rates of external power supplies are not taken into account
- The environmental conditions correspond to an average industrial environment

Calculation of PFD_{AVG}

The values for PFD_{AVG} specified above were calculated as follows for a 1oo1 architecture:

$$\text{PFD}_{\text{AVG}} = \frac{\text{PTC} \times \lambda_{\text{DU}} \times \text{T1}}{2} + \lambda_{\text{DD}} \times \text{MTTR} + \frac{(1 - \text{PTC}) \times \lambda_{\text{DU}} \times \text{LT}}{2}$$

Parameters used:

- T1 = Proof Test Interval
- PTC = 90 %
- LT = 10 years
- MTTR = 8 h

Boundary conditions relating to the configuration of the processing unit

A connected control and processing unit must have the following properties:

- The failure signals of the measuring system are judged according to the idle current principle
- "fail low" and "fail high" signals are interpreted as a failure, whereupon the safe state must be taken on

If this is not the case, the respective percentages of the failure rates must be assigned to the dangerous failures and the values stated in chapter "Safety-related characteristics" redetermined!

Multiple channel architecture

Due to the systematic capability SC3, this instrument can also be used in multiple channel systems up to SIL3, also with a homogeneously redundant configuration.

The safety-related characteristics must be calculated especially for the selected structure of the measuring chain using the stated failure rates. In doing this, a suitable Common Cause Factor (CCF) must be considered (see IEC 61508-6, appendix D).

5 Setup

5.1 General information

Mounting and installation Take note of the mounting and installation instructions in the operating instructions manual.

Setup must be carried out under process conditions.

5.2 Instrument parameter adjustment

Tools The following adjustment units are permitted for parameterization of the safety function:

- Display and adjustment module
- The DTM suitable for VEGABAR 80 in conjunction with an adjustment software according to the FDT/DTM standard, e. g. PACT-ware
- The device description EDD suitable for VEGABAR 80

The parameter adjustment is described in the operating instructions manual.

SIL Wireless connection is also possible with existing Bluetooth function.

SIL The documentation of the device settings is only possible with the full version of the DTM Collection.

Safety-relevant parameters

For protection against unwanted or unauthorized adjustment, the set parameters must be protected against unauthorized access. For this reason, the instrument is shipped in locked condition. The PIN in delivery status is "0000".

The default values of the parameters are listed in the operating instructions. When shipped with customer-specific parameter settings, the instrument is accompanied by a list of the values differing from the default values.

By means of the serial number this list can also be downloaded at "www.vega.com", "*Instrument search (serial number)*".

Safe parameterization

To avoid or detect possible errors during parameter adjustment for unsafe operating environments, a verification procedure is used that allows the safety-relevant parameters to be checked.

Parameter adjustment proceeds according to the following steps:

- Unlock adjustment
- Change parameters
- Lock adjustment and verify modified parameters

The exact process is described in the operating instructions.

SIL Wireless connection is also possible with existing Bluetooth function.

SIL The instrument is shipped in locked condition!

SIL For verification, all modified, safety-relevant and non safety-relevant parameters are shown.

The verification texts are displayed either in German or, when any other menu language is used, in English.

Unsafe device status**Warning:**

When adjustment is unlocked, the safety function must be considered as unreliable. This applies until the parameters are verified and the adjustment is locked again. If the parameter adjustment process is not carried out completely, the device statuses described in the operating instructions must be taken into consideration.

If necessary, you must take other measures to maintain the safety function.

Instrument reset**Warning:**

In case a reset to "*Delivery status*" or "*Basic setting*" is carried out, all safety-relevant parameters must be checked or set anew.

6 Diagnostics and servicing

6.1 Behaviour in case of failure

Internal diagnosis

The instrument permanently monitored by an internal diagnostic system. If a malfunction is detected, a fault signal will be output on the safety-relevant output (see section " *Safe status*").

The diagnosis interval is specified in chapter " *Safety-related characteristics*".

Error messages in case of malfunction

A fault message coded according to the type of fault is output. The fault messages are listed in the operating instructions.



If failures are detected, the entire measuring system must be shut down and the process held in a safe state by other measures.

The occurrence of a failure must be reported to the manufacturer (including a description of the fault and whether it is a dangerous, undetected failure). The device must be returned to the manufacturer for examination.

6.2 Repair

Electronics exchange

The procedure is described in the operating instructions manual. Note the instructions for parameter adjustment and setup.

Software update

The procedure is described in the operating instructions manual. Note the instructions for parameter adjustment and setup.

7 Proof test

7.1 General information

Objective

To identify possible dangerous, undetected failures, the safety function must be checked by a proof test at adequate intervals. It is the user's responsibility to choose the type of testing. The time intervals are determined by the selected PFD_{AVG} (see chapter "Safety-related characteristics").

For documentation of these tests, the test protocol in the appendix can be used.

If one of the tests proves negative, the entire measuring system must be switched out of service and the process held in a safe state by means of other measures.

In a multiple channel architecture this applies separately to each channel.

Preparation

- Determine safety function (mode, switching points)
- If necessary, remove the instruments from the safety chain and maintain the safety function by other means
- Provide an approved adjustment unit

Unsafe device status



Warning:

During the function test, the safety function must be treated as unreliable. Take into account that the function test influences downstream connected devices.

If necessary, you must take other measures to maintain the safety function.

After the function test, the status specified for the safety function must be restored.

7.2 Test 1: Without checking the process variable

Conditions

- Instrument can remain in installed condition
- Output signal corresponds to the assigned process variable
- Device status in the menu Diagnosis: "OK"

Procedure

1. Carry out a re-start (separate the test item at least 10 seconds from mains voltage)
2. Simulate upper fault current > 21 mA and check current output (test line resistor)
3. Simulate lower fault current ≤ 3.6 mA and check current output (test quiescent currents)



Note

Test 1 detects no failures in the probably used Secondary sensor!

Expected result

Step 1: Output signal corresponds to the assigned process variable and the device status in the menu Diagnosis is "OK"

Step 2: Output signal corresponds to > 21 mA

Step 3: Output signal corresponds to ≤ 3.6 mA

Proof Test CoverageSee *Safety-related characteristics***7.3 Test 2: With check of the process variable****Conditions**

- Instrument can remain in installed condition
- Output signal corresponds to the assigned process variable
- Device status in the menu Diagnosis: "OK"

Procedure

1. Carry out a re-start (separate the test item at least 10 seconds from mains voltage)
2. Simulate upper fault current > 21 mA and check current output (test line resistor)
3. Simulate lower fault current ≤ 3.6 mA and check current output (test quiescent currents)
4. Reference pressure measurement at 0 % - 50 % - 90 ... 100 % of the adjusted measuring range in use (4 mA - 12 mA - 18,4 ... 20 mA)
5. If necessary, sensor calibration through service log-in and subsequent reference pressure measurement as under point 4

**Note**

When a Secondary sensor is used, also this sensor must be checked with a reference pressure measurement acc. to point 4!

Expected result

Step 1: Output signal corresponds to the assigned process variable and the device status in the menu Diagnosis is "OK"

Step 2: Output signal corresponds to > 21 mA

Step 3: Output signal corresponds to ≤ 3.6 mA

Step 4 and 5: Output signal corresponds to the reference pressure

Proof Test CoverageSee *Safety-related characteristics*

8 Appendix A: Test report

Identification	
Company/Tester	
Plant/Instrument TAG	
Meas. loop TAG	
Instrument type/Order code	
Instrument serial number	
Date, setup	
Date of the last proof test	

Test reason/Test scope	
	Setup without checking the process variable
	Setup with check of the process variable
	Proof test without checking the process variable
	Proof test with check of the process variable

Mode	
	Monitoring of an upper limit value
	Monitoring a lower limit value
	Range monitoring

Adjusted parameters of the safety function are documented	
	Yes
	No

Test result (if necessary)				
Test point	Process variable ²⁴⁾	Expected measured value	Real value	Test result
Value 1				
Value 2				
Value 3				
Value 4				
Value 5				

Confirmation	
Date:	Signature:

²⁴⁾ e.g.: limit level, level, interface, pressure, flow, density

9 Appendix B: Term definitions

Abbreviations

SIL	Safety Integrity Level (SIL1, SIL2, SIL3, SIL4)
SC	Systematic Capability (SC1, SC2, SC3, SC4)
HFT	Hardware Fault Tolerance
SFF	Safe Failure Fraction
PFD_{AVG}	Average Probability of dangerous Failure on Demand
PFH	Average frequency of a dangerous failure per hour (Ed.2)
FMEDA	Failure Mode, Effects and Diagnostics Analysis
FIT	Failure In Time (1 FIT = 1 failure/10 ⁹ h)
λ_{SD}	Rate for safe detected failure
λ_{SU}	Rate for safe undetected failure
λ_S	$\lambda_S = \lambda_{SD} + \lambda_{SU}$
λ_{DD}	Rate for dangerous detected failure
λ_{DU}	Rate for dangerous undetected failure
λ_H	Rate for failure, who causes a high output current (> 21 mA)
λ_L	Rate for failure, who causes a low output current (≤ 3.6 mA)
λ_{AD}	Rate for diagnostic failure (detected)
λ_{AU}	Rate for diagnostic failure (undetected)
DC	Diagnostic Coverage
PTC	Proof Test Coverage (Diagnostic coverage for manual proof tests)
T1	Proof Test Interval
LT	Useful Life Time
MTBF	Mean Time Between Failure = MTTF + MTTR
MTTF	Mean Time To Failure
MTTR	IEC 61508, Ed1: Mean Time To Repair IEC 61508, Ed2: Mean Time To Restoration
$MTTF_d$	Mean Time To dangerous Failure (ISO 13849-1)
PL	Performance Level (ISO 13849-1)

10 Supplement C: SIL conformity

SIL Manufacturer declaration, NE130: Form B.1

Manufacturer			
VEGA Grieshaber KG Am Hohenstein 113, D-77761 Schiltach, Germany		VEGA Americas, Inc. 4241 Allendorf Drive, Cincinnati, Ohio 45209, USA	
General			
Device designation and permissible types	VEGABAR 80 series Two-wire 4...20mA/HART with SIL qualification Item-No: B8*.....A***** Slave sensor with SIL qualification Item-No: B8*.....T*****		
Safety-related output signal	4...20 mA		
Fault current	≥ 21 mA; ≤ 3,6 mA		
Process variable / function	Pressure transmitter for process pressure or hydrostatic level measurement In additional with slave sensor: differential pressure, deviation flow, density or interface measurements		
Safety function(s)	Generation of a measured value to monitor MIN / MAX / Range		
Device type acc. to IEC 61508-2	<input type="checkbox"/> Type A	<input checked="" type="checkbox"/> Type B	
Operating mode	<input checked="" type="checkbox"/> Low Demand Mode	<input checked="" type="checkbox"/> High Demand or Continuous Mode	
Valid Hardware-Version	≥ 1.0.0		
Valid Software-Version	≥ 1.0.0		
Safety manual	Document ID: 48369		
Type of evaluation (check only one box)	<input checked="" type="checkbox"/> Complete HW/SW evaluation parallel to development incl. FMEDA and change request acc. to IEC 61508-2, 3 <input type="checkbox"/> Evaluation of "Prior use" performance for HW/SW incl. FMEDA and change request acc. to IEC 61508-2, 3 <input type="checkbox"/> Evaluation of HW/SW field data to verify „prior use“ acc. to IEC 61511 <input type="checkbox"/> Evaluation by FMEDA acc. to IEC61508-2 for devices without software		
Evaluation through (incl. certificate no.)	TÜV Rheinland Industrie Service GmbH, Nr./No.: 968/EZ 640.04/20		
Test documents	Development documents	Test reports	Data sheets
Safety Integrity			
Systematic Capability (SC)		<input type="checkbox"/> SC2 for SIL2	<input checked="" type="checkbox"/> SC3 for SIL3
Hardware Safety Integrity	Single-channel use (HFT=0)	<input checked="" type="checkbox"/> SIL2 capable	<input type="checkbox"/> SIL3 capable
	Multi-channel use (HFT≥1)	<input type="checkbox"/> SIL2 capable	<input checked="" type="checkbox"/> SIL3 capable
FMEDA	Version		
	VEGABAR 82, 83, 86, 87	VEGABAR 81	
Safety function(s)	MIN / MAX / Range		MIN / MAX / Range
λ_{ou} (FIT = Failure In Time / 10 ⁹ h)	44 FIT	77 FIT	
λ_{od}	1223 FIT	1083 FIT	
λ_{su}	0 FIT	0 FIT	
λ_{sp}	0 FIT	0 FIT	
SFF (Safe Failure Fraction)	> 90 %	> 90 %	
PTC (Proof Test Coverage)	Test 1: 52% Test 2: 95%, with checking the process value	Test 1: 28% Test 2: 97%, with checking the process value	
FMEDA data source	SN 29500		

SIL Manufacturer declaration, NE130: Form B.1

FMEDA	Version with slave sensor consisting of a combination of		
	two VEGABAR 82, 83, 86 or 87	one VEGABAR 81 and one VEGABAR 82, 83, 86 or 87	two VEGABAR 81
Safety function(s)	MIN / MAX / Range	MIN / MAX / Range	MIN / MAX / Range
λ_{Du} (FIT = Failure In Time / 10^6 h)	63 FIT	97 FIT	132 FIT
λ_{Dp}	1508 FIT	1368 FIT	1226 FIT
λ_{Su}	0 FIT	0 FIT	0 FIT
λ_{Sp}	0 FIT	0 FIT	0 FIT
SFF (Safe Failure Fraction)	> 90 %	> 90 %	> 90 %
PTC (Proof Test Coverage)	Test 1: 36% Test 2: 95% ¹⁾	Test 1: 22% Test 2: 97% ¹⁾	Test 1: 16% Test 2: 97% ¹⁾
	¹⁾ Test 2 with checking the process value		
FMEDA data source	SN 29500		

Declaration	
<input checked="" type="checkbox"/>	Our internal company quality management system ensures information on safety-related systematic faults which become evident in the future.

Certificate



Nr./No.: 968/EZ 640.04/20

Prüfgegenstand Product tested	Druckmessumformer Pressure Transmitter	Zertifikats- inhaber Certificate holder	VEGA Grieshaber KG Am Hohenstein 113 77761 Schiltach Germany
Typbezeichnung Type designation	VEGABAR 81, VEGABAR 82, VEGABAR 83, VEGABAR 86, VEGABAR 87		
Prüfgrundlagen Codes and standards	IEC 61508 Parts 1-7:2010 IEC 61511-1:2016+ Corr.1:2016 + AMD1:2017 IEC 61326-3-2:2017 IEC 61010-1:2017 + Corr.1:2019		
Bestimmungsgemäße Verwendung Intended application	Druckmessumformung für Absolut- oder Differenzdruck in Flüssigkeiten, Gasen und viskosen Medien. Die Produkte erfüllen die Anforderungen der oben aufgeführten Prüfgrundlagen. Ein einzelner Sensor entspricht einer HFT = 0 - Struktur und kann in sicherheitsgerichteten Anwendungen bis SIL 2 entsprechend IEC 61508 / IEC 61511 eingesetzt werden. Bei zweikanaliger Anwendung (HFT = 1) können die Sensoren bis SIL 3 / SC 3 nach IEC 61508 / IEC 61511 eingesetzt werden. Pressure transmitter for absolute or differential pressure in liquids, gases and viscous media. The products comply with the requirements of the applicable standards as listed above. A single sensor can be used in a HFT = 0 structure in applications up to SIL 2 and in redundant application (HFT = 1) up to SIL 3 / SC 3 in accordance with IEC 61508 / IEC 61511.		
Besondere Bedingungen Specific requirements	Die zugehörigen Betriebsanleitungen und das Safety Manual sind zu beachten. The Operating Instructions and the Safety Manual shall be considered.		
Gültig bis / Valid until 2025-10-27			

Der Ausstellung dieses Zertifikates liegt eine Evaluierung entsprechend dem Zertifizierungsprogramm CERT FSP3 V1.0:2017 in der aktuellen Version zugrunde, deren Ergebnisse im Bericht Nr. 968/EZ 640.04/20 vom 27.10.2020 dokumentiert sind. Dieses Zertifikat ist nur gültig für Erzeugnisse, die mit dem Prüfgegenstand übereinstimmen.

The issue of this certificate is based upon an evaluation in accordance with the Certification Program CERT FSP3 V1.0:2017 in its actual version, whose results are documented in Report No. 968/EZ 640.04/20 dated 2020-10-27. This certificate is valid only for products, which are identical with the product tested.

TÜV Rheinland Industrie Service GmbH
Bereich Automation
Funktionale Sicherheit
Am Grauen Stein, 51105 Köln

Köln, 2020-10-27

Certification Body Safety & Security for Automation & Grid

GSO B
Dipl.-Ing. Gebhard Bouwer

www.fs-products.com
www.tuv.com

DAkkS
Deutsche
Akkreditierungsstelle
D-28-11052-02-01

TÜVRheinland®
Precisely Right.



Printing date:

VEGA

All statements concerning scope of delivery, application, practical use and operating conditions of the sensors and processing systems correspond to the information available at the time of printing.

Subject to change without prior notice

© VEGA Grieshaber KG, Schiltach/Germany 2021



48369-EN-210114

VEGA Grieshaber KG
Am Hohenstein 113
77761 Schiltach
Germany

Phone +49 7836 50-0
Fax +49 7836 50-201
E-mail: info.de@vega.com
www.vega.com